



# Laboratory Testing Report

Call or Text US  
(833) YESLABS, (833) 937-5227

Email Us:  
orders@yeslabslc.com

Find us on the Web  
WWW.YESLABSLLC.COM

<b>Property Location Information</b>	<b>Property:</b>	<b>Address:</b> 111 Anywhere Drive	<b>City:</b> Anywhere	<b>State:</b> Indiana	<b>Zip Code:</b> 46219
<b>General Information</b>	<b>Client:</b> Access Home Inspection	<b>Sample Source:</b> Private Well		<b>Sampled By:</b> YES Field Tech	<b>Initials:</b> MA
<b>Compliance Details</b>	<b>System:</b>	<b>PWSID #:</b>			<b>WSSN #:</b>
<b>Date / Time Received</b>	07-13-2023 10:08 AM			<b>County:</b> Hancock County	<b>Well Permit #:</b>

## Test Results

Sample Number	Eval Number	Sample Type	Sample Location	Test Performed	Test Result	Result Pass / Fail	Date / Time Sampled	Date / Time Started	Date / Time Analyzed	Method	Unit of Measure	MCL	AL
232669			Kitchen Sink	Total E.coli	Present	F	07-12-2023 10:32 AM	07-13-2023 11:20 AM	07-14-2023 11:34 AM	SM 9223 B - Colilert	per 100 mL	0.000001	
232669			Kitchen Sink	Total Coliform	Present	F	07-12-2023 10:32 AM	07-13-2023 11:20 AM	07-14-2023 11:34 AM	SM 9223 B - Colilert	per 100 mL	0.000001	
232253			Kitchen Sink	Chlorine Residual	0.0		07-12-2023 10:33 AM		07-13-2023 10:11 AM	HACH Test Strips	mg Cl2/L		
232253			Kitchen Sink	Temperature	21.3		07-12-2023 10:33 AM		07-13-2023 10:11 AM	Orion Star A215	°C		
232253			Kitchen Sink	pH	7.33		07-12-2023 10:33 AM		07-13-2023 10:11 AM	Orion Star A215	N/A		
232253			Kitchen Sink	Nitrite	<0.05	P	07-12-2023 10:33 AM		07-13-2023 06:17 PM	US EPA 353.2	mg NO2-N/L	1	
232253			Kitchen Sink	Nitrate	<0.50	P	07-12-2023 10:33 AM		07-13-2023 08:45 PM	US EPA 353.2	mg NO3-N/L	10	
232169			Kitchen Sink	Lead	2.36	PC	07-12-2023 10:33 AM		07-14-2023 02:59 PM	US EPA 200.5	ug Pb/L		15

Edgar Ramos  
Laboratory Manager

Carla Sue Snow  
Laboratory Technician

Ellie Highland  
Laboratory Technician

Your Environmental Services, LLC, 4609 Grape Road, STE D5, Mishawaka, Indiana 46545  
Indiana Microbiology Certification: M-76-06, Indiana Chemistry Certification: C-71-04, Michigan Microbiology/Inorganic Chemistry Certification: 9995

For Assistance Interpreting Your Report Results  
Please visit our website: [WWW.YESLABSLLC.COM](http://WWW.YESLABSLLC.COM)