

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 50

Dated: 14/5/24

It is certified that an inspection team headed by Dr. Dalveer Singh Rawat, Medical superintendent (Name of Officers with designation) from Community Health center, Block-Sasni, District-Hathras PHED inspected the Vishnave Global School, Thulai, Hathras-Sikandrara Road, Hathras on 16/09/24 (date of inspection) and on the basis of Water Test Rport (Attached) bearing no. UPJN/24/09/208 dated 16-09-24 of U.P. Jal Nigam Agra (Rural) (PHED Lab) certified that the Vishnave Global School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U. T. Govt.

The certificate is valid till 15/09/26.

Name

Dalveer Singh

Designation.

Medical SuperintendentName & Address of the Office/ Department: C.H.C. Sasni

To,

Manger,

Vishnave Global School,

Thulai, Hathras Sikandrara Road, Hathras

(Name & Address of the Institution)

Vishnave Global School
Thulai (Hathras)

VISHNAVE GLOBAL SCHOOL

President / Secretary


Note: The certificate is to be issued by authorized officer/ PHED Lab/ Local bodies



Regional Level Water Analysis Laboratory
Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002

TEST REPORT					
Report No:	UPJN/AGR/24/09/208		Issue Date:	16/09/2024	Page No 1
Customer Details					
Office Name and Address		MANEJAR VISHNAVE GLOBAL SCHOOL HATHARAS			
Ref Letter No & Date		ZERO/13/09/2024			
Basic details of sample					
Receipt No.	624	Block			
District	HATHARAS	Village/city	THULAI		
Gram Panchayat	-	Location	HATHARAS SIKANDRA RAO ROAD		
Water Source	R.O. WATER	Sample No.	1		
Quantity of Sample	1 Lt.	Date of Collection	13/09/2024		
Receiving Date	13/09/2024	S. Collector	PRAMOD KUMAR CHOUNHAN		
Sample Depositor	PRAMOD KUMAR CHOUNHAN	Sampling Method	As per IS 17614: Part 1: 2021		
Analysis Start Date	13/09/2024	Analysis Completion Date:	16/09/2024		
Technical Data of Analysis					
S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.09	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity mg/L	0.24	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	142	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.342	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	20	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	56	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	42.4	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	-	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	2.2	200	400	APHA 23 rd Edition 4500-SO ₄ Method E (Turbidity Method) 2017
10	Calcium mg/L	12	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	5.18	30	100	IS 3025 (Part 46):1994(Volumetric Method)
12	Color (Hazen)	-	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method)
13	Taste	-	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)
14	Nitrate (mg/l)	NILL	45	45	APHA 24 Edition -4500 NO ₃ method B (UV Spectrophotometric method:2023)


Principal
Vishnave Global School
Thulai (Hatharas)


FOR - VISHNAVE GLOBAL SCHOOL

President / Secretary



Regional Level Water Analysis Laboratory

Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Amity
Reviewed By-

Sanjay Upman
(Sanjay Upman)
Authorized Signatory:

Testing Lab In charge

Laboratory Contact details
Email- ZlaupjnR@gmail.com

Mob-9761093634

-----End of Report-----

Principal
Principal
Vishnave Global School
Thalai (Harbhag)

FOR - VISHNAVE GLOBAL SCHOOL

President / Secretary