A SAFETY ALERT

PLEASE SHARE THIS INFORMATION

Electrical Arc Incident

Near Fatal Near Miss

Date of Event: 2/2/2024

Location: Lometa

Craft(s) Involved: Electrical Subcontractor

Description of Incident: Two near-fatal incidents occurred during this event:

1.A client representative unknowingly encountered a live 480v power to ground hazard in the work area, narrowly avoiding stepping into the energized zone.

2.An electrician tested live conductors with a spare length of conductor instead of using the ohmmeter, resulting in a large and dangerous arc.

Contributing Factors:

- •Inadequate onsite supervision as per TDLR requirements.
- •Poor workmanship.
- •Deviation from industry best practices in all aspects of work.

Root Cause: Parallel feeds of the new MF building and existing HSP building had crossed wires, causing the 500v breaker to be hot in both the ON and OFF positions.

Corrective Actions:

1.Subcontractors to perform correct isolation verification whenever a construction disconnect is made to ensure no energized equipment is outstanding.

2.Integrated Water Services (IWS) to develop and implement a Subcontractor Qualification program for all subcontractors.

3.Development of an Energized Electrical Work Permit by IWS to ensure unauthorized hot work is not performed without a well-designed plan and approval from the Regional Vice President (RVP).

4.A journeyman electrician must be present on-site whenever electrical work is performed. 5.All work to be inspected by a third-party electrical inspector, and all deficiencies must be corrected.

6.The electrical subcontractor is required to develop a Quality Assurance/Quality Control (QA/QC) program.

7. Development of a Site Specific Safety Plan (SSSP) by IWS for all projects.

8.Development of a Site Specific Safety Plan (SSSP) by all subcontractors for IWS project work sites.

Conclusion: Safety is paramount in all our operations. These corrective actions are vital steps toward preventing such incidents in the future and ensuring the safety of all personnel involved.