

CarbonFree Kynoch Project Acoustic Assessment Report

H376108-0000-846-066-0001

					
2026-03-13	0	Client Review	M. Andargie	M. Choy	S. Thompson
DATE	REV.	STATUS	PREPARED BY	CHECKED BY	APPROVED BY
				Discipline Lead	Functional Manager

IMPORTANT NOTICE TO READER

This report has been prepared by Hatch Ltd. (Hatch) for the sole and exclusive use of CarbonFree Kynoch Ltd. (the "Client") for the purpose of assisting the Client in making decisions with respect to the development of a proposed solar photovoltaic project and shall not be (a) used for any other purpose, or (b) provided to, relied upon or used by any third party.

This report contains opinions, conclusions and recommendations made by Hatch, using its professional judgment and reasonable care. Any use of or reliance upon this report by the Client is subject to the following conditions:

1. the report being read in the context of and subject to the terms of the agreement between Hatch and the Client including any methodologies, procedures, techniques, assumptions and other relevant terms or conditions that were specified or agreed therein;
2. the report being read as a whole, with sections or parts hereof read or relied upon in context;
3. the conditions of the Project Location may change over time (or may have already changed) due to natural forces or human intervention, and Hatch takes no responsibility for the impact that such changes may have on the accuracy or validity of the observations, conclusions and recommendations set out in this report; and
4. the report is based on information made available to Hatch by the Client or by certain third parties; and unless stated otherwise in the Agreement, Hatch has not verified the accuracy, completeness or validity of such information, makes no representation regarding its accuracy and hereby disclaims any liability in connection therewith.
5. **The noise impact evaluation is based on preliminary design and vendor information with the intention of demonstrating that the CarbonFree Kynoch Project will meet all regulatory requirements for achieving community noise constraints. It should be noted that the noise control features proposed herein may be subject to change prior to the final regulatory submission for alignment with the latest Project information.**

Table of Concordance

The following table of concordance describes the scope of the report herein as per the requirements identified in Table 1 of O. Reg. 359/09 [1].

Item	Document	Requirement per Table 1 of O. Reg. 359/09	Project Type
8	Noise study report	Report to be prepared in accordance with Appendix A of the publication of the Ministry of the Environment and Climate Change entitled, "Basic Comprehensive Certificates of Approval (Air) – User Guide", dated April 2004, as amended from time to time and available from the Ministry.	Class 3 solar facility

Abbreviations and Definitions

AAR	Acoustic Assessment Report
AC	Alternating Current
dB	Decibel
dBA	A-weighted sound level
DC	Direct Current
IEEE	Institute of Electrical and Electronics Engineers
km	Kilometre
kV	Kilovolt
Leq	Equivalent sound level
m/s	Metre per second
MECP	Ministry of the Environment, Climate, and Parks
MVA	Megavolt-ampere
MW	Megawatt
NEMA	National Electrical Manufacturers Association
NPC	Noise Pollution Control
O. Reg.	Ontario Regulation
INV	Inverter System (combined inverter and medium-voltage transformer)
POR	Point of Reception
PV	Photovoltaic
PWC	Predictable Worst Case
REA	Renewable Energy Approval

Table of Contents

Table of Concordance	ii
Abbreviations and Definitions	iii
1. Introduction.....	1
1.1 Approach to Noise Assessment.....	1
1.2 Vibration Sources.....	2
2. Facility Description	2
2.1 Operational Flexibility	2
3. Noise Source Summary	2
3.1 Panel Arrays	2
3.2 Inverter With Integrated Medium-Voltage Transformer	2
3.3 Switchgear	3
3.4 Substation Transformer	3
3.5 Other Nearby Solar Facilities and External Anthropic Noise Sources.....	3
3.6 Ancillary Distribution Lines.....	3
3.7 Excluded Noise Sources.....	3
3.8 Noise Source Summary Table.....	4
4. Points of Reception	7
5. Mitigation Measures Summary.....	9
6. Assessment Criteria	10
7. Acoustic Assessment Summary.....	10
7.1 Analysis Methodology	10
7.2 Predictable Worst-Case Assessment Scenario	11
7.3 Noise Modelling Results	11
8. Conclusion	13
9. References	13

List of Tables

Table 3-1: Excluded Noise Sources.....	4
Table 3-2: Noise Source Summary Table.....	5
Table 4-1: Point of Reception Locations	7
Table 5-1: Mitigation Summary Table	9
Table 6-1: Class 3 Performance Limits.....	10
Table 7-1: Assessment Scenarios	11
Table 7-2: Acoustic Assessment Summary Table	11

List of Appendices

Appendix A Zoning/Land-Use Siting Map

Appendix B Site and Noise Source Layout

Appendix C Noise Source Sound Power Levels and Equipment Vendor Information

Appendix D POR Noise Impact Table and Noise Contour Plot

Appendix E Acoustic Assessment Report Checklist

1. Introduction

CarbonFree Kynoch Ltd. (CarbonFree) is proposing to develop a 154 megawatt (MW) Class 3 solar photovoltaic (PV) project adjacent to Highway 554 in the unincorporated District of Algoma.

The proposed CarbonFree Kynoch Project (hereinafter referred to as 'the Facility') is a renewable energy generation facility which will use solar PV technology to generate electricity. Electricity generated by solar PV panels will be converted from direct current (DC) to alternating current (AC) by inverters and then stepped up (via pad-mounted inverters, medium-voltage transformers and a main substation transformer) to 230 kilovolts (kV) prior to being connected to the existing Hydro One Networks Inc. transmission line.

The Project aims to contribute to the government of Ontario's goal of accelerating new electricity generation from renewable sources to support the province's growing energy needs. Accordingly, CarbonFree intends to enter into an agreement for the sale or supply of electricity, the quantity of which will be commensurate with the nameplate capacity of the facility.

Construction of the Project will commence in early 2027 once the Renewable Energy Approval (REA) and other required permits have been obtained. This Acoustic Assessment Report (AAR) provides an evaluation of the community noise impact of the Facility under predictable worst-case (PWC) noise-emitting operating conditions.

1.1 Approach to Noise Assessment

The AAR follows the Province of Ontario regulations and guidelines: O. Reg. 359/09 [1], PIBS 8472e – "Technical Guide to Renewable Energy Approvals" [2], PIBS 4391e01 – "Basic Comprehensive Certificates of Approval (Air)" [3], and NPC-300 [4]. The Facility's noise performance limit is established as the higher of the 1-hour a-weighted equivalent sound level (Leq) identified for the applicable exclusion limit or the background sound level. No background measurements were taken, so the noise limit has been set to the applicable exclusion limit based on the surrounding receptor classifications. A review of the surrounding community identifies all noise sensitive receptors as Class 3.

A community noise model of the Facility has been developed to assess the noise impact of the nearest points of reception (PORs). The noise study area for modelling was extended 1 km from the outermost noise sources consistent with the approach outlined in the *Technical Guide to Renewable Energy Approvals* [2]. Participating and non-participating receptors were identified including receptors for vacant lots. Acoustic modelling was completed on a PWC basis that determined the equivalent 1-hour noise impact on the identified PORs. There are no other surrounding solar facilities within 1 km of the boundary of the Facility.

1.2 Vibration Sources

The Facility does not have any significant stationary or moving ground-borne vibration sources. As such, a vibration assessment is not required.

2. Facility Description

The Facility is located adjacent to Highway 554 in the unincorporated District of Algoma (Appendix A).

The proposed 154 MW solar facility is comprised of eight solar panel arrays spread over four properties. Each array is isolated by its own switchgear. The panels are routed into 36 SunGrow SG4400, 4.4 megavolt-ampere (MVA) inverter/transformer system (INV) modules. Each switchgear feeds the proposed high-voltage substation located at the north end of the Facility. The Facility is designed to operate during daylight hours, 7 days a week. The proposed layout of the Facility is included in Appendix B.

2.1 Operational Flexibility

The Facility is seeking the inclusion of operational flexibility with its REA application as described under Section 9 of PIBS 8472e [2]. Operational flexibility allows the Facility to make limited modifications to its operations or works without having to seek an amendment to the REA. These permissible operational flexibility changes include:

- Noise from site maintenance equipment including vegetation control, panel washing, snow clearing, access road and infrastructure maintenance.
- In-kind equipment replacements (panels, tracker motors, inverter systems, transformer, switches, etc.).
- Decreasing the number of project components.

3. Noise Source Summary

3.1 Panel Arrays

Panel racks will be fitted with a single axis tracker. The proposed Facility will have one motor per tracker. A sample tracker is provided in Appendix C. The tracker motor operates briefly to tilt the panels into an optimal position for solar radiation exposure. Due to their relatively small size and brief operation, the tracker motors are considered insignificant community noise emission sources.

3.2 Inverter With Integrated Medium-Voltage Transformer

The 4.4 MW AC inverters convert the DC supplied by the PV modules to AC. A 4.4 MVA, 3-phase, liquid-filled transformer will then 'step up' the voltage to 34.5 kV. Each installation will consist of a SunGrow Solar Inverter Skid SG4400 or equivalent inverter system (INV) that combines the inverter and medium-voltage transformer in single container skid.

Noise from the inverter system comes from its air-cooling fans while noise from its medium-voltage transformer is largely from the magnetostriction hum. Due to the tonal nature of the magnetostriction hum, a 5 decibel (dB) tonal penalty is added to the noise emission of entire inverter system. Full calculations can be found in Appendix C.

3.3 Switchgear

The local panel array and substation switchgears are a combination of switches, fuses and circuit breakers used to safely isolate arrays or the entire facility for maintenance. Switchgear control panel cooling fans are small and are located indoors. Therefore, the switchgears are considered insignificant community noise emission sources.

3.4 Substation Transformer

The Facility contains one large 172 MVA transformer that will 'step up' the voltage from 34.5 kV to 230 kV. The substation transformer noise was calculated using the NEMA TP-80050 standard [5] with a 5 dB tonal penalty added for its magnetostriction hum. Calculations to characterize the sound emission of the substation transformer can be found in Appendix C. Transformer noise was modelled as a point source at half the height of the transformer.

Additional substation yard components such as the switchgear, communication tower, and line reactors are considered insignificant noise sources.

3.5 Other Nearby Solar Facilities and External Anthropogenic Noise Sources

There are no adjacent solar facilities within 1 km of the Facility. As such, a cumulative noise impact study that incorporates adjacent solar facilities, as recommended in Ontario's *Technical Guide to Renewable Energy Approvals* [2], is not required.

A desktop review of Access Environment did not identify any Environmental Compliance Approvals for industrial applications within 1 km of the Facility. The land-use map included with Appendix A identifies that the site is surrounded by agricultural land. As such, additional external anthropogenic noise may include farming equipment. However, these external anthropogenic noise sources need not be included with the AAR.

3.6 Ancillary Distribution Lines

Aboveground ancillary distribution lines connecting the local panel switchgears to the substation will not emit significant amounts of isolator corona noise due to a relatively low AC line current and voltage (34.5 kV). Therefore, the noise from the ancillary distribution lines is considered insignificant.

3.7 Excluded Noise Sources

Insignificant and non-applicable noise sources were excluded from this assessment. Table 3-1 lists noise sources insignificant or outside the scope of this assessment.

Table 3-1: Excluded Noise Sources

Source	Reason for Exclusion
Vehicular Traffic	Noise exclusions identified in accordance with O. Reg. 359/09 [1] and the <i>Technical Guide to Renewable Energy Approvals</i> [2]
Maintenance and Service Activities	
Emergency Conditions	
Construction and Decommissioning	

3.8 Noise Source Summary Table

Table 3-2 lists the significant noise sources from the Facility. The noise source layout is presented in Appendix B.

Table 3-2: Noise Source Summary Table

Source ID	Equipment Description	NV dB Library Source	Sound Power (Lw) Unweighted Octave Band Spectrum, Hz (dB)									Overall (dBA)	Source Location	Sound Characteristic	Noise Control Measure	UTM Zone 16	
			31.5	63	125	250	500	1000	2000	4000	8000					E	N
INV01	Inverter System No 01	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327618	5146657
INV02	Inverter System No 02	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327342	5146565
INV03	Inverter System No 03	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327180	5146403
INV04	Inverter System No 04	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327183	5146161
INV05	Inverter System No 05	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327308	5145938
INV06	Inverter System No 06	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327413	5145811
INV07	Inverter System No 07	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327413	5145633
INV08	Inverter System No 08	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327407	5145389
INV09	Inverter System No 09	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327204	5145435
INV10	Inverter System No 10	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327026	5145554
INV11	Inverter System No 11	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	327026	5145754
INV12	Inverter System No 12	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326764	5144654
INV13	Inverter System No 13	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326531	5144660
INV14	Inverter System No 14	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326324	5144656
INV15	Inverter System No 15	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326122	5144654
INV16	Inverter System No 16	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326130	5144835
INV17	Inverter System No 17	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326224	5145008
INV18	Inverter System No 18	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	326265	5145118
INV19	Inverter System No 19	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	325923	5144656
INV20	Inverter System No 20	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	325929	5144834
INV21	Inverter System No 21	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	325633	5144759
INV22	Inverter System No 22	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	325453	5144633
INV23	Inverter System No 23	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	325029	5144201
INV24	Inverter System No 24	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	324846	5144201
INV25	Inverter System No 25	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324655	5144194
INV26	Inverter System No 26	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	325186	5143890
INV27	Inverter System No 27	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324813	5143885
INV28	Inverter System No 28	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324655	5143902

Source ID	Equipment Description	NV dB Library Source	Sound Power (Lw) Unweighted Octave Band Spectrum, Hz (dB)									Overall (dBA)	Source Location	Sound Characteristic	Noise Control Measure	UTM Zone 16	
			31.5	63	125	250	500	1000	2000	4000	8000					E	N
INV29	Inverter System No 29	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	325102	5142776
INV30	Inverter System No 30	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324859	5142646
INV31	Inverter System No 31	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	324626	5142636
INV32	Inverter System No 32	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	324429	5142646
INV33	Inverter System No 33	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	324181	5142645
INV34	Inverter System No 34	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324970	5142392
INV35	Inverter System No 35	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	U	324787	5142224
INV36	Inverter System No 36	INV	90	87	91	92	95	88	88	93	80	97	O	S, T	B	324639	5142225
ST01	Substation Transformer	TR_172	102	108	110	105	105	99	94	89	82	105	O	S, T	B	327424	5146656

*Spectra and Overall levels do NOT include tonal penalties. A 5 dB tonal penalty is added in the model for all sources with tonal sound characteristics.

1. O: located/installed outside the building, including on the roof, I: located/installed inside the building.

2. S: Steady; Q: Quasi-Steady Impulsive; B: Buzzing; T: Tonal; C: Cyclic.

3. S: Silencer, Acoustic Louvre, Muffler; A: Acoustics lining, Plenum; B: Barrier, Berm, Screening; L: Lagging; E: Acoustic Enclosure; O: Other; U: Uncontrolled.

4. Points of Reception

PORs representing the worst-case community noise sensitive dwellings and vacant lots were identified around the Facility. In accordance with O. Reg. 359/09 [1] and the *Technical Guide to Renewable Energy Approvals* [2], the noise study area extent for POR identification was set to 1 km from each of the noise sources.

All PORs, participating receptors and vacant lots within 1 km of a Facility noise source were identified and included in the noise assessment. Though O. Reg. 359/09 [1] Clause (6) notes that a “noise receptor does **not** include a location on a parcel of land if any part of the renewable energy generation facility will be located on that parcel of land once the facility is installed, constructed or expanded,” these participating receptors are identified herein, but noise compliance for them have not been evaluated.

Each POR was modelled at 1.5 m above ground for single-storey dwellings or 4.5 m above ground for two-storey dwellings to represent a plane of window on the building façade. Building façade POR IDs are identified with a “f” suffix. Outdoor living areas are modelled at 1.5 m above ground within 30 m of a façade of the dwelling. Outdoor living POR IDs are identified with an “o” suffix. Table 4-1 lists the PORs impacted by the Facility. The layout of identified PORs is shown in Appendix D.

Table 4-1: Point of Reception Locations

POR ID	Description	UTM Coordinates (Zone 16)	
		Easting	Northing
Points of Reception			
RN01_f	55 ON-554 Existing residential dwelling	324335	5142360
RN01_o		324364	5142349
RN02_f	58 ON-554 Existing residential dwelling	325428	5142571
RN02_o		325399	5142572
RN03_f	59 ON-554 Existing residential dwelling	325370	5142505
RN03_o		325342	5142510
RN04_f	60 ON-554 Existing residential dwelling	325068	5143159
RN04_o		325065	5143130
RN05_f	61 ON-554 Existing residential dwelling	325046	5143475
RN05_o		325076	5143468
RN06_f	ON-554 Existing residential dwelling	325346	5143377
RN06_o		325323	5143399
RN07_f	62 ON-554 Existing residential dwelling	325204	5143691
RN07_o		325172	5143704

POR ID	Description	UTM Coordinates (Zone 16)	
		Easting	Northing
RN08_f	64 ON-554	325291	5144179
RN08_o	Existing residential dwelling	325266	5144179
RN09_f	65 ON-554	325278	5144339
RN09_o	Existing residential dwelling	325262	5144317
RN10_f	66 ON-554	325281	5144372
RN10_o	Existing residential dwelling	325266	5144358
RN11_f	ON-554	325353	5144398
RN11_o	Existing residential dwelling	325390	5144394
RN12_f	67 ON-554	325217	5144486
RN12_o	Existing residential dwelling	325245	5144498
RN13_f	69 ON-554	325311	5145117
RN13_o	Existing residential dwelling	325331	5145114
RN14_f	70 ON-554	325228	5145182
RN14_o	Existing residential dwelling	325254	5145182
RN15_f	2273 ON-554	325304	5145620
RN15_o	Existing residential dwelling	325334	5145618
RN16_f	2267 ON-554	325042	5145637
RN16_o	Existing residential dwelling	325073	5145627
RN17_f	28 ON-554	325340	5146036
RN17_o	Existing residential dwelling	325340	5146022
RN18_f	7 ON-554	325196	5146094
RN18_o	Existing residential dwelling	325218	5146073
RN19_f	Existing residential dwelling	328157	5146959
RN19_o		328135	5146949
RN20_f	Existing residential dwelling	328096	5147136
RN20_o		328090	5147118
VN01	Vacant Lot	324400	5141163
VN02	Vacant Lot	326446	5143416
VN03	Vacant Lot	326786	5144023
VN04	Vacant Lot	325202	5145341
VN05	Vacant Lot	325347	5146270
VN06	Vacant Lot	324624	5146101
Participating Receptors			
RP01_f	54 ON-554	324226	5142065
RP01_o	Existing residential dwelling	324238	5142092

POR ID	Description	UTM Coordinates (Zone 16)	
		Easting	Northing
RP02_f	57 ON-554	324555	5142472
RP02_o	Existing residential dwelling	324559	5142443
RP03_f	54A ON-554	325134	5142144
RP03_o	Existing residential dwelling	325112	5142163
RP04_f	63 ON-554	325202	5144115
RP04_o	Existing residential dwelling	325179	5144136
RP05_f	68 ON-554	325376	5144782
RP05_o	Existing residential dwelling	325391	5144780
RP06_f	68 ON-554	325335	5144820
RP06_o	Existing residential dwelling	325334	5144803
RP07_f	Existing residential dwelling	326947	5145300
RP07_o		326954	5145310

5. Mitigation Measures Summary

Table 5-1 lists the preliminary noise mitigation features proposed to be incorporated into the design. The evaluation of the community noise impact presented in Section 7 includes these mitigation features. The locations of these noise mitigation features are identified in Appendix D.

It should be noted that the noise control features proposed herein may be subject to change prior to the final regulatory submission for alignment with the latest Project information.

Table 5-1: Mitigation Summary Table

Mitigation ID	Targeted Noise Source	Description	Details
NB01	ST01	Noise barrier at substation transformer	15 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB02	INV21	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB03	INV22	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB04	INV23	Noise barrier	5 m tall, 10 m total length, 2-sides, minimum 20 kg/m ²
NB05	INV24	Noise barrier	5 m tall, 10 m total length, 2-sides, minimum 20 kg/m ²
NB06	INV26	Noise barrier	5 m tall, 20 m total length, 3-sides, minimum 20 kg/m ²

Mitigation ID	Targeted Noise Source	Description	Details
NB07	INV29	Noise barrier	5 m tall, 25 m total length, 3-sides, minimum 20 kg/m ²
NB08	INV31	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB09	INV32	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB10	INV33	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²
NB11	INV36	Noise barrier	5 m tall, 10 m total length, 1-side, minimum 20 kg/m ²

6. Assessment Criteria

The MECP publications *NPC-300 - Environmental Noise Guideline - Stationary and Transportation Sources - Approval and Planning* provides guidance on control of industrial noise emissions for Ontario [4] and *Technical Guide to Renewable Energy Approvals* [2] provide noise limits according to the surrounding POR classification. Table 6-1 shows the Class 3 performance limits for rural receptors at different times of the day. A conservative assessment limit of 40 dBA was used at all receptor locations under the likely potential for the Facility to operate, sometime throughout its lifecycle, at full power generation for at least 1 hour during the evening period.

Table 6-1: Class 3 Performance Limits

Class 3 Area	
Time Period	Sound Level Limit – Leq [1 hour] (dBA)
07:00 to 19:00 (Daytime)	45
19:00 to 23:00 (Evening)	40
23:00 to 07:00 (Nighttime)	40

7. Acoustic Assessment Summary

7.1 Analysis Methodology

To model the community noise impact of the project, a noise model was developed using CADNA-A software application. The ISO 9613-2 [7] algorithm was implemented using CADNA-A to evaluate the environmental noise exposure from stationary sources.

The assumptions used in the noise model are in accordance with Section 9.2 of the *Technical Guide to Renewable Energy Approvals* [2] and are as follows:

- The model is assessed at 10°C and 70% relative humidity.

- The noise study area extends 1 km from each noise source.
- Ground absorption was modelled with a global value of G=0.7.
- All equipment on-site operates continuously steady during daytime, and for at least 1 hour during evening and night periods without impulsive noise emissions.
- The substation transformer was modelled as point sources at top height and sound power data was estimated based on National Electrical Manufacturers Association (NEMA) [5] and Institute of Electrical and Electronics Engineers (IEEE) [6] standards.

7.2 Predictable Worst-Case Assessment Scenario

Acoustic modelling was completed on a PWC basis that determined the equivalent 1-hour noise impact on the identified noise PORs. The following worst-case scenario was analyzed as described in Table 7-1.

Table 7-1: Assessment Scenarios

Scenario	Description
Predictable Worst-Case (PWC)	36 INV units. One 172 MVA substation transformer. Panels as noise obstructions not modelled. All equipment operates simultaneously at design for 1 hour during the evening/nighttime period. Conservative noise limit of 40 dBA at all receptors, modelled 4.5 m above ground.

7.3 Noise Modelling Results

Table 7-2 summarizes the noise assessment results at each of the noise sensitive POR locations. Participating receptors are listed but not compared to the noise criteria as noted under Clause (6) of O. Reg. 359/09 [1] (Section 4). All applicable PORs are compliant with the NPC-300 40 dBA noise criteria for a Class 3 receptor during the evening and nighttime periods. To visualize the predicted noise emissions from the Facility, refer to the noise contour plot in Appendix D.

Table 7-2: Acoustic Assessment Summary Table

POR ID	Description	Sound Level (dBA)		Verified by Acoustic Audit	Performance Limit (dBA)		Compliance (Yes/No)
		Day	Night/Evening		Day	Night/Evening	
Points of Reception (Non-Participating)							
RN01_f	55 ON-554	39	39	No	45	40	Yes
RN01_o	Existing residential dwelling	38	38	No	45	40	Yes
RN02_f	58 ON-554	39	39	No	45	40	Yes
RN02_o	Existing residential dwelling	38	38	No	45	40	Yes
RN03_f	59 ON-554	39	39	No	45	40	Yes
RN03_o	Existing residential dwelling	37	37	No	45	40	Yes

POR ID	Description	Sound Level (dBA)		Verified by Acoustic Audit	Performance Limit (dBA)		Compliance (Yes/No)
		Day	Night/ Evening		Day	Night/ Evening	
RN04_f	60 ON-554	39	39	No	45	40	Yes
RN04_o	Existing residential dwelling	37	37	No	45	40	Yes
RN05_f	61 ON-554	39	39	No	45	40	Yes
RN05_o	Existing residential dwelling	35	35	No	45	40	Yes
RN06_f	ON-554	35	35	No	45	40	Yes
RN06_o	Existing residential dwelling	33	33	No	45	40	Yes
RN07_f	62 ON-554	39	39	No	45	40	Yes
RN07_o	Existing residential dwelling	37	37	No	45	40	Yes
RN08_f	64 ON-554	39	39	No	45	40	Yes
RN08_o	Existing residential dwelling	37	37	No	45	40	Yes
RN09_f	65 ON-554	38	38	No	45	40	Yes
RN09_o	Existing residential dwelling	37	37	No	45	40	Yes
RN10_f	66 ON-554	38	38	No	45	40	Yes
RN10_o	Existing residential dwelling	37	37	No	45	40	Yes
RN11_f	ON-554	38	38	No	45	40	Yes
RN11_o	Existing residential dwelling	37	37	No	45	40	Yes
RN12_f	67 ON-554	38	38	No	45	40	Yes
RN12_o	Existing residential dwelling	36	36	No	45	40	Yes
RN13_f	69 ON-554	39	39	No	45	40	Yes
RN13_o	Existing residential dwelling	38	38	No	45	40	Yes
RN14_f	70 ON-554	38	38	No	45	40	Yes
RN14_o	Existing residential dwelling	36	36	No	45	40	Yes
RN15_f	2273 ON-554	32	32	No	45	40	Yes
RN15_o	Existing residential dwelling	32	32	No	45	40	Yes
RN16_f	2267 ON-554	32	32	No	45	40	Yes
RN16_o	Existing residential dwelling	30	30	No	45	40	Yes
RN17_f	28 ON-554	33	33	No	45	40	Yes
RN17_o	Existing residential dwelling	31	31	No	45	40	Yes
RN18_f	7 ON-554	32	32	No	45	40	Yes
RN18_o	Existing residential dwelling	30	30	No	45	40	Yes
RN19_f	Existing residential dwelling	34	34	No	45	40	Yes
RN19_o		30	30	No	45	40	Yes
RN20_f	Existing residential dwelling	31	31	No	45	40	Yes
RN20_o		29	29	No	45	40	Yes
VN01	Vacant Lot	26	26	No	45	40	Yes
VN02	Vacant Lot	28	28	No	45	40	Yes
VN03	Vacant Lot	31	31	No	45	40	Yes
VN04	Vacant Lot	34	34	No	45	40	Yes

POR ID	Description	Sound Level (dBA)		Verified by Acoustic Audit	Performance Limit (dBA)		Compliance (Yes/No)
		Day	Night/Evening		Day	Night/Evening	
VN05	Vacant Lot	32	32	No	45	40	Yes
VN06	Vacant Lot	27	27	No	45	40	Yes
Participating Receptors							
RP01_f	54 ON-554	36	36	No	45	40	N/A
RP01_o	Existing residential dwelling	34	34	No	45	40	N/A
RP02_f	57 ON-554	44	44	No	45	40	N/A
RP02_o	Existing residential dwelling	44	44	No	45	40	N/A
RP03_f	54A ON-554	43	43	No	45	40	N/A
RP03_o	Existing residential dwelling	42	42	No	45	40	N/A
RP04_f	63 ON-554	41	41	No	45	40	N/A
RP04_o	Existing residential dwelling	40	40	No	45	40	N/A
RP05_f	68 ON-554	46	46	No	45	40	N/A
RP05_o	Existing residential dwelling	45	45	No	45	40	N/A
RP06_f	68 ON-554	44	44	No	45	40	N/A
RP06_o	Existing residential dwelling	43	43	No	45	40	N/A
RP07_f	Existing residential dwelling	45	45	No	45	40	N/A
RP07_o		44	44	No	45	40	N/A

8. Conclusion

An acoustic assessment of the proposed Kynoch 154 MW Class 3 solar PV facility has been completed. Based on this AAR's approach and noise mitigations included with the design, the proposed Project is expected to be compliant with the community noise limits identified in the *MECP Technical Guide to Renewable Energy Approvals* [2] and *Environmental Noise Guidelines NPC-300* [4] for the PWC operating condition.


9. References

- [1] Province of Ontario, O. Reg. 359/09 - *Renewable Energy Approvals under Part V.0.1 of the Environmental Protection Act*, 2016.
- [2] Province of Ontario, PIBS 8472e – *Technical Guide to Renewable Energy Approvals*, 2013.
- [3] Province of Ontario, PIBS 4391e01 – *Basic Comprehensive Certificates of Approval (Air)*, 2011.
- [4] Ontario Ministry of the Environment, Climate, and Parks (MECP), NPC-300 - *Environmental Noise Guideline – Stationary and Transportation Sources*, 2013.

- [5] National Electrical Manufacturers Association, “NEMA TP-80050-2013 (R2024): Transformers, Step Voltage Regulators, and Reactors,” NEMA, Rosslyn, VA, USA, 2013.
- [6] Institute of Electrical and Electronics Engineers, C57.12.90 Standard Test Code for Liquid-Immersed Distribution, Power and Regulating Transformers, 2010.
- [7] International Organization for Standardization, “ISO 9613-2: Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation,” ISO, Geneva, Switzerland, 1996.

Appendix A

Zoning/Land-Use Siting Map



LEGEND

- Building
- 🌾 Adjacent Agricultural Land
- Road
- Contour
- Field Identified Watercourse
- Intermittent Watercourse
- Permanent Watercourse
- Proposed Transmission Line
- Transmission Line
- Trail System
- Project Location
- Study Area (300m Buffer)
- Waterbody
- Unevaluated Wetland
- Field Identified Wetland
- Crown Land
- Private Land
- Provincial Park

NOTES:

1. Produced by Hatch, contains information licensed under the Open Government Licence – Ontario
2. Spatial referencing: NAD 1983 UTM Zone 17N
3. Crown and Private Land digitized from Crown Land Use Policy Atlas web map, September 2025


0 0.25 0.5 1 Km

1:25,000

PROJECT: Project Description Report Kynoch Solar Project				
FIGURE TITLE: Project Location				
CLIENT: CarbonFree Kynoch Ltd.				
DWG BY: S. PERRY	CHK BY: C. SEHL	FIG NO.: 1	REV NO.: 1	HATCH
DATE: 04/02/26	PAGE: 1			

Appendix B

Site and Noise Source Layout



- LEGEND**
- Noise Source
 - PV Array
 - Road
 - - - Project Location

NOTES:

1. Produced by Hatch, contains information licensed under the Open Government Licence – Ontario
2. Spatial referencing: NAD 1983 UTM Zone 17N

0 250 500 1,000
 1:22,000 m

PROJECT: Acoustic Assessment Report
Kynoch Solar Project

FIGURE TITLE: Noise Source Layout

CLIENT: CarbonFree Kynoch LTD

DWG BY: V. BAXTER	CHK BY: M. ANDARGIE	FIG NO.: 1	REV NO.: 1	HATCH
DATE: 10/03/26	PAGE: 1			

Appendix C

Noise Source Sound Power Levels and Equipment Vendor Information

Equipment Type	Solar Inverter Skid	NV dB	INV	Project Tags	INV xx
Manufacturer	Sungrow				
Power	4400 kW	Date	25/2/2026		
Flow	- (m ³ /s)	Source	Sungrow SG4400UD		
Pres	- kPA		2025-05-08 Test report		
Temperature	- (°C)				

	31.5	63	125	250	500	1000	2000	4000	8000	OVL(A)
Derived Lw	90	87	91	92	95	88	88	93	80	97


Figure 1. Photo of Solar Inverter Skid (Looking South)



Table 1. Sound Measurement Data, dB

Position	Octave Band Center Frequency, Hz									dBA	dBZ, Calculated
	31.5	63	125	250	500	1000	2000	4000	8000		
1	67.9	64.7	67.9	61	54	47.3	46.7	51.8	36	58.5	72.3
2	64.9	65	69.1	70.3	75	68.5	68.3	67.3	59.7	75.8	78.9
3	68.5	65.9	71.5	77.4	80	72.2	72.9	71.6	63.8	80.4	83.7
4	65.4	63.8	67.3	67.2	67.8	61.7	63	67.4	53.5	71.5	75.0
5	62.9	64.3	66.8	67.9	66.5	61.5	64.7	78.8	62.5	79.9	80.1
6	60	65.8	68.9	62.4	58.7	58.1	60	68.4	53	70.4	73.8
7	61.4	63.1	69.1	56.3	53.8	46.5	47.2	49.9	35.2	57.5	70.9
8	66.1	63.9	70.9	68.3	75.1	68.3	66.8	65.9	55.6	75.2	78.7
9	67.8	65.7	71.4	76.3	77.9	71.6	69.5	67.1	56.5	78	82.0
10	64.9	62.9	70.4	66.8	67.2	60.9	61.9	65.3	51.9	70.2	75.1
11	63.9	63.2	68.2	67	64.6	59.5	64.6	74.2	60.4	75.8	77.0
12	59.4	64.7	66.2	64.9	59	55.7	57.5	68.9	52.5	70.5	73.2
13	69.1	62.3	71.6	62.1	64.8	59.7	58.5	66.2	49	69.3	75.4
14	76.3	68.1	68.6	68.1	70.8	64.9	63.5	68.8	53.2	73.3	79.4
Average	68.1	64.8	69.5	70.3	72.7	65.9	65.9	70.8	57.6	75.1	78.3
Lw	90.0	86.7	91.4	92.2	94.6	87.8	87.7	92.6	79.5	97.0	100.2

Figure 2. Measurement Positions, Overhead View



Equipment Type	245 kV 172 MVA Transformer	NV dB	TR_172	Project Tags	ST01
Manufacturer	Larson Electronics				
Power	172 MVA	Date	2025.12.23		
Flow	(m ³ /s)				
Pres	kPA	Source	NEMA TR1-1993 (R2000), Oil Filled- Forced Larson Electronics 103.2/137.6/172 MVA 245 kV MT-PSTC-R7-3P		
Temperature	(°C)				

Derived Lw	31.5	63	125	250	500	1000	2000	4000	8000	OVL
	102	108	110	105	105	99	94	89	82	105

From Handbook of Noise and Vibration Control (Crocker, 2007, page 1335-1336, Eq. 18 and Table 20)
Average LpA **82** dBA Based on NEMA TR1-1993 (R2000), Table 0-4, Dry type ventilated forced air cooled
Estimated surface area **119.0** m² Estimated based on Culter-Hammer catalogue

	102	108	110	105	105	99	94	89	82	105
	31.5	63	125	250	500	1000	2000	4000	8000	(dBA)

STEP 1: Correction factors

C1 Outdoors, indoors in mechanical room over	-11	-5	-3	-8	-8	-14	-19	-24	-31	
C2 - Indoors	-11	-2	3	-2	-2	-11	-19	-24	-31	
C3 - Serious Noise Problems	-11	-2	3	2	2	-4	-9	-14	-21	

STEP 2: Sound Power Level calculated as Lw=Average LpA + Awt + 10*log(Estimated surface area) + C + 10

C1 based [dB]	102	108	110	105	105	99	94	89	82	105
C2 based [dB]	102	111	116	111	111	102	94	89	82	110
C3 based [dB]	102	111	116	115	115	109	104	99	92	115

A-weightings				-39.4	-26.2	-16.1	-8.6	-3.2	0	1.2	1	-1.1
---------------------	--	--	--	-------	-------	-------	------	------	---	-----	---	------


Table 1
Audible Sound Levels for Oil-Immersed Power Transformers

Average Sound Level in Decibels	Equivalent Two-Winding Rating*											
	350 kV BIL and Below			450, 550, 650 kV BIL			750 and 825 kV BIL			900 and 1050 kV BIL		
	1	2	3	1	2	3	1	2	3	1	2	3
57	750											
58	1000											
59				700								
60	1500		1000									
61	2000											
62	2500		1500									
63	3000		2000									
64	4000		2500									
65	5000		3000									
66	6000		4000									
67	7500	6250 ▲▲	5000	3750 ▲▲			4000	3125 ▲▲				
68	10000	7500	6000	5000			5000	3750				
69	15000	11250	7500	6250			6000	5000				
70	20000	15000	10000	7500			7000	6500				
71	20000	16667	12500	8076			10000	7500				
72	25000	20000	20000	15000	12500	9375						
73	30000	26667	25000	20000	16667	15000	15000	12500				
74	40000	33333	33333	25000	20000	20000	20000	20000	20000	16667		
75	50000	40000	41667	30000	26667	25000	25000	20000	20000	20000	20000	20000
76	60000	53333	50000	40000	33333	33333	30000	26667	25000	25000	20000	20000
77	80000	66667	66667	50000	40000	41667	40000	33333	30000	30000	25000	20000
78	100000	80000	83333	60000	53333	50000	50000	41667	40000	40000	33333	33333
79		106667	100000	80000	66667	66667	60000	53333	50000	50000	40000	41667
80		133333	133333	100000	80000	83333	80000	66667	66667	60000	53333	50000
81			166667	100000	106667	100000	100000	80000	83333	80000	66667	66667
82		200000		133333	133333	106667	100000	100000	80000	80000	63333	
83			250000		166667		133333	133333		10686	100000	
84				200000			200000		16667		13333	133333
85					250000			250000			200000	
86						300000						200000
87							400000					200000
88								500000				200000
89									600000			200000
90										800000		
91											1000000	

Larson Electronics LLC
9419 E US HWY 175, Kemp, TX 75143
Phone: 800.369.6671



- Tertiary winding: N/A
- Frequency: 60 Hz
- Temperature Rise: 65°C
- Insulation Rating: Class A Insulation
- Cooling Class: ONAN/ONAF/ONAF
- Forced Air (Fans): Included, Two-Stage, Totally Enclosed, Individually Protected Type,**
- Fan Blades Of One-Piece Cast aluminum, Galvanized Fan Guards.
- Cooling Radiator: Included, Galvanized, Has Upper And Lower Drain Plugs, ANSI #70 Sky
- Conduit Opening: Bottom
- Tank Cover Access Handhole: Included
- Dimensions*: 185" L x 159" W x 161" H**
- Weight*: 89,560 Lbs
- *Please note that numbers are approximate and subject to change



13.5.5 Sound power level calculation (L_w)

The sound power level shall be computed for each frequency band (A-weighted, one-third octave band, or discrete frequency) using Equation (34)

$$L_w = L_p + 10 \cdot \log(S) \quad (34)$$

The measurement surface area S is the vertical area (in square meters or square feet) enveloping the transformer (measurement surface) on which the sound measurement points are located plus the horizontal plane bounded by the vertical measurement surface.

Alternatively, for large transformers, the measurement surface area is approximately equal to 135% of the vertical area enveloping the transformer (measurement surface).





Nextracker Motor Sound Summary

Each Nextracker row uses a 24V DC motor powered by a Nextracker controller (SPC). To track the Sun, the motor operates for five to ten seconds every few minutes. The noise level of the motors is tested by the manufacturer. Test reports from the manufacturer indicate that the sound power level is approximately ~65dB. The sound level produced is low and essentially indistinguishable to surrounding noises such as inverters, transformers, and HVAC units.

Below is a Motor test report from Nextracker Vendor.

Distance	Sound Level	Equivalent Sound
3m (9.8 ft)	~ 65dB	Normal Conversation, Quiet Suburb
30m (98 ft)	~ 45dB	Light Rain, Bird calls
300m (980 ft)	~ 25dB	Leaves Rustling, Whisper

Applicator	Lu Weijian	Department	Technical	Date	2020.04.14
Sample name		Drawing No.		Sample No.	2
Test purpose	Test gearbox motor can meet the noise standard				
Test process	<p>1. The test motor shall be isolated from the aging table to prevent it from being affected by the noise of the aging table. The torque shall be set to 150N.m for 10min forward rotation, 1min stop, 10min reverse and 1min stop, work for 2 cycles. The noise meter should be 1m to the under test motor.</p> <p>2. Acceptable standard: Noise during the test shall be $\leq 65\text{dB}$</p>				
Test equipment	300N.m dynamometer, noise meter				
Test cycle	1 day				
Process Description	<p>1. Clamp the sample motor and test the corresponding data according to the above test methods</p> <p>1-1 Ambient noise 56.1dB</p>  <p>1-2 Dynamometer parameter setting 150N.m</p>  <p>1-3 Test the motor noise when running as required, and the horizontal distance from the motor is 1m</p>  <p>1-4 Motor noise test result: 64.7dB</p>				

			
<p>Test report</p>	<p>No. B1 Motor noise 64.7 dB; No. F1 Motor noise 63.2 dB;</p>		
<p>Test result</p>	<p>According to the test results show that the stable operation of electric motor noise can meet the performance requirements;</p>		
<p>Operator</p>	<p>Sun Jieying</p>	<p>Audit</p>	<p>Lu Weijian</p>

Appendix D

POR Noise Impact Table and Noise Contour Plot

Point of Reception Noise Impact Table


Receptor ID	Top Noise Sources										Source ID
	1	2	3	4	5	6	7	8	9	10	
RN01_f	INV35	INV30	INV34	INV36	INV31	INV32	INV33	INV29	INV28	INV27	Partial Level
	34 dBA	32 dBA	31 dBA	27 dBA	26 dBA	25 dBA	24 dBA	21 dBA	21 dBA	21 dBA	
	317 m	597 m	504 m	0 m	308 m	332 m	636 m	872 m	1557 m	1598 m	
RN01_o	INV35	INV30	INV34	INV36	INV31	INV32	INV33	INV29	INV28	INV27	Partial Level
	34 dBA	30 dBA	30 dBA	27 dBA	24 dBA	24 dBA	23 dBA	20 dBA	18 dBA	18 dBA	
	286 m	578 m	473 m	0 m	312 m	356 m	608 m	852 m	1563 m	1601 m	
RN02_f	INV29	INV35	INV34	INV36	INV30	INV31	INV32	INV33	INV22	INV27	Partial Level
	36 dBA	30 dBA	29 dBA	28 dBA	26 dBA	24 dBA	22 dBA	19 dBA	18 dBA	18 dBA	
	385 m	861 m	684 m	0 m	578 m	1004 m	1250 m	491 m	2065 m	1451 m	
RN02_o	INV29	INV34	INV35	INV30	INV31	INV36	INV32	INV33	INV27	INV28	Partial Level
	36 dBA	30 dBA	25 dBA	25 dBA	24 dBA	23 dBA	21 dBA	19 dBA	17 dBA	16 dBA	
	361 m	659 m	835 m	549 m	976 m	0 m	1221 m	465 m	1438 m	1509 m	
RN03_f	INV34	INV29	INV35	INV36	INV30	INV31	INV33	INV32	INV27	INV28	Partial Level
	36 dBA	32 dBA	31 dBA	29 dBA	27 dBA	25 dBA	24 dBA	22 dBA	17 dBA	16 dBA	
	602 m	382 m	784 m	0 m	535 m	955 m	415 m	1199 m	1489 m	1554 m	
RN03_o	INV34	INV29	INV36	INV35	INV31	INV30	INV32	INV33	INV27	INV28	Partial Level
	31 dBA	31 dBA	27 dBA	26 dBA	25 dBA	22 dBA	22 dBA	19 dBA	16 dBA	16 dBA	
	579 m	359 m	0 m	758 m	926 m	507 m	1170 m	389 m	1474 m	1537 m	
RN04_f	INV30	INV31	INV34	INV32	INV35	INV33	INV36	INV27	INV29	INV28	Partial Level
	33 dBA	30 dBA	29 dBA	28 dBA	27 dBA	26 dBA	26 dBA	25 dBA	24 dBA	24 dBA	
	550 m	816 m	945 m	1021 m	1013 m	773 m	0 m	769 m	385 m	834 m	
RN04_o	INV30	INV31	INV32	INV35	INV34	INV36	INV29	INV33	INV27	INV28	Partial Level
	32 dBA	29 dBA	27 dBA	25 dBA	24 dBA	24 dBA	24 dBA	24 dBA	23 dBA	22 dBA	
	522 m	796 m	1004 m	986 m	916 m	0 m	356 m	744 m	796 m	859 m	
RN05_f	INV28	INV27	INV25	INV30	INV31	INV32	INV34	INV23	INV24	INV33	Partial Level
	32 dBA	30 dBA	28 dBA	28 dBA	27 dBA	26 dBA	25 dBA	25 dBA	25 dBA	24 dBA	
	567 m	472 m	819 m	844 m	1028 m	1192 m	1248 m	722 m	748 m	1085 m	
RN05_o	INV28	INV27	INV23	INV25	INV30	INV24	INV31	INV35	INV36	INV32	Partial Level
	27 dBA	25 dBA	24 dBA	23 dBA	23 dBA	22 dBA	22 dBA	21 dBA	21 dBA	20 dBA	
	592 m	493 m	729 m	839 m	845 m	763 m	1041 m	1301 m	0 m	1210 m	
RN06_f	INV29	INV27	INV22	INV23	INV30	INV28	INV19	INV21	INV24	INV31	Partial Level
	24 dBA	24 dBA	24 dBA	23 dBA	23 dBA	22 dBA	22 dBA	22 dBA	22 dBA	21 dBA	
	649 m	736 m	1264 m	877 m	875 m	857 m	1393 m	1411 m	959 m	1169 m	
RN06_o	INV27	INV23	INV29	INV24	INV28	INV30	INV25	INV31	INV19	INV21	Partial Level
	23 dBA	23 dBA	22 dBA	22 dBA	21 dBA	21 dBA	21 dBA	20 dBA	20 dBA	20 dBA	
	705 m	849 m	661 m	929 m	826 m	881 m	1038 m	1165 m	1383 m	1395 m	
RN07_f	INV23	INV24	INV25	INV26	INV27	INV28	INV21	INV19	INV20	INV22	Partial Level
	33 dBA	32 dBA	30 dBA	29 dBA	28 dBA	26 dBA	25 dBA	24 dBA	23 dBA	21 dBA	
	534 m	618 m	744 m	195 m	436 m	582 m	1151 m	1194 m	1354 m	980 m	

Receptor ID	Top Noise Sources									
	1	2	3	4	5	6	7	8	9	10
RN07_o	INV23	INV26	INV24	INV27	INV25	INV28	INV21	INV19	INV20	INV22
	32 dBA	29 dBA	27 dBA	26 dBA	25 dBA	24 dBA	22 dBA	22 dBA	20 dBA	19 dBA
	513 m	182 m	591 m	403 m	713 m	548 m	1152 m	1204 m	1361 m	978 m
RN08_f	INV27	INV25	INV19	INV23	INV21	INV22	INV28	INV26	INV24	INV20
	33 dBA	31 dBA	29 dBA	28 dBA	26 dBA	26 dBA	26 dBA	25 dBA	24 dBA	23 dBA
	561 m	637 m	785 m	262 m	674 m	490 m	702 m	312 m	446 m	915 m
RN08_o	INV25	INV23	INV27	INV19	INV28	INV26	INV22	INV21	INV24	INV20
	30 dBA	28 dBA	28 dBA	27 dBA	25 dBA	24 dBA	24 dBA	24 dBA	23 dBA	22 dBA
	612 m	237 m	540 m	805 m	679 m	305 m	499 m	686 m	421 m	932 m
RN09_f	INV25	INV27	INV15	INV22	INV21	INV23	INV19	INV28	INV20	INV24
	31 dBA	31 dBA	28 dBA	27 dBA	26 dBA	26 dBA	25 dBA	25 dBA	24 dBA	24 dBA
	640 m	650 m	899 m	352 m	550 m	286 m	714 m	772 m	818 m	456 m
RN09_o	INV25	INV27	INV23	INV22	INV15	INV28	INV19	INV21	INV24	INV20
	30 dBA	30 dBA	26 dBA	25 dBA	25 dBA	24 dBA	24 dBA	24 dBA	23 dBA	23 dBA
	619 m	623 m	261 m	379 m	922 m	746 m	738 m	578 m	434 m	845 m
RN10_f	INV25	INV27	INV15	INV22	INV21	INV19	INV23	INV28	INV20	INV24
	31 dBA	31 dBA	28 dBA	27 dBA	27 dBA	26 dBA	25 dBA	24 dBA	24 dBA	23 dBA
	651 m	675 m	886 m	323 m	523 m	698 m	306 m	794 m	797 m	470 m
RN10_o	INV25	INV27	INV22	INV23	INV19	INV28	INV21	INV20	INV24	INV15
	29 dBA	29 dBA	26 dBA	25 dBA	25 dBA	24 dBA	24 dBA	23 dBA	23 dBA	22 dBA
	633 m	655 m	343 m	287 m	717 m	774 m	543 m	816 m	451 m	904 m
RN11_f	INV22	INV25	INV27	INV21	INV19	INV20	INV15	INV23	INV28	INV16
	31 dBA	30 dBA	30 dBA	28 dBA	27 dBA	25 dBA	24 dBA	24 dBA	24 dBA	23 dBA
	263 m	728 m	745 m	456 m	621 m	723 m	809 m	381 m	868 m	891 m
RN11_o	INV22	INV25	INV27	INV19	INV21	INV20	INV15	INV16	INV28	INV23
	31 dBA	27 dBA	27 dBA	27 dBA	26 dBA	25 dBA	24 dBA	23 dBA	22 dBA	22 dBA
	253 m	762 m	770 m	589 m	438 m	696 m	775 m	861 m	895 m	411 m
RN12_f	INV25	INV27	INV15	INV19	INV22	INV20	INV28	INV23	INV21	INV16
	31 dBA	30 dBA	27 dBA	25 dBA	25 dBA	24 dBA	24 dBA	24 dBA	22 dBA	22 dBA
	634 m	724 m	920 m	723 m	291 m	793 m	824 m	345 m	497 m	977 m
RN12_o	INV25	INV27	INV19	INV22	INV20	INV28	INV15	INV23	INV16	INV24
	29 dBA	28 dBA	25 dBA	25 dBA	24 dBA	23 dBA	22 dBA	22 dBA	22 dBA	20 dBA
	663 m	749 m	694 m	262 m	763 m	851 m	891 m	370 m	947 m	501 m
RN13_f	INV22	INV20	INV19	INV16	INV17	INV15	INV18	ST01	INV25	INV21
	34 dBA	31 dBA	29 dBA	28 dBA	27 dBA	27 dBA	27 dBA	26 dBA	25 dBA	24 dBA
	507 m	680 m	773 m	866 m	919 m	940 m	954 m	2614 m	1133 m	482 m
RN13_o	INV22	INV20	INV19	INV16	INV17	INV15	INV18	ST01	INV21	INV25
	32 dBA	29 dBA	28 dBA	26 dBA	25 dBA	25 dBA	25 dBA	24 dBA	23 dBA	22 dBA
	497 m	660 m	755 m	846 m	899 m	921 m	933 m	2600 m	466 m	1142 m
RN14_f	INV22	INV20	INV19	INV16	INV17	ST01	INV15	INV18	INV25	INV27
	32 dBA	29 dBA	28 dBA	27 dBA	26 dBA	26 dBA	26 dBA	26 dBA	25 dBA	23 dBA
	597 m	783 m	879 m	967 m	1011 m	2645 m	1045 m	1039 m	1143 m	1362 m

Receptor ID	Top Noise Sources									
	1	2	3	4	5	6	7	8	9	10
RN14_o	INV22	INV20	INV19	INV16	INV17	INV15	INV18	ST01	INV21	INV25
	30 dBA	27 dBA	26 dBA	25 dBA	24 dBA	24 dBA	24 dBA	24 dBA	21 dBA	19 dBA
	587 m	760 m	858 m	943 m	986 m	1022 m	1013 m	2624 m	568 m	1156 m
RN15_f	ST01	INV17	INV22	INV20	INV18	INV16	INV19	INV21	INV15	INV14
	25 dBA	23 dBA	21 dBA	21 dBA	20 dBA	20 dBA	19 dBA	19 dBA	18 dBA	17 dBA
	2360 m	1104 m	998 m	1004 m	1083 m	1139 m	1155 m	922 m	1273 m	1411 m
RN15_o	ST01	INV17	INV20	INV22	INV18	INV21	INV16	INV19	INV15	INV14
	25 dBA	23 dBA	21 dBA	21 dBA	20 dBA	20 dBA	20 dBA	20 dBA	18 dBA	17 dBA
	2334 m	1078 m	984 m	991 m	1056 m	909 m	1116 m	1137 m	1253 m	1388 m
RN16_f	ST01	INV17	INV22	INV20	INV19	INV18	INV16	INV15	INV25	INV03
	26 dBA	23 dBA	21 dBA	20 dBA	19 dBA	18 dBA	18 dBA	17 dBA	17 dBA	16 dBA
	2591 m	1338 m	1088 m	1196 m	1326 m	1328 m	1351 m	1467 m	1495 m	2271 m
RN16_o	ST01	INV22	INV20	INV19	INV18	INV17	INV16	INV15	INV25	INV14
	24 dBA	20 dBA	19 dBA	18 dBA	18 dBA	18 dBA	18 dBA	17 dBA	16 dBA	16 dBA
	2566 m	1067 m	1166 m	1298 m	1295 m	1306 m	1320 m	1438 m	1493 m	1590 m
RN17_f	ST01	INV20	INV17	INV16	INV19	INV15	INV14	INV18	INV03	INV21
	24 dBA	23 dBA	23 dBA	22 dBA	22 dBA	21 dBA	20 dBA	19 dBA	19 dBA	19 dBA
	2175 m	1339 m	1356 m	1438 m	1509 m	1597 m	1704 m	1304 m	1876 m	1311 m
RN17_o	ST01	INV20	INV17	INV16	INV19	INV15	INV18	INV21	INV14	INV22
	23 dBA	21 dBA	20 dBA	20 dBA	19 dBA	18 dBA	18 dBA	18 dBA	18 dBA	17 dBA
	2179 m	1326 m	1345 m	1426 m	1495 m	1584 m	1293 m	1297 m	1693 m	1392 m
RN18_f	ST01	INV20	INV17	INV16	INV19	INV15	INV14	INV25	INV03	INV21
	24 dBA	22 dBA	22 dBA	21 dBA	21 dBA	20 dBA	19 dBA	18 dBA	18 dBA	18 dBA
	2298 m	1457 m	1495 m	1568 m	1621 m	1720 m	1836 m	1976 m	2008 m	1405 m
RN18_o	ST01	INV20	INV17	INV16	INV19	INV15	INV21	INV18	INV14	INV22
	23 dBA	20 dBA	19 dBA	19 dBA	18 dBA	18 dBA	17 dBA	17 dBA	17 dBA	16 dBA
	2282 m	1428 m	1465 m	1538 m	1593 m	1691 m	1378 m	1417 m	1806 m	1459 m
RN19_f	INV01	ST01	INV02	INV06	INV05	INV11	INV07	INV10	INV09	INV03
	32 dBA	28 dBA	23 dBA	17 dBA	16 dBA	16 dBA	15 dBA	15 dBA	15 dBA	14 dBA
	618 m	793 m	906 m	1368 m	1322 m	1653 m	1521 m	1803 m	1791 m	1125 m
RN19_o	INV01	ST01	INV02	INV06	INV09	INV07	INV10	INV12	INV08	INV14
	27 dBA	25 dBA	19 dBA	15 dBA	13 dBA	12 dBA	9 dBA	9 dBA	7 dBA	7 dBA
	594 m	769 m	882 m	1348 m	1771 m	1502 m	1782 m	2682 m	1721 m	2931 m
RN20_f	ST01	INV01	INV02	INV06	INV07	INV05	INV10	INV09	INV11	INV03
	27 dBA	26 dBA	20 dBA	17 dBA	16 dBA	15 dBA	14 dBA	14 dBA	12 dBA	12 dBA
	826 m	677 m	946 m	1491 m	1652 m	1428 m	1910 m	1914 m	1748 m	1174 m
RN20_o	ST01	INV01	INV02	INV07	INV06	INV09	INV11	INV03	INV10	INV18
	26 dBA	25 dBA	17 dBA	14 dBA	13 dBA	12 dBA	10 dBA	9 dBA	9 dBA	8 dBA
	811 m	660 m	931 m	1633 m	1472 m	1895 m	1730 m	1158 m	1891 m	2708 m
RP01_f	INV35	INV34	INV30	INV36	INV31	INV32	INV28	INV27	INV33	INV29
	32 dBA	29 dBA	28 dBA	26 dBA	19 dBA	19 dBA	19 dBA	18 dBA	18 dBA	18 dBA
	443 m	627 m	861 m	0 m	623 m	591 m	1869 m	1912 m	813 m	1128 m

Receptor ID	Top Noise Sources									
	1	2	3	4	5	6	7	8	9	10
RP01_o	INV35	INV34	INV30	INV36	INV31	INV32	INV33	INV29	INV28	INV27
	31 dBA	27 dBA	26 dBA	25 dBA	18 dBA	18 dBA	18 dBA	17 dBA	16 dBA	16 dBA
	422 m	608 m	834 m	0 m	593 m	565 m	792 m	1102 m	1840 m	1883 m
RP02_f	INV36	INV35	INV30	INV34	INV31	INV32	INV33	INV29	INV27	INV28
	39 dBA	36 dBA	36 dBA	34 dBA	30 dBA	29 dBA	27 dBA	23 dBA	17 dBA	17 dBA
	0 m	239 m	351 m	354 m	222 m	415 m	423 m	626 m	1436 m	1415 m
RP02_o	INV36	INV35	INV30	INV34	INV31	INV32	INV33	INV29	INV27	INV28
	41 dBA	37 dBA	36 dBA	34 dBA	28 dBA	27 dBA	25 dBA	22 dBA	16 dBA	16 dBA
	0 m	211 m	363 m	332 m	249 m	432 m	415 m	637 m	1464 m	1444 m
RP03_f	INV34	INV35	INV36	INV30	INV32	INV29	INV31	INV27	INV28	INV33
	39 dBA	37 dBA	34 dBA	32 dBA	20 dBA	20 dBA	20 dBA	15 dBA	15 dBA	14 dBA
	325 m	514 m	0 m	580 m	1081 m	633 m	872 m	1770 m	1805 m	298 m
RP03_o	INV34	INV35	INV36	INV30	INV32	INV31	INV29	INV27	INV28	INV33
	39 dBA	37 dBA	33 dBA	28 dBA	19 dBA	19 dBA	16 dBA	14 dBA	14 dBA	13 dBA
	297 m	488 m	0 m	552 m	1052 m	843 m	613 m	1748 m	1781 m	270 m
RP04_f	INV23	INV27	INV25	INV26	INV28	INV19	INV24	INV21	INV22	INV17
	35 dBA	35 dBA	33 dBA	28 dBA	28 dBA	28 dBA	26 dBA	24 dBA	23 dBA	23 dBA
	190 m	452 m	552 m	230 m	594 m	895 m	365 m	775 m	584 m	1358 m
RP04_o	INV23	INV27	INV25	INV28	INV26	INV24	INV19	INV21	INV22	INV20
	34 dBA	34 dBA	32 dBA	27 dBA	27 dBA	26 dBA	25 dBA	22 dBA	22 dBA	21 dBA
	161 m	444 m	528 m	582 m	251 m	339 m	901 m	770 m	576 m	1024 m
RP05_f	INV22	INV20	INV19	INV15	INV16	INV17	INV25	INV18	INV21	INV14
	45 dBA	33 dBA	33 dBA	29 dBA	29 dBA	28 dBA	27 dBA	27 dBA	27 dBA	22 dBA
	172 m	556 m	564 m	760 m	756 m	878 m	930 m	950 m	258 m	958 m
RP05_o	INV22	INV20	INV19	INV15	INV21	INV17	INV18	INV16	INV25	INV14
	45 dBA	31 dBA	31 dBA	28 dBA	26 dBA	26 dBA	25 dBA	24 dBA	22 dBA	22 dBA
	164 m	540 m	548 m	744 m	242 m	863 m	936 m	740 m	942 m	942 m
RP06_f	INV22	INV20	INV19	INV16	INV15	INV17	INV25	INV18	INV27	INV21
	42 dBA	32 dBA	32 dBA	29 dBA	29 dBA	27 dBA	27 dBA	27 dBA	26 dBA	25 dBA
	227 m	594 m	613 m	795 m	808 m	909 m	924 m	976 m	1070 m	304 m
RP06_o	INV22	INV20	INV19	INV15	INV17	INV25	INV21	INV18	INV16	INV14
	42 dBA	30 dBA	30 dBA	27 dBA	25 dBA	25 dBA	24 dBA	24 dBA	24 dBA	21 dBA
	214 m	596 m	610 m	805 m	914 m	912 m	303 m	983 m	797 m	1003 m
RP07_f	INV10	INV09	INV11	INV07	INV06	INV18	INV08	INV17	ST01	INV04
	40 dBA	39 dBA	35 dBA	32 dBA	30 dBA	30 dBA	30 dBA	29 dBA	29 dBA	28 dBA
	266 m	294 m	460 m	572 m	691 m	706 m	469 m	780 m	1437 m	892 m
RP07_o	INV10	INV09	INV07	INV11	INV08	INV06	ST01	INV18	INV17	INV12
	40 dBA	39 dBA	31 dBA	30 dBA	29 dBA	29 dBA	28 dBA	28 dBA	27 dBA	25 dBA
	255 m	284 m	561 m	449 m	460 m	679 m	1425 m	715 m	790 m	693 m
VN01	INV36	INV35	INV34	INV30	INV29	INV27	INV28	INV33	INV32	INV31
	21 dBA	20 dBA	18 dBA	17 dBA	12 dBA	9 dBA	9 dBA	8 dBA	4 dBA	3 dBA
	0 m	1107 m	1164 m	1558 m	1759 m	2753 m	2733 m	1355 m	1507 m	1492 m

Receptor ID	Top Noise Sources									
	1	2	3	4	5	6	7	8	9	10
VN02	INV13	INV14	INV12	INV21	INV22	INV17	INV18	INV20	INV16	INV19
	19 dBA	19 dBA	19 dBA	16 dBA	16 dBA	16 dBA	16 dBA	15 dBA	15 dBA	15 dBA
	1232 m	1235 m	1269 m	1570 m	1564 m	1608 m	1712 m	1510 m	1454 m	1336 m
VN03	INV12	INV14	ST01	INV13	INV17	INV18	INV09	INV08	INV10	INV22
	24 dBA	23 dBA	21 dBA	20 dBA	19 dBA	18 dBA	17 dBA	17 dBA	17 dBA	16 dBA
	621 m	775 m	2709 m	668 m	1134 m	1212 m	1480 m	1501 m	1550 m	1454 m
VN04	ST01	INV22	INV25	INV20	INV19	INV16	INV17	INV18	INV15	INV21
	26 dBA	25 dBA	24 dBA	23 dBA	22 dBA	21 dBA	21 dBA	21 dBA	20 dBA	19 dBA
	2582 m	754 m	1271 m	886 m	1002 m	1057 m	1075 m	1086 m	1155 m	724 m
VN05	ST01	INV17	INV21	INV20	INV16	INV19	INV15	INV03	INV14	INV18
	25 dBA	21 dBA	21 dBA	21 dBA	20 dBA	20 dBA	19 dBA	19 dBA	19 dBA	17 dBA
	2113 m	1536 m	1538 m	1549 m	1635 m	1724 m	1801 m	1838 m	1896 m	1473 m
VN06	ST01	INV22	INV20	INV18	INV25	INV17	INV19	INV16	INV15	INV28
	21 dBA	16 dBA	15 dBA	14 dBA	13 dBA	12 dBA				
	2855 m	1690 m	1818 m	1913 m	1907 m	1937 m	1951 m	1967 m	2090 m	2217 m



LEGEND

- Point of Reception
- Noise Barrier
- Road
- Project Location

Noise Contour (dBA)

30-35	35-40	40-45	45-50	50-55	>55
-------	-------	-------	-------	-------	-----

NOTES:

- Produced by Hatch, contains information licensed under the Open Government Licence – Ontario
- Spatial referencing: NAD 1983 UTM Zone 17N
- Noise contours were generated based on a 10 x 10m grid at a 4.5m elevation above ground

0 250 500 1,000
 1:28,000 m

PROJECT: Acoustic Assessment Report Kynoch Solar Project	
FIGURE TITLE: Noise Contours at 4.5m Above Ground	
CLIENT: CarbonFree Kynoch LTD	
DWG BY: V. BAXTER	CHK BY: M. ANDARGIE
DATE: 10/03/26	PAGE: 1
FIG NO.: 2	REV NO.: 1
HATCH	

Appendix E

Acoustic Assessment Report Checklist



ACOUSTIC ASSESSMENT REPORT CHECK-LIST

Company Name: CarbonFree Kynoch Ltd.

Company Address: 1 St Clair Ave W#801
Toronto, Ontario M4T 1Y5

Location of Facility: Kynoch, Ontario

The attached Acoustic Assessment Report was prepared in accordance with the guidance in the ministry document "Information to be Submitted for Approval of Stationary Sources of Sound" (NPC 233) dated October 1995 and the minimum required information identified in the check-list on the reverse of this sheet has been submitted.

Company Contact:	<u>Doug Deeks</u>
Name:	<u>Doug Deeks</u>
Title:	<u>Vice President - Projects</u>
Phone Number:	<u>647-608-9680</u>
Signature:	_____
Date:	_____

Technical Contact:	<u>Hatch Ltd</u>
Name:	<u>Mervyn Choy</u>
Representing:	<u>Hatch Ltd.</u>
Phone Number:	<u>289-326-2740</u>
Signature:	 _____
Date:	<u>2026-03-13</u>

ACOUSTIC ASSESSMENT REPORT CHECKLIST

Required Information		Submitted	Explanation/Reference
1.0	Introduction (Project Background and Overview)	<input checked="" type="checkbox"/> Yes	Section 1
2.0	Facility Description		
	2.1 Operating hours of facility and significant Noise Sources	<input checked="" type="checkbox"/> Yes	Section 2
	2.2 Site Plan identifying all significant Noise Sources	<input checked="" type="checkbox"/> Yes	Appendix B
3.0	Noise Source Summary		
	3.1 Noise Source Summary Table	<input checked="" type="checkbox"/> Yes	Table 3-4
	3.2 Source noise emissions specifications	<input checked="" type="checkbox"/> Yes	Appendix C
	3.3 Source power/capacity ratings	<input checked="" type="checkbox"/> Yes	Appendix C
	3.4 Noise control equipment description and acoustical specifications	<input type="checkbox"/> Yes	Section 5
4.0	Point of Reception Noise Impact Calculations		
	4.1 Point of Reception Noise Impact Table	<input checked="" type="checkbox"/> Yes	Appendix D
	4.2 Point(s) of Reception (POR) list and description	<input checked="" type="checkbox"/> Yes	Table 4-1
	4.3 Land-use Zoning Plan	<input checked="" type="checkbox"/> Yes	Appendix A
	4.4 Scaled Area Location Plan	<input checked="" type="checkbox"/> Yes	Appendix A / B
	4.5 Procedure used to assess noise impacts at each POR	<input checked="" type="checkbox"/> Yes	Section 7.1
	4.6 List of parameters/assumptions used in calculations	<input checked="" type="checkbox"/> Yes	Section 7.1
5.0	Acoustic Assessment Summary		
	5.1 Acoustic Assessment Summary Table	<input checked="" type="checkbox"/> Yes	Table 7-2
	5.2 Rationale for selecting applicable noise guideline limits	<input checked="" type="checkbox"/> Yes	Section 5
	5.3 Predictable Worst Case Impacts Operating Scenario	<input checked="" type="checkbox"/> Yes	Section 7.2
6.0	Conclusions		
	6.1 Statement of compliance with the selected noise performance limits	<input checked="" type="checkbox"/> Yes	Section 8
7.0	Appendices (Provide details such as)	<input checked="" type="checkbox"/> Yes	
	Listing of Insignificant Noise Sources	<input checked="" type="checkbox"/> Yes	Section 3
	Manufacture's Noise Specifications	<input checked="" type="checkbox"/> Yes	Appendix C
	Calculations	<input checked="" type="checkbox"/> Yes	Appendix C
	Instrumentation	<input type="checkbox"/> Yes	n/a
	Meteorology during Sound Level Measurements	<input type="checkbox"/> Yes	n/a
	Raw Data from Measurements	<input type="checkbox"/> Yes	n/a
	Drawings (Facility / Equipment)	<input checked="" type="checkbox"/> Yes	Appendix B