




## NTE8 Time Delay Relay

### 1. General

NTE8 Series time delay relay is applicable for controlling circuit @AC 50Hz/60Hz, up to 230V rated voltage or up to DC 24V rated voltage as delay element to make or break circuit according to preset time.

This product meets the requirements of IEC60947-5-1.

### 2. Type designation



### 3. Technical data

Type	NTE8
Operating mode	Control-off delay/(power) on delay
Delay range	0.1s~10s, 10s~120s, 30s~480s
Number of contacts	Delay 1 N/O
Contact capacity	Ue/Ie:AC-15 230V/1A; DC-13 30V/1A; Ith:5A
Operational voltage	AC230V, AC24V, DC24V
Electrical life	$1 \times 10^5$
Mechanical life	$1 \times 10^6$
Ambient temperature	-5℃~+40℃
Mounting type	Rail type

Figure 2 NTE8-□A Relay wiring diagram







Figure 3 NTE8-□B Relay wiring diagram



### 4. Overall and mounting dimensions (mm)



Adopt TH35-7.5 sectional steel guide rail for installation

# C E R T I F I C A T E



of Conformity  
Low Voltage Directive 2006/95/EC

Registration No.: AN 50227646 0001

Report No.: 15050839 001

Holder: Zhejiang Chint Electrics Co., Ltd.  
No.1,  
Chint Road, Chint Industrial Zone,  
North Baixiang  
Yueqing, Zhejiang Province 325603  
P.R. China

Product: Relay  
(Time-delay Relay)

Identification: Type Designation : NTE8-a/b  
(a = 10, 120, 480)  
(b = A or B, A: OFF-delay B: ON-delay)  
Ratings : AC-15, 1 A / 230 V; DC-13, 1 A / 30 V  
Serial No. : Engineering samples  
Remark: Refer to test report 15050839 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all revision of Annex I of Council Directive 2006/95/EC, in its latest amended version, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.

Certification Body

Qingdao, 13.06.2012



TÜV Rheinland/CCIC (Qingdao) Co., Ltd. - Qingdao 266071 - P.R.China

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE



PHOTO DOCUMENTATION


15050839 001

for

**Time-delay Relay**

**NTE8-a/b**

**Zhejiang Chint Electric Co., Ltd.**



This documentation consists of 4 pages (excluding this cover page).

Remark: **NTE8-a/b** ( $a = 10, 120, 480$ ,  $b = A$  or  $B$ ,  $A$ : OFF-delay relay,  $B$ : ON-delay relay)



