TOKHEIM FLAME ARRESTER INSTALLATION

- 1. Inspect plate stacks and base to be sure they are free of any packing materials.
- 2. Apply pipe sealer to pipe nipple and screw arrester on pipe by hand. Tighten securely with a pipe wrench applied to the base of the unit.

TOKHEIM FLAME ARRESTER MAINTENANCE

Tokheim Flame Arresters are designed for use at the termination of a vent pipe to vent vapors directly to the atmosphere. It is very important that the vent pipe is extended a safe distance above ground. If it is near a building it should be extended above the roof. It is important to inspect and clean the plate stacks on a regular basis to maintain maximum performance.

To Inspect:

Remove the cover and lift out the plate stacks. Hold the plate stacks up to a light. Spaces between plates should be open and clear of debris.

To Clean:

Immerse plate stacks in warm soapy water and agitate to clean out any dirt or debris

Use a soft cloth dampened with naptha to clean the base and cover of the unit. Rinse all parts well with hot water and blow dry with compressed air. Replace plate stacks and cover making sure nuts are tightened firmly.

Tokheim Flame Arresters will perform much better if they are kept clean.