

BULLETIN 4-22-08

Clarification on pressure/ vapor capacity of the components of the NO. 20
TANK GAUGE

The following components have been pressure tested and are 100%
inspected to be pressure and vapor tight at 5 PSI:

Reading Section Part # 20R-20GX

Lower Housing/
Proving Device Part # 20R-20A

Elbows Part # 20R020H

Float Part # 12-AF

Tokheim gauges are also fully enclosed and tamper proof.