

TECHNICAL REPORT

SATRA Technology Europe Ltd Bracetown Business Park Clonee County Meath Dublin 15 Ireland	SATRA reference:	CHM2010891
		2433
		1
	Report ID/Issue number:	43958/1
	Your reference:	STE2010519
	Date samples received:	16/08/2024
	Date(s) work carried out:	29/08/2024 to 20/09/2024
	Date of report:	20/09/2024

Testing Requirements

Regulation 2016/425 Module C2 testing of gloves described as MASTERFUL in accordance with EN 16523-1:2015+A1:2018 resistance to permeation by chemicals against 40% Sodium Hydroxide & 37% Formaldehyde

For SATRA's full terms and conditions see our website: <https://new.satra.com/satra-terms-and-conditions/>

For SATRA's statements regarding the confidentiality, publication and dissemination of this report, decision rules and UKAS accreditation please see the final page of this technical report.

Report Signed by:

Lorna Harding


Report Signatory

WORK REQUESTED:

Samples of gloves described as MASTERFUL were received by SATRA Technology UK on the 16th August 2024 for testing in accordance with EN 16523-1:2015+A1:2018 and with the performance requirements of EN ISO 374-1:2016+A1:2018 to demonstrate ongoing production compliance with Module C2 of Regulation (EU) 2016/425.

Sample Reference:	MASTERFUL
Lot/Batch Code:	83414 28705
Date of Manufacture:	11/2023
Expiry Date:	11/2028
Sample Colour:	Blue
Sample Size:	XLarge
Date Sample(s) Received by SATRA Technology Europe:	12/08/2024
Sample(s) were obtained from:	Not provided.
Test area:	Palm
Customer:	DCK GRUP İÇ DIŞ TİCARET MEDİKAL LTD.ŞTİ. MACUN MAH. BATI BULV. ATB İŞ MERKEZİ E BLOK 1/108 YENİMAHALLE Ankara 06374
Initial testing/ Retest:	Initial testing

SAMPLES SUBMITTED:



Samples described as MASTERFUL

CONCLUSION:

When assessed in accordance with the requirements of EN ISO 374-1:2016+A1:2018 the samples of gloves described as MASTERFUL achieved the following performance levels:

Chemical	Performance level
40% Sodium hydroxide (CAS: 1310-73-2)	6
37% Formaldehyde (CAS: 50-00-0)	5

Mean thickness of 20 specimens prepared from the palm area of the gloves (mm)	0.10
---	------

Full results are reported in the following tables.

TESTING REQUIRED:

- EN 16523-1:2015+A1:2018 - Determination of material resistance to permeation by chemicals - Part 1: Permeation by liquid chemical under conditions of continuous contact
- Indicative thickness measurements of 20 specimens prepared from the palm area of the gloves


RESULTS AND REQUIREMENTS:

EN ISO 374-1:2016+A1:2018 - Protective gloves against dangerous chemicals and micro-organisms - Part 1: Terminology and performance requirements for chemical risks. Table 1: Permeation performance levels.

Permeation performance level	Measured breakthrough time (minutes)
1	>10
2	>30
3	>60
4	>120
5	>240
6	>480


Performance levels are based on the lowest individual result achieved per chemical.

Test/Property	Sample reference:	MASTERFUL		Performance	
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-009 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 40% Sodium Hydroxide		Level 6	
		Normalised permeation rate (NPR): 1 µg/cm²/min			
		Detection technique: Conductimetry (continuous measurement)			
		Collection medium: Deionised water (closed loop)			
		Collection medium stirring rate: (each cell constant to within ± 45 – 65 ml/min 10%)			
		Test temperature: (23 ± 1) °C			
	Specimen	Thickness (mm)△	Breakthrough time (mins)		
		1	0.09		>480
		2	0.11		>480
		3	0.09		>480
		Test result:	>480		
	UoM:	<1			
Visual appearance of specimens after testing:		Swollen and discoloured			



Test/Property	Sample reference:	MASTERFUL		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-025 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 37% Formaldehyde		Level 5
		Normalised permeation rate (NPR): 1 µg/cm²/min		
		Detection technique: HPLC-DAD (periodic measurement)		
		Collection medium: Deionised water (closed loop)		
		Collection medium stirring rate: (each cell constant to within ± 45 – 65 ml/min 10%)		
		Test temperature: (23 ± 1) °C		
	Specimen	Thickness (mm)△	Breakthrough time (mins)▼	
		1	0.10	Between 241 to 360
		2	0.10	Between 241 to 360
		3	0.09	>480
	Test result:	Between 241 to 360		
	UoM:	See below		
Visual appearance of specimens after testing:		Swollen and discoloured		

For SOP CAT-025, where both the P_1 and P_u are observed in the same sampling range, uncertainty is expressed as the time difference between the mid-point of the range and the previous sampling time. This uncertainty is included in the reported result.



Formaldehyde is determined by discrete sampling; therefore, the permeation rate graph is not a smooth curve.

- △ EN 16523-1:2015+A1:2018 does not require the test specimen thicknesses to be reported, this information is indicative only.
- ▼ Breakthrough expressed as a range between discrete sampling points where the average permeation rate exceeds the NPR. Due to the complexity of the detection technique, the minimum sampling frequency as specified in table 1 of EN 16523-1:2015+A1:2018 is not possible.

Indicative thickness measurements of 20 specimens prepared from the palm area of the gloves

Thickness measurement (mm)			
1	0.11	11	0.09
2	0.09	12	0.11
3	0.10	13	0.10
4	0.10	14	0.09
5	0.10	15	0.10
6	0.11	16	0.11
7	0.11	17	0.12
8	0.10	18	0.10
9	0.10	19	0.08
10	0.10	20	0.08
Mean thickness (mm)		0.10	

Conditions of Use

Confidentiality and Dissemination

SATRA test reports may be forwarded to other parties if they are not changed in any way and are not marked as confidential. Test reports must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Liability

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Accreditation

Where the UKAS logo is included on the test report then tests marked ≠ fall outside the UKAS Accreditation Schedule for SATRA. Where no UKAS logo is included on the test report then none of the tests reported are covered by SATRA's UKAS Accreditation.

Tests marked ¥ are performed under SATRA's Flexible UKAS Schedule.

Opinions and interpretations fall outside the UKAS Accreditation for SATRA.

Uncertainty of Measurement and Decision Rules

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail or the allocation of a class or level) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class, or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

SATRA's guidelines provide recommendations that are based upon SATRA's knowledge and experience. The guidelines are intended to indicate conformance by providing information on the likely performance or characteristics of a property. As such, uncertainty of measurement is not applied when evaluating results against guideline recommendations.
