

Beach Harbor
Attn: Manager
111 Beach Harbor Drive
Grasonville, MD 21638

Reporting Date: 03/04/2024
PWSID #: MD1170001

System Name: Beach Harbor
Sample Type: Drinking Water
Laboratory Certification: MD-214
Received by Lab: Date: 01/10/2024 Time: 11:22 AM
Sampler ID: R. Shields, 2212RS, WTL of MD

Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
5341-1	TP01 - POE Tap	01/10/2024 09:35 AM	ARSENIC	1005	0.0078	mg/L	0.0010	EPA 200.9, Rev 2.2	0.0100	01/12/2024 11:09 AM
5340-1	TP01-POE Tap	01/10/2024 09:35 AM	NITRATE	1040	ND	mg/L	0.5	EPA 353.2, Rev. 2.0	10	01/10/2024 01:01 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
5. ND - Not Detected at the corresponding reporting limit.
6. NA - Not Applicable.
7. We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

K. Wentworth

K. Wentworth, Customer Service Representative