

**Beach Harbor
Attn: Manager
111 Beach Harbor Drive
Grasonville, MD 21638**

Reporting Date: 06/11/2024
PWSID #: MD1170001

System Name: Beach Harbor
Sample Type: Drinking Water
Laboratory Certification: MD-214
Received by Lab: Date: 06/03/2024 Time: 03:03 PM
Sampler ID: R. Shields, 2212RS, WTL of MD

Analytical Results

Sample ID	Sample Address	Sample Source	Date Collected	Time Collected	pH (SU)	Results			
						Coliforms/100ml		mg/L	
						Total Coliform Bacteria	E.Coli Bacteria	Free Chlorine	Total Chlorine
5321-1	111 Beach Harbor Drive Grasonville, MD 21638	Clubhouse Restroom	06/03/2024	02:11 PM	7.7	Absent	Absent	0.2	0.3
5333-1	111 Beach Harbor Drive Grasonville, MD 21638	Unit #77-Hose Bib	06/03/2024	02:18 PM	7.7	Absent	Absent	0.8	0.9

- Notes:
1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
 2. Sample received and examined within EPA's recommended holding time.
 3. Results in **BOLD** exceed the EPA's Primary MCL.
 4. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
 5. ND - Not Detected at the reporting limit of 0.1 mg/L.
 6. NA - Not Applicable.
 7. Analytical method(s): SM9221D+F with Report Limit: Present/Absent
 8. We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,
K. Wentworth

K. Wentworth, Customer Service Representative