

RPMUD Newsletter



MONTHLY ACTIVITY

Sewer Collection/Lift Station

Completed control and pump repair at Mosswood lift station.

Jetted sewer line due to stoppage on Brandon Rd.

Used backhoe to make repair to sewer line on Vicksburg Ln.

Water Distribution

Flushed dead end mains throughout District.

Flush and tested fire hydrants throughout District.

Excavated and repaired 9 leaks throughout District.

Began valve survey throughout distribution.

Water Treatment Plants

Made repairs to chlorination equipment at water plant 2 (replaced regulator).

Sewer Treatment Plant

De-ragged lift pumps at on-site lift station.

MAJOR PROJECTS

Sanitary Sewer Rehabilitation Phase 1

Contractor completed the lining of RP10006 to RP10006BC along Charleston.

Storm Sewer Rehabilitation Phase 1

Contractor completed the work along Robert E. Lee Dr replacing the 60" corrugated metal pipe.

Water Plant No. 2 Electrical Upgrades

Contractor has completed the conduit work and has been pulling all of the wires to various components of the plant.

East Ditch Cleanout

Contractor has completed the cleanout of the East Ditch

