

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Sacred International School G.T Road Khilchian, Amritsar
Sacred International School G.T Road Khilchian, Amritsar

No.: RWTLASR/2223/01054 Dated : 06/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Nil Dated: 17/03/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 21/03/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab, Amritsar

✓



TC-9815

TEST REPORT						
Name & Address of Customer : Principal Sacred International School G.T Road Khilchian, Amritsar Sacred International School G.T Road Khilchian, Amritsar			Customer Reference No.	No : Nil Dated : 17/03/2023		
			Sample Submitted by	Mr. Vikramjeet Singh		
			Date of Sample Receipt	21/03/2023		
			Analysis Starting Date	22/03/2023		
			Analysis completion Date	23/03/2023		
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC98152300000178F		Sample Type :	Water		
Test Report No.:	RWTLASR/2223/01054		Date of Issue :	06/04/2023		
Registration no.:	RWTLASR/REG2223/07915		Condition of Sample :	Unsealed		
Collection Point:	Private Submersible		Quantity/Type of Bottle:	1000 ml / Plastic Bottles		
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :	G.T Road(S/pump 110 ft) / NA		
Village :	Not Mentioned		Habitation :	Not Mentioned		
Block:	Not Mentioned		District :	Amritsar		
Latitude :	Not Mentioned		Longitude:	Not Mentioned		
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.90	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	306	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.50	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	280	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	208	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	36.87	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	28.18	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	95.97	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

(Signature)

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab, Amritsar

----- End of the Test Report -----



OFFICE OF CIVIL SURGEON, AMRITSAR

PHONE 0183 2211864

E-MAIL:- nrhmamritsar@gmail.com



No.SSI/CS/ASR/2023/.....¹².....

DATED; 08/05/2023.....

Certificate of Cleanliness and Sanitation

*This Is To Certify That We Have Inspected The Premises Of **SACRED INTERNATIONAL SCHOOL G.T.Road Khilchian Distt. AMRITSAR** On 26/04/2023 After Inspecting Their Class Rooms And Toilets. We Certify That Their Cleanliness And Sanitation is Satisfactory. Facility of portable water with R.O. is also available.*


Civil Surgeon ,Amritsar