



Mt. Angel Fire District

www.mtangelfire.org

300 Monroe St.
PO Box 335
Mt Angel OR. 97362
PH 503-845-2438
FAX 503-845-2855

APPLICATION FOR TENT PERMIT

APPLICATION #: _____
(Issued by Fire District)

Name of Applicant: _____

Mailing Address: _____

Telephone Number: (Home) _____ (Work) _____

Date(s) of Use: _____ Inspection Setup Time: _____

Site Address: _____

Size of Tent: _____

Manufacturer's Name: _____

Flame Retardant Certification Last Date Treated: _____

Plot Plan Attached to Application? ☐ Yes ☐ No

Other Pertinent Information: _____

Issued By: _____ Date: _____
(Fire Code Official)

Inspection Fee: \$50.00*

* Note: The fee will be waived for a recognized non-profit organization

**PROVISIONS OF THE OREGON FIRE CODE CHAPTER 24 SHALL APPLY TO THE
ISSUANCE OF THIS PERMIT (See attached checklist).**

LIABILITY: THIS PERMIT DOES NOT RELIEVE THE PERMITTEE FROM CRIMINAL OR CIVIL LIABILITY FOR DAMAGES ARISING FROM EVENTS OCCURRING UNDER HIS/HER CONTROL. VIOLATIONS OF THE REQUIREMENTS MAY RESULT IN THE ISSUANCE OF A CITATION OR CIVIL PENALTY.

I have read and understand the above and agree to the conditions.

Permittee or Permittee's Agent: _____ Date: _____
(Signature)

PERMIT INVALID WITHOUT SIGNATURE AND FIRE DEPARTMENT SIGN-OFF

This completed application may be emailed to MAFD@mtangelfire.org , or dropped off at the fire district office

OFC TENT & MEMBRANE STRUCTURE CHECKLIST

☐ Permit Requirements

- A tent permit is required for tents greater than 400 sq. ft. in area and canopies greater than 700 sq. ft. in area, and a copy shall remain available on site. A plot plan with dimensions and required distance information shall be attached to the permit application.
- A copy of the Flame Retardant Certification with the last date of treatment shall be attached to the permit application
- Available contact person(s) name and phone number(s) shall be clearly printed on the permit form.

☐ Location (Minimum Required Distances):

- 20' from lot lines, buildings, other tents, canopies or membrane structures, parked vehicles or internal combustion engines (**Exception:** Separation distance for tents not used for cooking is not required when the aggregate floor area does not exceed 10,000 square feet.)
- 20' from combustible vegetation, 30' from combustible waste
- 50' from fuel dispensing locations
- 50' from other structures unless joined together by a corridor (tents 15,000 sq. ft. or more only)
- 50' from combustible liquid storage
- 10' from LP gas containers with a capacity of 500 gallons or less
- 25' from LP gas containers with a capacity of more than 500 gallons

Access

- Minimum 12' unobstructed firebreak passageway or fire road maintained on sides of tent
- Minimum 3' clearance from fabric envelope to all contents located inside membrane structure

Exits/Egress/Aisles

- Shall be spaced at approximately equal intervals around the perimeter of the tent, canopy or membrane structure, and shall be located such that all points are 100 feet (30 480 mm) or less from an exit.
- Shall be clearly marked and unobstructed
- Shall remain open (unless covered with a fire resistant sliding curtain) or have exit doors swinging in the path of exit travel
- Minimum height 8' to guy wires, guy ropes and other support members crossing means of egress
- Shall have at least one exit and not less than the number of exits required by Table 2403.12.2. The widths of means of egress required by Table 2403.12.2 shall be divided approximately equally among the separate means of egress. The total width of means of egress in inches (mm) shall not be less than the total occupant load served by a means of egress multiplied by 0.2 inches (5 mm) per person.
- Maximum occupancy sign shall be posted near the main entrance when occupant load > 49 at discretion of fire code official.

☐ **Signage/Exit Illumination/Emergency Power**

- Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more.
- The means of egress shall be illuminated with light having an intensity of not less than 1 foot-candle at floor level while the structure is occupied. Fixtures required for means of egress illumination shall be supplied from a separate circuit or source of power.
- Emergency power shall be required for occupant loads of over 300
- Smoking shall not be permitted in tents, canopies or membrane structures. Approved "NO SMOKING" signs shall be conspicuously posted in accordance with Section 310.

☐ **Anchorage**

- Tents, canopies or membrane structures and their appurtenances shall be adequately roped, braced and anchored to withstand the elements of weather and prevent against collapsing. Documentation of structural stability shall be furnished to the fire code official on request.

☐ **Heat Sources/Cooking**

- Fireworks shall not be used within 100 feet (30 480 mm) of tents, canopies or membrane structures.
- Open flame or other devices emitting flame, fire or heat or any flammable or combustible liquids, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 20 feet (6096 mm) of the tent, canopy or membrane structures while open to the public unless approved by the fire code official.
- Tents where cooking is performed shall be separated from other tents, canopies or membrane structures by a minimum of 20 feet (6096 mm). Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet (6096 mm) from a tent, canopy or membrane structure.
- Cooking and heating equipment shall not be located within 10 feet (3048 mm) of exits or combustible materials.
- Heating and cooking equipment shall be installed in accordance with the International Mechanical Code and the International Fuel Gas Code

☐ **Portable fire extinguishers shall be provided as follows:**

- Minimum "2A10B:C" rating
- Located preferably near exits
- Maximum travel distance to an extinguisher = 75'

Table 2403.12.2: Minimum Number of Means of Egress and Means of Egress Widths from Temporary Membrane Structures, Tents, and Canopies

Occupant Load	Minimum # of Means of Egress	Minimum Width of each Means of Egress (inches)-Tent	Minimum Width of each Means of Egress (inches)-Membrane Structure
10 to 199	2	72	36
200 to 499	3	72	72
500 to 999	4	96	72
1,000 to 1,999	5	120	96
2,000 to 2,999	6	120	96
Over 3,000	7	120	96

Occupant Load Factor (sq. ft. per occupant): Assembly (Standing only) = 5;
Assembly (Chairs) = 7; Assembly (Tables & Chairs) =15; Mercantile = 30