

CORNELL 30 MW COMBINED HEAT AND POWER PROJECT

October 21, 2010

Aaron Bolhous, P.Eng

***IAGT Fall 2010 Course
Hamilton Ontario***



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Cornell University

- Founded in 1865
- Member of Ivy League
- 1,600 Faculty
- 7,600 Staff
- 19,000 Students
- Central Utilities and Energy Management provides steam and chilled water to 300 buildings totaling 14,000,000 ft²
 - 57% Endowed Cornell Campus
 - 40% State funded facilities
 - 3% Federal & Private Research
- Continuing to expand



Cornell University




Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Central Heating Plant



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Central Heating Plant

- Six existing steam boilers

Boiler	Fuel	Pressure	Capacity
1	Coal	400 psig	75,000 lb/hr
2	#6 Fuel Oil	200 psig	70,000 lb/hr
5	Natural Gas	200 psig	100,000 lb/hr
6	Natural Gas or #6 Fuel Oil	400 psig	107,500 lb/hr 109,500 lb/hr
7	Natural Gas or #6 Fuel Oil	400 psig	107,500 lb/hr 109,500 lb/hr
8	Coal	400 psig	170,000 lb/hr

- Two existing back-pressure steam turbine generators: 1,700 kW and 5,800 kW
- Two existing hydroelectric generators: 800 kW and 1,100 kW




Electrical Consumption

- Total campus consumption is 250 Million kW.hr annually
- On-site generation is 32 Million kW.hr (13%)
- Peak Purchased Demand – 34,000 kW
- Minimum Demand – 16,000 kW
- Annual Average Load – 25,000 kW
- Expected 20-year Growth
 - Total Consumption – 300 Million kW.hr annually
 - Peak Purchased Demand – 41,500 kW
 - Annual Average Load – 30,600 kW



Electrical Consumption




Steam Consumption

- Maximum Annual Steam Load – 360,000 lb/hr
- Minimum Annual Steam Load – 50,000 lb/hr
- Annual Average Steam Load – 143,000 lb/hr
- Steam Produced at 400 psig, 600°F
- Winter Distribution Pressure – 75 psig
- Summer Distribution Pressure – 35 psig
- Expected 20-year Growth
 - Maximum Annual Steam Load – 450,000 lb/hr
 - Annual Average Steam Load – 185,000 lb/hr



Steam Consumption



Reasons for Combined Heat and Power

- Electrical outages are very costly in terms of research and salaries
- Some critical research facilities require specific ambient conditions
- Aging existing boilers
- Continued load growth
- Wanted increased fuel flexibility to minimize operating costs
- Wanted to decrease dependence on coal
- University mandate working toward Carbon Neutral
- 2003 Northeast blackout emphasized potential vulnerability




Feasibility Study

- Cogeneration plants in various sizes between 5-30 MW
- 1 vs. 2 GTG/HRSG trains
- Natural gas procurement
- Dual fuel capability
- Condensing steam turbine due to excess steam
- Other steam load modifiers
- Existing stacks vs. new stacks
- Emissions abatement req'mts
- Electrical interconnection
- Adjacent to existing heating plant or different section of campus




Feasibility Study

- Plant location:
 - North: buried utilities, highway, aesthetics, existing plant access
 - South: virtually no visual impact, coal pile, installation of future new package boilers, hill/road
- Constructability
- Economic evaluation including all utility, operating and maintenance, debt services, compliance and labour costs
- Potential retirement of 1 or 2 existing boilers



Study Results

- 30 MW plant based on 2x15 MW units provides most flexibility and meets electric and steam needs
- HRSG equipped with duct burners for additional steam flexibility
- Natural gas to be procured through new 5.2 km high pressure line interconnecting with Dominion Transmission Inc.
- Dual fuel was determined not cost effective
- Dual fuel to be included based on risk management considerations
- Existing No.6 fuel oil system to be converted to No.2 fuel oil system



Study Results


- Condensing steam turbine not economic since not enough excess steam and significant additional equipment
- Steam condenser included to allow operation of both GTGs during summer for electrical demand reduction or sale of electricity
- New stacks included to maintain complete flexibility of operating the GTG/HRSGs and the existing boilers simultaneously
- Emissions examined included NO_x, CO, VOC, SO₂, CO₂, particulate (PM10), formaldehyde and NH₃
- Both SCR and CO catalysts required
- Renewal and upgrade of 115 to 13.2 kV substation
- Addition of third transformer
- CHP plant would be located south of the existing heating plant

Decision was made to build the Combined Heat and Power Plant




Design Implementation

- GTG and HRSG selected by competitive bid process
- 2 x Solar Titan 130 successful bid
- ISO rating: 15,000 kW, 9,695 btu/kW.hr (LHV)



Design Implementation

- SCR catalyst temperature range required a split evaporator
- HRSG changed to two pressures to avoid split evaporator and increase overall efficiency
- CO catalyst options:
 - high temperature located upstream of duct burner
 - low temperature located within evaporator



Design Implementation

- Temporary support of new enclosed conveyor



Design Implementation

- Placing the new plant deep within an existing slope
- Locating new plant beside 90 year old building/foundation
- Ensuring new plant doesn't "slide" into existing building over time
- New office building on piles to minimize additional pressure



Design Implementation

- Constrained site made setting of major equipment difficult
- Large, heavy equipment deliveries through hilly terrain and city streets req'd detailed delivery schedule and plan



- 8 “escorted” deliveries
- HRSGs alone required approximately 40 trucks



Design Implementation

- Emissions modeling and permitting accounting for GTGs, HRSG duct burners, and two 1,000 kW EDGs
- Ammonia unloading and storage system required
- Continuous Emission Monitoring system required



Design Implementation

- Replace existing two x 100% 50 MVA, 115 to 13.8 kV transformers
- Change to three x 50% 37.5 MVA, 115 to 13.8 transformers
- Maintaining electricity to campus throughout construction and commissioning



Design Implementation

- Dedicated 5.2 km high pressure 8" gas pipeline (550 psig)
- New on-site filtering, heating and regulating station (425 & 30 psig)



Construction



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Construction




Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Construction



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Overall Budget and Schedule

Budget

Construction	\$43.8 Million
Engineering & Permitting	\$8.0 Million
Pre-Purchased Equipment	\$28.5 Million
Support	<u>\$2.0 Million</u>
Total Project Budget	\$82.3 Million

Schedule

Planning	Mar 02 – Dec 05
Engineering	Jan 06 – May 09
Permitting	Jul 07 – Jun 08
Construction	Jun 07 – Jan 10



Combined Heat and Power Plant



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Combined Heat and Power Plant



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Enclosed Air Plenum



“Unique” pre-filtration system for GTG inlet air, GTG enclosure ventilation and building ventilation



Mezzanine Level - HRSGs



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Mezzanine Level – Electrical Room



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Mezzanine Level – Balance of Plant



Water cooled generator and lube oil coolers via on-campus chilled water district cooling system



Operating Floor – Access Aisle




Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Operating Floor – Centre Aisle



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



New Office / Locker Room Building



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Steam Condenser Building



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com



Summer 2005



Fall 2009



Gryphon International Engineering Services Inc.
www.gryphoneng.com

Industrial Application of Gas Turbines
www.iagtcommittee.com

