

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1685

Dated: 26/11/2025

It is certified that an inspection team headed by Chandan Bhustan Ram

(Name of Officers with designation) from Junior Engineer PHED

inspected the SIDHARTH FOUNDATION SCHOOL, KAHATHU, JAGDISHPUR, BHOJPUR, BIHAR

(Name & Address of the school) on 15.11.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Nil dated 21.11.25


of Lab certificate (PHED Lab) certified that the

SIDHARTH FOUNDATION SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with Seal: 
Name: Chandan Bhustan Ram
Designation: Junior Engineer
Name & Address of the Office / Department :

To
SIDHARTH FOUNDATION SCHOOL
KAHATHU-JAGDISHPUR, BHOJPUR BIHAR
(Name & Address of the Institution)

JUNIOR ENGINEER
P.H. SECTION
(BIHIYA)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar
Public Health Engineering Department

District Name : Bhojpur

Division Name: P.H. Division, Ara

Date of Sampling :- 15-11-2025
Date of Testing :- 21-11-2025

S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters																Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1	JAGDISHPUR	-	-	WATER SAMPLE OF SIDHARTH FOUNDATION SCHOOL KAHATHU - MASURI (JAGDISHPUR)	-	7.161	0.1	107	69	80	16.03	9.72	19.99	80	0.02	NT	NT	NT	<0.001	-ve	SAFE	
Permissible Limit in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1'	0.01	-		
						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-		

*NT = Not Tested, BDL=Below Detection Limit


 Research Assistant
 (Chemist)
 P.H. Division, Ara

Research Assistant
 DLWQTL.
 P.H. Div. Ara