



Hydrant Flow Test Report

PROJECT SUMMARY:

Address: _____

By: xxxx xxxx - Servinspect
xxxx xxxx - Servinspect

Date: _____

Witness: City/Town of xxxx

Time: _____

Pipe Size: xxx mm

RESIDUAL HYDRANT TESTING RESULTS:

Static Pressure: 110 PSI

Diffuser Type: 2.5 " Hydrant Pro Diffuser

Residual Pressure (1 Port Open): 85 PSI

Diffuser Coefficient: 0.9

Residual Pressure (2 Ports Open): 60 PSI

Port Diameter: 2.5 "

FLOW HYDRANT TESTING RESULTS:

1 Port Open

Pitot Reading 50 psi

2 Ports Open

Pitot Reading 13 & 17 psi

Projected Flow to 20 PSI

Flow 1187 USGPM

Flow 1297 USGPM

Flow 1782 USGPM

HYDRANT FLOW TEST PLOT:

