

DISCHARGE MONITORING REPORT (DMR)

Digitally signed by:
AEPACS
Date: 2026.05.27 14:50:22 -05:00
Reason: Copy Of Record
Location: State of Alabama

Permittee Name: Water, Sewer, & Gas Board of the Town of Wedowee
Facility Name: Wedowee Lagoon
Location: Woodland Lane, Off of Alabama Highway 48
 Wedowee, AL 36278
County: Randolph

Permit No: AL0024171	
Monitoring Period	
From: 4/1/2026	To: 4/30/2026

Outfall: 002-1

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Sample Freq	Sample Type
Oxygen, Dissolved (DO) (00300) EFFLUENT GROSS VALUE	Sample Measurement	*****	*****	*****	7.6	*****	*****	mg/l	0	Monthly	Grab
	Permit Requirement	*****	*****		6.0 Minimum Daily	*****	*****			Monthly	Grab
pH (00400) EFFLUENT GROSS VALUE	Sample Measurement	*****	*****	*****	7.2	*****	7.2	S.U.	0	Monthly	Grab
	Permit Requirement	*****	*****		6.0 Minimum Daily	*****	9.0 Maximum Daily			Monthly	Grab
Solids, Total Suspended (00530) EFFLUENT GROSS VALUE	Sample Measurement	5.98	9.13	lbs/day	*****	11	11	mg/l	0	Monthly	Grab
	Permit Requirement	187 Monthly Average	281 Weekly Average		*****	90.0 Monthly Average	135 Weekly Average			Monthly	Grab
Solids, Total Suspended (00530) RAW SEW/INFLUENT	Sample Measurement	132.68	202.48	lbs/day	*****	244	244	mg/l	0	Monthly	Grab
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average			Monthly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Andrew Shelton		Electronically Signed via AEPACS	(334) 849-7741	05/27/2026

DISCHARGE MONITORING REPORT (DMR)

Permittee Name: Water, Sewer, & Gas Board of the Town of Wedowee
Facility Name: Wedowee Lagoon
Location: Woodland Lane, Off of Alabama Highway 48
 Wedowee, AL 36278
County: Randolph

Permit No: AL0024171	
Monitoring Period	
From: 4/1/2026	To: 4/30/2026

Outfall: 002-1

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Sample Freq	Sample Type
Nitrogen, Ammonia Total (As N) (00610) EFFLUENT GROSS VALUE	Sample Measurement	1.67	2.55	lbs/day	*****	3.07	3.07	mg/l	0	Monthly	Grab
	Permit Requirement	9.4 Monthly Average	14.0 Weekly Average		*****	4.5 Monthly Average	6.7 Weekly Average			Monthly	Grab
Nitrogen, Kjeldahl Total (As N) (00625) EFFLUENT GROSS VALUE	Sample Measurement	3.40	5.19	lbs/day	*****	6.26	6.26	mg/l	0	Monthly	Grab
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average			Monthly	Grab
Nitrite Plus Nitrate Total 1 Det. (As N) (00630) EFFLUENT GROSS VALUE	Sample Measurement	5.76	8.80	lbs/day	*****	10.6	10.6	mg/l	0	Monthly	Grab
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average			Monthly	Grab
Phosphorus, Total (As P) (00665) EFFLUENT GROSS VALUE	Sample Measurement	2.24	3.42	lbs/day	*****	4.12	4.12	mg/l	0	Monthly	Grab
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average			Monthly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Andrew Shelton		Electronically Signed via AEPACS	(334) 849-7741	05/27/2026

DISCHARGE MONITORING REPORT (DMR)

Permittee Name: Water, Sewer, & Gas Board of the Town of Wedowee
Facility Name: Wedowee Lagoon
Location: Woodland Lane, Off of Alabama Highway 48
 Wedowee, AL 36278
County: Randolph

Permit No: AL0024171	
Monitoring Period	
From: 4/1/2026	To: 4/30/2026

Outfall: 002-1

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Sample Freq	Sample Type
Flow, In Conduit or Thru Treatment Plant (50050) EFFLUENT GROSS VALUE	Sample Measurement	0.0652	0.1079	MGD	*****	*****	*****	*****	0	Daily	Continuous
	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Continuous
Chlorine, Total Residual (50060) EFFLUENT GROSS VALUE	Sample Measurement	*****	*****	*****	*****	0.01	0.01	mg/l	0	Monthly	Grab
	Permit Requirement	*****	*****		*****	0.053 Monthly Average	0.091 Maximum Daily			Monthly	Grab
E. Coli (51040) EFFLUENT GROSS VALUE	Sample Measurement	*****	*****	*****	*****	0	0	col/100mL	0	Monthly	Grab
	Permit Requirement	*****	*****		*****	548 Monthly Average	2507 Maximum Daily			Monthly	Grab
BOD, Carbonaceous 05 Day, 20C (80082) EFFLUENT GROSS VALUE	Sample Measurement	0.27	0.41	lbs/day	*****	0.5	0.5	mg/l	0	Monthly	Grab
	Permit Requirement	14.5 Monthly Average	21.8 Weekly Average		*****	7.0 Monthly Average	10.5 Weekly Average			Monthly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Andrew Shelton		Electronically Signed via AEPACS	(334) 849-7741	05/27/2026

DISCHARGE MONITORING REPORT (DMR)

Permittee Name: Water, Sewer, & Gas Board of the Town of Wedowee
Facility Name: Wedowee Lagoon
Location: Woodland Lane, Off of Alabama Highway 48
 Wedowee, AL 36278
County: Randolph

Permit No: AL0024171	
Monitoring Period	
From: 4/1/2026	To: 4/30/2026

Outfall: 002-1

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082) RAW SEW/INFLUENT	Sample Measurement	74.55	113.77	lbs/day	*****	137.1	137.1	mg/l	0	Monthly	Grab
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average			Monthly	Grab
BOD, Carb-5 Day, 20 Deg C, Percent Remvl (80091) Percent Removal	Sample Measurement	*****	*****	*****	99	*****	*****	%	0	Monthly	Calculated
	Permit Requirement	*****	*****		85.0 Monthly Average Minimum	*****	*****			Monthly	Calculated
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	*****	*****	*****	95	*****	*****	%	0	Monthly	Calculated
	Permit Requirement	*****	*****		65.0 Monthly Average Minimum	*****	*****			Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Andrew Shelton		Electronically Signed via AEPACS	(334) 849-7741	05/27/2026

DISCHARGE MONITORING REPORT (DMR)

Permittee Name: Water, Sewer, & Gas Board of the Town of Wedowee
Facility Name: Wedowee Lagoon
Location: Woodland Lane, Off of Alabama Highway 48
 Wedowee, AL 36278
County: Randolph

Permit No: AL0024171	
Monitoring Period	
From: 4/1/2026	To: 4/30/2026

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Andrew Shelton		Electronically Signed via AEPACS	(334) 849-7741	05/27/2026

Submission Identifier: DMR-AL0024171-20260430-1

Submission Signature Hash: Sv65v+sNPQ2bsoSzlhF48KtjazA1ja0zS31PK+sEi2E=

Submitter Name: Andrew Shelton

Submitter Email: andrew.shelton@clearwatersolutions.com

Submitted Date/Time: 5/27/2026 2:50:21 PM