

2024 Water Quality Report for Michiana Water Authority

Water Supply Serial Number: MI0004320

This report covers the drinking water quality for Michiana Water Authority for the 2024 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2024. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

The Michiana Water Authority purchases its water from the Dept. of Water Works, Michigan City, IN. The water is already treated and is transmitted through a 12" watermain into a 500,000 gallon ground storage tank. It is then re-boostered to the distribution system of the Village of Michiana, and a few customers in New Buffalo Township and sold in bulk to the Village of Grand Beach.

If you would like to know more about this report, please contact: Rick Reitz at 269-469-1967 or email rreitz@michianavillage.org


Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish

limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2024 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- ppt: parts per trillion
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Level 1 Assessment: A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

1Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
TTHM Total Trihalomethanes (ppb)	80	N/A	27.90 ug/L		2024	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	<2.000 ug/L		2024	No	Byproduct of drinking water disinfection
Chlorine ¹ (ppm)	4	4	0.62	0.20 - 1.20	2024	No	Water additive used to control microbes
Total Coliform	TT	N/A	N/A	N/A			Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note ²	0	0	N/A	2024	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	0	N/A	2024	No	Human and animal fecal waste

¹ The chlorine "Level Detected" was calculated using a running annual average.

² *E. coli* MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or (2) the supply fails to take all required repeat samples following *E. coli*-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for *E. coli*.

Per- and polyfluoroalkyl substances (PFAS)								
Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant	
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	< 1.9 ng/L	1.9 ng/l	2024	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process	
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	< 1.9 ng/L	1.9 ng/L	2024	No	Discharge and waste from industrial facilities; stain-resistant treatments	
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	< 1.9 ng/L	1.9 ng/L	2024	No	Firefighting foam; discharge and waste from industrial facilities	
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	< 1.9 NG/L	1.9 ng/L	2024	No	Firefighting foam; discharge and waste from industrial facilities	
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	< 1.9 ng/L	1.9 ng/L	2024	No	Discharge and waste from industrial facilities; breakdown of precursor compounds	
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	< 1.9 ng/L	1.9 ng/L	2024	No	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities	
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	< 1.9 ng/L	1.9 ng/L	2024	No	Discharge and waste from industrial facilities; stain-resistant treatments	
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water ³	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant	
Lead (ppb)	15	0	1 ppb	0 ppb – 1ppb	2024	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits	
Copper (ppm)	1.3	1.3	0.1 ppm	0.0ppm - 0.1ppm	2024	0	Corrosion of household plumbing systems; Erosion of natural deposits	

³ Ninety (90) percent of the samples collected were at or below the level reported for our water:0.0ppm-0.1ppm

Unregulated Contaminant Name	Average Level Detected	Range	Year Sampled	Comments
[Name of Unregulated Contaminant] (unit)	N/A	N/A		Results of monitoring are available upon request
[Name of Unregulated Contaminant] (unit)	N/A	N/A		Results of monitoring are available upon request

Information about lead: *Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Michiana Water Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact Michiana Water Authority at 269-469-1967 or rreitz@michianavillage.org for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.*

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney, or nervous system problems.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.



Michigan City Department of Water Works

Water Quality Report 2024

PWSID IN5246020

Message from the Superintendent

We're pleased to once again present to you this year's Annual Water Quality Report. This report is to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are pleased to report that our drinking water is safe and meets federal and state requirements. If you have any questions about this report or concerning your water utility, you may contact the Main Office at (219) 874-3228, and speak to Christopher Johnsen, Superintendent. We want our valued customers to be informed about their water utility. If you want to learn more you may attend the Water Board meetings. They are scheduled twice monthly on the 2nd and 4th Tuesdays at 7:00 p.m. in the Main Office, 532 Franklin Street.

Water Source and Treatment

The greater area of Michigan City receives its drinking water directly from Lake Michigan, a surface water source. It is treated through a conventional treatment process that includes Flocculation-Sedimentation (the mixing of Alum into the water to create "Floc" which allows large particulate matter to settle out of the water) and Filtration (to remove fine particulate matter and micro-organisms from the water). Chemical additions are also required which includes Chlorine (for bacteriological removal), Alum (to remove large particulate matter), Fluoride (to prevent dental decay), and Chloramines (the mixture of chlorine and ammonia which allows for longer disinfectant levels in the water distribution system and remove chlorine odor from the water). Polyphosphate is added to inhibit internal corrosion of water mains and water services.

Monitoring & Measuring Contaminants

The Department of Water Works of Michigan City, IN routinely monitors for contaminants in your drinking water according to Federal and State laws. The Table on the back shows the results of our monitoring for the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

It is important to know that some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune systems disorders, some elderly, and infants can particularly be at risk and should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are also available from the Safe Drinking Water Hotline (800) 426-4791.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. The Department of Water Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in private plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/safewater/lead>.

Other Related Data

The sources of drinking water (both tap and bottled water) include, rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water are:

1. **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural, livestock operations and wildlife.
2. **Inorganic Chemical Contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
3. **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, stormwater runoff and residential uses.
4. **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban stormwater runoff, and septic systems.
5. **Radioactive Contaminants**, which can be naturally occurring or be the result of oil and gas productions and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Water Quality Analysis

The chart that follows the list of abbreviations shows the highest recorded level in Michigan City in 2023 or the last time the contaminant was tested and the highest allowed by the USEPA. Michigan City water has met all EPA requirements.

MCL: Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water, if applicable.

MCLG: Maximum Contaminant Level Goal, the level of a contaminant in drinking water below which there is no known or expected risk to health, if applicable.

MRDL: Maximum Residual Disinfectant Level, the highest level of disinfectant allowed in drinking water.

MRDLG: Maximum Residual Disinfectant Level Goal, the level of drinking water disinfectant below which there is no known or expected risk to health.

AL: Action level, the concentration of a contaminant, which if exceeded, triggers treatment or other requirements, which a water system must follow.

TT: Treatment Technique, a required process intended to reduce the level of a contaminant in drinking water.

NTU: Nephelometric Turbidity Unit, is the measure of clarity of the water

mg/l: milligrams per liter, a measurement for concentration equivalent to ppm = one part per million

ug/l: micrograms per liter, measurement for concentration equivalent to ppb = one part per billion

pCi/l: picocuries per liter, a measurement of radiation

P*: Potential violation, one that is likely to occur in the near future, subject to other applicable requirements.

ND: Not detected, the result was not detected at or below the analytical method detection level.

TT:** **Special Note on Turbidity:** The turbidity treatment technique (TT) requires that at least 95% of the total combined effluent turbidity samples shall not exceed 0.3 NTU (1.0 NTU for slow sand and diatomaceous earth filtration systems). At least 95% is required to be in compliance. In addition, the maximum turbidity level cannot exceed 1.0 NTU at any time.

Date	Contaminant	MCL	MCLG	Unit	Result	Range or Mas	Sites over AL	Violation	Likely Sources
4/1/2024	Barium	2	2	mg/L	0.02	0.02		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
4/1/2024	Fluoride	4	4	mg/L	0.63	0.63		No	Water additive that promotes strong teeth; Erosion of natural deposits; Discharges from fertilizer and aluminum factories.
4/1/2024	Nitrate-Nitrite (as N)	10	10	mg/L	0.38	0.38		No	Erosion of natural deposits; Runoff from fertilizers; Leaching from septic systems and sewers.
4/1/2024	Chromium	100	100	ug/L	1	1		No	Byproduct of drinking water chlorination
2023-2024	Total Trihalomethanes	80	0	ug/L	21.9	13.1-34.1		No	Byproduct of drinking water chlorination
2023-2024	Total Haloacetic Acids	60	0	ug/L	13.1	ND-3.9		No	Byproduct of drinking water chlorination
2024	Chloramines	MRDL = 4	MRDLG = 4	mg/L	1	2-2.5		No	Water additive used to control microbes; At least 40 samples per month per Total Coliform Rule
3/11/2024	Total Organic Carbon	TT	TT	mg/L	2.26	1.45-2.26		No	Naturally present in the environment
2024	Turbidity (lowest percentage)	TT**	TT**	%	98.0	1		No	Soil runoff
2024	Turbidity (Maximum level)	1	1	NTU	0.19	0.02-0.19		No	Soil runoff
2023	Lead (90th percentile)	15 (AL)	0	ug/L	1.9	ND-21	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
2023	Copper (90th percentile)	1.3 (AL)	1.3	mg/L	0.24	0.0018-0.86	0	No	Erosion of natural deposits; Corrosion of household plumbing systems; Leaching from wood preservatives

Violations:

During the period covered by this report, the Department had one violation. Per the Consumer Confidence rule, the Department is required to submit a copy of the CCR to the State by July 1. The Department did not submit the CCR for the year 2023 to the State until July 15, 2024. This violation was a documentation oversight, but in no way jeopardized the safety of the water supplied by the Department.

UCMR-5: Forever Chemicals – PFAS and PFOS

In the year 2023, the USEPA required the Department to monitor for these contaminants quarterly beginning in May of 2023. The contaminants of concern included Perfluorinated and Polyfluorinated Alkyl Substances and Perfluorinated Alkyl Acids, commonly known as PFAS or PFOS. These chemicals have been used in many everyday items, such as Teflon, fire-retardant clothing, and fire-fighting foam. These chemicals have been discovered to not break down over time like many other chemicals do. Therefore, these chemicals have been called "Forever Chemicals". There were a total of 29 variations of these chemicals included. In addition to these chemicals, lithium was tested, due, in part, to the sharp increase in the use of lithium battery technology.

We are happy to announce that all samples of finished water tested below the minimum detection level of the tests. We are also happy to report that the levels found in Lake Michigan were very low, and that the water treatment process that removes these contaminants from the finished water does not release the contaminants to the Sanitary District.