



SEPTIC SERVICE



19604 - 67th Avenue N.E.
 Arlington, WA 98223-8769
 TEL: (360) 435-5531 - 1-800-659-1941
 FAX: (360) 425-8575

7093

4231

SEPTIC CLEANING, PUMP SALES, SERVICE & INSTALLATION

CUSTOMER NAME Jan Tucker COMPLETION DATE 4.9.24
 ADDRESS 12225 3rd Ave NE PO # _____
 CITY Tulalip STATE WA ZIP 98271 PHONE NUMBER (206) 920-5242
 BILLING ADDRESS _____

DESCRIPTION

TANK LOCATION: FRONT BACK TANK LOCATOR USED: YES NO SIDE: RIGHT LEFT _____ FT & N S E W
 TANK(S) RISERED: YES NO SEPTIC TANK SIZE 1000 GAL.: SINGLE DBL. COMP. CUST. INITIALS (if Refused) _____
 1ST COMPARTMENT: SCUM 12" /SLUDGE 4" 2ND COMPARTMENT: SCUM 1" /SLUDGE 2"
 PUMP SYSTEM: YES NO PUMP TANK SIZE: N/A GAL.
 PUMP TANK PUMPED: YES REFUSED CUST. INITIALS (if Refused) _____
 INLET & BAFFLES ARE CLEAR: YES NO FILTER CLEANED: YES NO N/A
 DRAINFIELD APPEARS TO BE IN WORKING CONDITION AT THIS TIME: YES NO (IF NO EXPLAIN IN COMMENTS)
 RME REPORT COMPLETED: YES NO
 MISC. WORK: DRAINFIELD JET-VAC MAINLINE CLEANING PUMP/FLOAT REPLACEMENT RISER/LID INSTALLATION

COMMENTS

PRICE

AMOUNT

[Handwritten signature]

Septic Pumping

260⁰⁰

Extra Gallonage

Waste Disposal

300⁰⁰

Truck Time/Labor

Inspection Fee

90⁰⁰

In consideration of delivery by Cuz Concrete Products, Inc. of the materials and services within the boundaries of the premises shown, purchaser releases Cuz Concrete Products, Inc. and agrees to hold it harmless from any claim arising out of any delivery by Cuz Concrete Products, Inc. whether due to -negligence or otherwise. ALL CLAIMS FOR ALLOWANCES MUST BE MADE IMMEDIATELY UPON RECEIPT OF GOODS AND SERVICES. ALL CLAIMS AND RETURNED GOODS MUST BE ACCOMPANIED BY THIS BILL. BALANCE DUE BY 10TH OF THE MONTH FOLLOWING BILLING. SERVICE CHARGE OF 1% PER MONTH (APR 18%) APPLIED ON OUTSTANDING BALANCE LESS CREDITS. ALL COLLECTION COSTS INCLUDING ATTORNEY FEES SHALL BE BORNE BY PURCHASER.

Sub Total

650⁰⁰

Tax

59.¹⁵

Total

709.¹⁵

HOLD HARMLESS AGREEMENT

1. THE UNDERSIGNED, AGREE TO HOLD CUZ CONCRETE PROD. INC. DBA CUZ SEPTIC HARMLESS FOR ANY OR ALL COVERAGE DONE FROM WORK REQUESTED BY MYSELF OR MY AGENT, WHETHER INCIDENTAL OR THE ACTUAL WORK PREFERRED.
2. THAT I AGREE TO PAY FOR ANY TOOLS OR MACHINERY WHICH CANNOT BE RETRIEVED AND OR THE COST OF RETRIEVAL OF SAME.
3. THAT I AGREE TO PAY FOR ANY SUBCONTRACTOR OR CONTRACTOR HIRED TO REPAIR ANY DAMAGES INCIDENTAL TO WORK BEING PERFORMED BY CUZ CONCRETE PRODUCTS INC.

SIGNATURE: _____

DATE: _____

SEPTIC TANK VISUAL / OPERATIONAL REPORT

CUZ

SEPTIC SERVICE

19604 - 67th Ave NE Arlington, Wa. 98223
Telephone (360) 435-5531

Customer Name Dan Pucker

Address 12225 3rd Ave NE
Federalip, WA 98271

Phone No. (206) 520-5242 Fax No. _____

Technician's Name Jeremy Lehman

Date of Service 8/9/24

Job Name / Address _____

Is residence occupied? Yes No _____ If no how long _____ Date last pumped? N/A

No. of people in home 6 No. of bedrooms 4 Garbage disposal? Yes No _____

SEPTIC TANK

Septic tank size 1000 gallon Compartments: Single _____ Double
Overall condition of septic tank: Good Poor _____ Comment _____

BAFFLES

Obstruction/build-up in inlet baffle? Yes _____ No _____ Comment _____
Condition of inlet baffle? Good Poor _____ Comment _____
Condition of center baffle? Good Poor _____ Comment _____
Condition of outlet baffle? Good Poor _____ Comment _____
Type of outlet baffle? Regular _____ Screened _____ Filtered

SEWAGE / EFFLUENT

Depth of floating mat in first compartment? 12 inches. Second compartment? 1 inches.
Depth of accumulated sludge in the first compartment? 4 inches. Second compartment? 2 inches.
Is effluent running back into tank? Yes _____ No Comment _____
Is there evidence of effluent surfacing in yard? Yes _____ No Comment _____
Is there evidence the septic tank for any reason, might have backed up at some time? Yes _____ No
If yes explain. _____

PUMP TANK / PUMP

Does system include a pump? Yes _____ No
Pump tank size _____ gallons.
Depth of accumulated sludge in pump tank? _____ inches. Pump tank pumped? Yes _____ No _____
Depth of flooding in pump tank from bottom of lid to water line? _____ inches.
Is there evidence the effluent level in the pump tank for any reason, might have been at a level higher than what the float switch is set? Yes _____ No _____
If yes explain. _____
Condition of pump? Working? Yes _____ No Comment _____
Condition of alarm? Working? Yes _____ No _____ Comment _____
System appears to be functioning at this time? Yes No _____
If no explain. _____

The results of this report are based solely on a visual inspection of the septic tank and/or pump tank and those accessories mentioned contained therein. Cuz Concrete Products Inc. will not be responsible for any attempt to interpret report results for use in determining the condition of the drainfield of this system. Any attempt by others will be at their own risk.