

Simple design process.**a) Determine Design Current I_b**

Triton T80 Pro Fit Electric Shower - 10.5kW SP8001PF



Design Current (Single phase)

$$I_b = \frac{P}{V \times \cos\phi}$$

$$I_b = \frac{10.5 \text{ kW}}{230V} = 45.65A$$

**Can I apply diversity?**

OSG Table A2 Pg 137

6 Water heaters (thermostatically controlled)	No diversity allowable [†]
---	-------------------------------------

For an individual household installation **not allowed.** ❌**b) Determine rating and type of overcurrent protective consider additional protection if required.**Nominal Rating of Device I_n $I_n \geq I_b \geq I_z$ (This gives compliance with **BS7671 (2022)** Regulation 433.1.1 **OVERLOAD PROTECTION**)

Manufacturer's Instructions require a 30mA RCD.

BS 7671 (2022) Pg 243 **OSG** Pg 87 7.2.5 (d)**Regulation 701.411.3.3** requires additional protection via a **30mA RCD**.**Hager VM144** consumer unit with 100 A Main Switch

ADB150

Hager RCBO available and compatible with existing consumer unit. ✓ RCBO Electronic 1M 1P 10kA B-50A 30mA AC Class

Fault protection provided by the MCB part - **Type B** (no inrush current to consider)**OSG** Table 7.2.7 (ii) Pg 90Additional protection provided by the RCD - **Type AC**  is suitable as the shower load current has no DC components. **BS 7671 (2022)** Pg 157

Selected a BS EN 61009-1 Type B 50A.

BS 7671 (2022) Table 41.3 Pg 68 / **OSG** Table B6 Pg 145 $I_n \geq I_b$ 50 ≥ 45.65 ✓

c) Determine Installation or Reference Method

Under floors Reference Method **C**

Inside trunking Reference Method **B**

Inside loft under **<100mm** of insulation touching on one side Reference Method **100**

Which method will have the worst effect on the current carrying capacity of the cable?


Inside the loft!!



BS7671 (2022) Table 4A2 Pg 437

OSG Table 7.1(iv) Pg 85

Reference Method **100** ✓



d) De-Rating Factors to consider.

Ambient Temperature C_a

BS 7671 (2022) Appendix 4 Table 4B1 Pg 441

OSG Appendix F Table F1 Pg 168

$C_a = 1$ (70°C thermoplastic cable in 30°C Ambient temp)



Grouping C_g

BS 7671 (2022) Appendix 4 Table 4C1 Pg 443


OSG Appendix F Table F3 Pg 170

$C_g = 0.80$ (Circuit enclosed with 1 other circuit so 2 circuit total)

C_i : N/A

C_f : N/A

C_c : N/A




e) Determine CSA of cable required.

BS 7671 (2022) Appendix 4 Pg 425

OSG Appendix F Pg 167

$$I_z = \frac{In}{Ca \times Cg}$$

$$I_z = \frac{50A}{0.80 \times 1} = 62.5 \text{ A}$$



A cable needs to be selected that can carry at least **62.5 Amps**.

BS 7671 (2022) Appendix 4 Table 4D5 Pg 456

OSG Appendix F Table F6 Pg 177

16.0mm² conductor which has an $I_t = 57 \text{ A}$ ❌

This is the largest CSA available but does not comply with **Regulation 433.1.1 BS 7671 (2022)**

$I_t \geq I_z$ (This gives compliance with **BS7671 (2022) Regulation 433.1.1**)

$57 \geq 62.5$ ❌

Possible solution

Change cable type and increase CSA?



Or have we overlooked something?

BS 7671 (2022) Appendix 4 Pg 425

Alternatively, it may be obtained from the following formulae, provided the circuits of the group are not liable to simultaneous overload.

$$I_z = \frac{Ib}{Ca \times Cg}$$

$$I_z = \frac{45.65A}{1 \times 0.8} = 57 \text{ A}$$

We can now select the **16.0mm²** conductor as it has a current carrying capacity of 57 A.

Therefore

$I_t \geq I_z$ (This gives compliance with **BS7671 (2022) Regulation 433.1.1**)

$57 \geq 57$ ✅

f) Calculate Volt Drop:

BS 7671 (2022) Appendix 4 (6) Pg 428 Table 4AB Pg 430

OSG Appendix F Pg 168

$$\text{Volt drop} = \frac{\text{mV/A/m} \times \text{Ib} \times \text{Length}}{1000}$$

mV/A/m = BS 7671 (2022) Table 4D5 Pg 456 (column 9) = 2.8 mV/A/m

mV/A/m = OSG Table F6 Pg 177 (column 8) 2.8 mV/A/m

$$\text{Calculated volt drop} = \frac{2.8 \times 45.65 \times 78\text{m}}{1000} = 3.3 \text{ V} \quad \checkmark$$

Max Volt drop is stated BS 7671 (2022) Table 4AB.

$$\text{For Power circuits max volt drop} = 5\% \text{ of } U_o \text{ (230V)} \quad \text{Max volt drop} = \frac{230 \times 5}{100} = 11.5 \text{ V}$$

$$3.3 \text{ V} \leq 11.5 \text{ V} \quad \checkmark$$

Our calculated Volt drop is less than maximum allowed so is **acceptable**. \checkmark **g) Determine Max Disconnection time for this circuit. (Shock Protection)**

ADS chosen protective measure from Chapter 41 BS 7671 (2022)

BS 7671 (2022) Pg 64 / 65

Regulation 411.3.2.3

Maximum disconnections time stated in Table 41.1 shall be applied to final circuits with a rated current not exceeding:

- (i) 63 A with one or more socket-outlets
- (ii) 32 A supplying fixed connected current-using equipment.

In a TN-C-S system, a disconnection time **not exceeding 5 s** is permitted for a distribution circuit and for a **circuit not covered by Regulation 411.3.2.2**

50A final circuit TN-C-S earthing system.


Therefore, maximum disconnection time of **5 Seconds**. \checkmark

OSG Appendix B Pg 139

- h) Determine maximum Earth fault loop impedance value (Zs) to achieve the 5 second maximum disconnection time.

BS 7671 (2022)

OSG Appendix I Pg 217



$$Z_s = Z_e + (R_1 + R_2)$$

Line conductor = 16.00 mm²

CPC conductor = 6.00 mm²

$$R_1 + R_2 = \frac{m\Omega/m \times Multiplier \times Length}{1000}$$

Values for mΩ/m: **OSG Table I1 Pg 218 = 4.23 mΩ/m**
 Temperature multiplier values: **OSG Table I3 Pg 220 = 1.20**
 (70°C Thermoplastic cable bunched with the live conductors)

16	6	4.23
Incorporated in a cable or bunched (NOTE 2)		1.20

$$R_1 + R_2 = \frac{4.23 \text{ m}\Omega/m \times 1.2 \times 78 \text{ m}}{1000} = 0.3959 \Omega \quad R_1 + R_2 = 0.40 \Omega$$

$$Z_s = 0.14 \Omega + 0.40 \Omega = \mathbf{0.54 \Omega}$$

- i) Verify maximum earth fault loop impedance value as stated in **BS 7671 (2022)** to ensure 5 second disconnection time.

BS 7671 (2022) Table 41.3 Pg 68 max Zs for 50A Type B BS EN 61009 RCBO = 0.87 Ω ✓

Our calculated Zs value is less than the maximum allowed and therefore acceptable.

- j) **Determine the Fault current. (If)**


OSG Appendix I Pg 217

$$I_f = \frac{U_o}{Z_s} = \frac{230V}{0.54\Omega} = \mathbf{425.92 \text{ A}}$$

- k) **Confirm the disconnection time of device selected.**

BS EN 61009-1 Type B RCBO

BS 7671 (2022) Appendix 3 Fig 3A4 Pg 417



A minimum of 250 A is required to disconnection between 0.1s to 5seconds.

Therefore 425.92 A will achieve our maximum disconnection time of 5 seconds. (0.1s actual) ✓

- l) Is the CSA of the CPC acceptable within our selected cable?

16.0mm² Line and Neutral conductors + 6.0mm² CPC



BS 7671 (2022) Pg 199

Regulation 543.1.3 states to calculate minimum CSA of the CPC required:

$$S = \frac{\sqrt{I^2 t}}{k}$$

$$I = 425.92 \text{ A}$$

$$t = \text{Table 3A4 Appendix 3 BS 7671 (2022) Pg 417} = 0.1\text{s}$$

$$k = \text{Table 54.3 Pg 200 BS 7671 (2022)} (70^\circ\text{C Thermoplastic Copper conductor}) = 115$$

$$S = \frac{\sqrt{425.92\text{A}^2 \times 0.1\text{s}}}{115} = 1.17 \text{ mm}^2 \quad \checkmark$$

6.0mm² CPC is within our selected cable which has a larger CSA than the minimum calculated 1.17 mm² and therefore an **acceptable CSA**. \checkmark

Summary

Our chosen cable CSA of 16.0mm² will comply fully with the relevant parts of BS 7671 (2022).



Could this circuit be designed and installed differently?



