



Title	Waltham College Training Booths
Project no.	
Operation scenario	
Client	Waltham College
Date	14/10/2021
Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Content

1. Main supply	
1.1. Supply	1
2. Maximum demand	
2.2. Maximum demand Supply	2
3. Circuits schedule	
3.1. SB1-Sub-Main Chamber	3
3.2. DB1-Current DB	4
3.3. DB2-Glasgow Switch	5
3.4. DB3	6
4. Circuits schedule with incomers	
4.1. SB1-Sub-Main Chamber	9
4.2. DB1-Current DB	10
4.3. DB2-Glasgow Switch	11
4.4. DB3	12
5. Circuits schedule (simple)	
5.1. SB1-Sub-Main Chamber	15
5.2. DB1-Current DB	16
5.3. DB2-Glasgow Switch	17
5.4. DB3	18
6. Boards schedule	
6.1	20
7. BTS Tap-off schedule	
8. Lighting columns schedule	
9. Cables schedule	
9.1. SB1-Sub-Main Chamber	21
10. Brief calculations	
10.1. SB1-Sub-Main Chamber	23
10.2. DB1-Current DB	24
10.3. DB2-Glasgow Switch	25
10.4. DB3	26
11. Voltage drop analysis	
11.1. SB1-Sub-Main Chamber	28
11.2. DB1-Current DB	29
11.3. DB2-Glasgow Switch	30
11.4. DB3	31
12. Connected loads analysis	
12.1. Connected loads analysis	33
13. Load densities	
14. Analytical calculations	

14.1. SB1-Sub-Main Chamber	35
14.2. DB1-Current DB	36
14.3. DB2-Glasgow Switch	37
14.4. DB3	38
15. Zs - Earth fault loop impedance	
15.1. SB1-Sub-Main Chamber	57
15.2. DB1-Current DB	58
15.3. DB2-Glasgow Switch	59
15.4. DB3	60
16. Warnings	
16.1. SB1-Sub-Main Chamber	63
16.2. DB1-Current DB	64
16.3. DB2-Glasgow Switch	65
16.4. DB3	66
17. Harmonic assessment	
17.1	69
18. IT System Touch Voltage	
18.1	70
19. Equipment Type	
19.1	71
20. Bill of quantities	
20.1. Bill of quantities	72
21. Selectivity study results	
21.1. Selectivity study results	73
22. Selectivity study analysis	
22.1. SB1-Sub-Main Chamber	75
22.2. DB1-Current DB	76
22.3. DB2-Glasgow Switch	77
22.4. DB3	78
23. Current limiting	
23.1. SB1-Sub-Main Chamber	96
24. Protective devices commissioning	
24.1. SB1-Sub-Main Chamber	97
24.2. DB1-Current DB	98
24.3. DB2-Glasgow Switch	99
24.4. DB3	100
25. Schematic diagrams	
25.1. Main	107
26. Boards single line diagrams	
26.1. SB1-Sub-Main Chamber	108
26.2. DB1-Current DB	109
26.3. DB2-Glasgow Switch	110

Main supply report : Supply

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

Supply details	
Description	Supply
Supply method	User defined source @500kVA
Phase/Voltage	Three-phase 400/230V 50Hz
Earthing system	TN-S
Voltage drop limit	Public supply: Lighting 3%, other uses 5%

Prospective symmetrical 3Ph fault	
Isc-3ph (kA)	11.98
Zp-p (Ω)	0.0192
cos φ	0.23

Prospective Ph to N fault	
Isc-1ph (kA)	0.61
Zp-n (Ω)	0.38
cos φ	0.23

Prospective earth fault	
Ief (kA)	0.61
Ze (Ω)	0.3803

Earthing arrangements	
Earthing conductor (mm ²)	-
Earthing electrode resistance (Ω)	0
Main bonding conductor (mm ²)	25

Min/Max Fault levels							
Isc-max (kA)	11.98	Cmax	1	Isc-min (kA)	0.61	Cmin	1

Protection by supplier	Main protective device
Fuse 3P 80A/33kA	

Load calculations				
Phase	L1	L2	L3	N
Connected load (A)	26.09	26.09	26.09	
Diversified load (A)	26.09	26.09	26.09	
Spare load (A)	0 (0%)	0 (0%)	0 (0%)	
Design load (A) (Diversified + Spare)	26.09	26.09	26.09	0

Design load power calculations				
Phase	L1	L2	L3	Total
kVA	6	6	6	18
kW	6	6	6	18
kVAr	0	0	0	0
cos φ	1	1	1	-

Main conductor	4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu Length: 1m
-----------------------	---

Maximum demand report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

Supply details

Description	Supply
Supply method	User defined source @500kVA
Phase/Voltage	Three-phase 400/230V 50Hz
Earthing system	TN-S

Design load power calculations

Phase	L1	L2	L3	Total
kVA	6	6	6	18
kW	6	6	6	18
kVAr	0	0	0	0
cos φ	1	1	1	-

Load calculations

Phase	L1	L2	L3	N
Connected load (A)	26.09	26.09	26.09	
Diversified load (A)	26.09	26.09	26.09	
Spare load (A)	0 (0%)	0 (0%)	0 (0%)	
Design load (A) (Diversified + Spare)	26.09	26.09	26.09	0

Load power calculations per switchboard and distribution board

Description [Load type]	Power factor			Connected Load (A)				Connected Load (kVA)			
	Diversity factor			Diversified load (A)				Diversified load (kVA)			
Supply area (m ²)	Spare load (%)			Diversified + Spare load (A)				Diversified + Spare load (kVA)			
	L1	L2	L3	L1	L2	L3	N	L1	L2	L3	Total
SB1-Sub-Main Chamber [Sub-Circuits]	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	0	0	0	26.09	26.09	26.09	0	6	6	6	18
DB1-Current DB [Sub-Circuits]	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	0	0	0	26.09	26.09	26.09	0	6	6	6	18
DB2-Glasgow Switch [Sub-Circuits]	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	0	0	0	26.09	26.09	26.09	0	6	6	6	18
DB3 [Sub-Circuits]	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	1	1	1	26.09	26.09	26.09		6	6	6	18
N/A	0	0	0	26.09	26.09	26.09	0	6	6	6	18

Circuits schedule report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways	Spare load	Spare ways				
SB1-Sub-Main Chamber	400V AC	TP&N	3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0				
						L1	L2	L3	
Location:		Mounting:	Surface	Reference No.:		Connected load (A) Diversified load (A) Diversified+Spare load (A)	26.09	26.09	26.09
Connected from:	Supply	IP Rating:	IP 4X	Isolator Rating:			26.09	26.09	26.09
Zs (Ω):	0.3809	Board Rating (A):		Fault Rating (kA):			26.09	26.09	26.09

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
1	L1,L2,L3	DB1-Current DB	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09
L1,L2,L3	SB1-Sub-Main Chamber		4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu Length: 1m		1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09

Circuits schedule report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways	Spare load	Spare ways	Empty ways			
DB1-Current DB	400V AC	TP&N	3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0	1Ph: 0 (0%)			
						L1	L2	L3	
Location:		Mounting:	Surface	Reference No.:		Connected load (A) Diversified load (A) Diversified+Spare load (A)	26.09	26.09	26.09
Connected from:	SB1	IP Rating:	IP 4X	Isolator Rating:	125				
Zs (Ω):	0.3874	Board Rating (A):		Fault Rating (kA):					

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
1	L1,L2,L3	DB2-Glasgow Switch	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09
L1,L2,L3		DB1-Current DB	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09

Circuits schedule report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways	Spare load	Spare ways	Empty ways			
DB2-Glasgow Switch	400V AC	TP&N	3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0	1Ph: 0 (0%)			
						L1	L2	L3	
Location:		Mounting:	Surface	Reference No.:		Connected load (A) Diversified load (A) Diversified+Spare load (A)	26.09	26.09	26.09
Connected from:	DB1	IP Rating:	IP 4X	Isolator Rating:			26.09	26.09	26.09
Zs (Ω):	0.3944	Board Rating (A):		Fault Rating (kA):			26.09	26.09	26.09

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
1	L1,L2,L3	DB3	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09
L1,L2,L3	DB2-Glasgow Switch	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	1	1	1	26.09	26.09	26.09	
				1	1	1	26.09	26.09	26.09	
				0	0	0	26.09	26.09	26.09	

Circuits schedule report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways	Spare load	Spare ways	Empty ways		
DB3	400V AC	TP&N	3Ph: 10 / 1Ph: 30	0%	3Ph: 3 , 1Ph: 0	1Ph: 0 (0%)		
						L1	L2	L3
Location:		Mounting:	Surface	Reference No.:	Connected load (A) Diversified load (A) Diversified+Spare load (A)	26.09	26.09	26.09
Connected from:	DB2	IP Rating:	IP 4X	Isolator Rating:		26.09	26.09	26.09
Zs (Ω):	0.3976	Board Rating (A):		Fault Rating (kA):		26.09	26.09	26.09

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
1	L1,L2,L3	SPD	16mm ²	MCB C 3P 6A/10kA Generic BS EN 60898 10kA MCB Type C						
2	L1	FC1-Booth 1	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
2	L2	FC1-Booth 2	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
2	L3	FC1-Booth 3	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
3	L1	FC1-Booth 4	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
3	L2	FC1-Booth 5	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
3	L3	FC1-Booth 6	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
4	L1	FC1-Booth 7	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		

Circuits schedule report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
4	L2	FC1-Booth 8	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
4	L3	FC1-Booth 9	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
5	L1	FC1-Booth 10	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
5	L2	FC1-Booth 11	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
5	L3	FC1-Booth 12	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
6	L1	FC1-Booth 13	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
6	L2	FC1-Booth 14	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
6	L3	FC1-Booth 15	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
7	L1	FC1-Booth 16	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
7	L2	FC1-Booth 17	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
7	L3	FC1-Booth 18	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35

Circuits schedule report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Protective devices	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)		
					L1	L2	L3	L1	L2	L3
8	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0 0	0 0 0	0 0 0
9	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0 0	0 0 0	0 0 0
10	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0 0	0 0 0	0 0 0
L1,L2,L3	DB3		4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	1 1 0	1 1 0	1 1 0	26.09 26.09 26.09	26.09 26.09 26.09	26.09 26.09 26.09

Circuits schedule with incomers report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Served From: Supply / Fuse 3P 80A/33kA / Located:

Design Zs/MaxZs: 0.3809/0.4714Ω

Design Ief: 0.57

Design Isc: 11.59

Design Vd: 0.01% @ 230V / 400V = 0.02V / 0.04V

Earthing Arrangements: TN-S

Frequency: 50Hz

Design Voltage at input Terminals (AC): 229.98V / 399.96V

From description		Supply Conductors	Main Switch/Disconnect/Isolator	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)					
				L1	L2	L3	L1	L2	L3			
Incomer	Supply	4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu Length: 1m		1	1	1	26.09	26.09	26.09			
				1	1	1	26.09	26.09	26.09			
				0	0	0	26.09	26.09	26.09			
Way	Phase	Description	Conductor	Protective devices			L1	L2	L3			
1	L1,L2,L3	DB1-Current DB	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses			1	1	1	26.09	26.09	26.09
							1	1	1	26.09	26.09	26.09
							0	0	0	26.09	26.09	26.09

Circuits schedule with incomers report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Served From: SB1-Sub-Main Chamber / 1.L1,L2,L3 Fuse 3P 80A/80kA / Located:

Design Zs/MaxZs: 0.3874/0.542Ω

Design Ief: 0.56

Design Isc: 9.4

Design Vd: 0.1% @ 230V / 400V = 0.23V / 0.4V

Earthing Arrangements: TN-S

Frequency: 50Hz

Design Voltage at input Terminals (AC): 229.77V / 399.6V

From description		Supply Conductors	Main Switch/Disconnect/Isolator	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)					
				L1	L2	L3	L1	L2	L3			
Incomer	SB1-Sub-Main Chamber	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Isolator 125A	1	1	1	26.09	26.09	26.09			
				1	1	1	26.09	26.09	26.09			
				0	0	0	26.09	26.09	26.09			
Way	Phase	Description	Conductor	Protective devices			L1	L2	L3			
1	L1,L2,L3	DB2-Glasgow Switch	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA			1	1	1	26.09	26.09	26.09
				Generic BS EN 60898 10kA MCB Type C			1	1	1	26.09	26.09	26.09
							0	0	0	26.09	26.09	26.09

Circuits schedule with incomers report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Served From: DB1-Current DB / 1.L1,L2,L3 MCB C 3P 50A/10kA / Located:

Design Zs/MaxZs: 0.3944/0.437Ω

Design Ief: 0.55

Design Isc: 7.45

Design Vd: 0.21% @ 230V / 400V = 0.48V / 0.84V

Earthing Arrangements: TN-S

Frequency: 50Hz

Design Voltage at input Terminals (AC): 229.52V / 399.16V

From description		Supply Conductors	Main Switch/Disconnect/Isolator	Power factor			Connected load (A)			
				Diversity factor	3rd Harmonics %		Diversified load (A)	Diversified+Spare load (A)		
Way	Phase	Description	Conductor	Protective devices	L1	L2	L3	L1	L2	L3
Incomer		DB1-Current DB	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m		1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09
1	L1,L2,L3	DB3	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09

Circuits schedule with incomers report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Served From: DB2-Glasgow Switch / 1.L1,L2,L3 Fuse 3P 32A/80kA / Located:

Design Zs/MaxZs: 0.3976/1.7346Ω

Design Ief: 0.55

Design Isc: 6.8

Design Vd: 0.25% @ 230V / 400V = 0.57V / 1V

Earthing Arrangements: TN-S

Frequency: 50Hz

Design Voltage at input Terminals (AC): 229.43V / 399V

From description		Supply Conductors	Main Switch/Disconnect/Isolator	Power factor Diversity factor 3rd Harmonics %			Connected load (A) Diversified load (A) Diversified+Spare load (A)			
Way	Phase	Description	Conductor	Protective devices	L1	L2	L3	L1	L2	L3
Incomer		DB2-Glasgow Switch	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m		1	1	1	26.09	26.09	26.09
					1	1	1	26.09	26.09	26.09
					0	0	0	26.09	26.09	26.09
1	L1,L2,L3	SPD	16mm ²	MCB C 3P 6A/10kA Generic BS EN 60898 10kA MCB Type C						
2	L1	FC1-Booth 1	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1			4.35		
					1			4.35		
					0					
2	L2	FC1-Booth 2	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1			4.35	
						1			4.35	
						0				
2	L3	FC1-Booth 3	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1			4.35
							1			4.35
							0			
3	L1	FC1-Booth 4	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1			4.35		
					1			4.35		
					0					
3	L2	FC1-Booth 5	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1			4.35	
						1			4.35	
						0				
3	L3	FC1-Booth 6	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1			4.35
							1			4.35
							0			
4	L1	FC1-Booth 7	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1			4.35		
					1			4.35		
					0					
4	L2	FC1-Booth 8	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1			4.35	
						1			4.35	
						0				

Circuits schedule with incomers report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Protective devices	L1	L2	L3	L1	L2	L3
4	L3	FC1-Booth 9	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
5	L1	FC1-Booth 10	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
5	L2	FC1-Booth 11	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
5	L3	FC1-Booth 12	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
6	L1	FC1-Booth 13	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
6	L2	FC1-Booth 14	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
6	L3	FC1-Booth 15	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
7	L1	FC1-Booth 16	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	1 1 0			4.35 4.35		
7	L2	FC1-Booth 17	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C		1 1 0			4.35 4.35	
7	L3	FC1-Booth 18	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C			1 1 0			4.35 4.35
8	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0	0 0	0 0
9	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0	0 0	0 0

Circuits schedule with incomers report : DB3



Company UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Designer Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Protective devices	L1	L2	L3	L1	L2	L3
10	L1,L2,L3	Spare			1 1 0	1 1 0	1 1 0	0 0 0	0 0 0	0 0 0

Circuits schedule report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways
SB1-Sub-Main Chamber	400V AC	TP&N	3Ph: 1 / 1Ph: 3
Total circuit ways	Spare load	Spare ways	Empty ways
3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0	1Ph: 0 (0%)

Location:		Mounting:	Surface	Reference No.:	
Connected from:	Supply	IP Rating:	IP 4X	Isolator Rating:	
Zs (Ω):	0.3809	Board Rating (A):		Fault Rating (kA):	

Way	Phase	Description	Conductor	Protective devices	In(A)	Ib(A)
1	L1,L2,L3	DB1-Current DB	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	80	26.09

Circuits schedule report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways
DB1-Current DB	400V AC	TP&N	3Ph: 1 / 1Ph: 3
Total circuit ways	Spare load	Spare ways	Empty ways
3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0	1Ph: 0 (0%)

Location:		Mounting:	Surface	Reference No.:	
Connected from:	SB1	IP Rating:	IP 4X	Isolator Rating:	125
Zs (Ω):	0.3874	Board Rating (A):		Fault Rating (kA):	

Way	Phase	Description	Conductor	Protective devices	In(A)	Ib(A)
1	L1,L2,L3	DB2-Glasgow Switch	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	50	26.09

Circuits schedule report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Description	Voltage	Phase	Total circuit ways
DB2-Glasgow Switch	400V AC	TP&N	3Ph: 1 / 1Ph: 3
Total circuit ways	Spare load	Spare ways	Empty ways
3Ph: 1 / 1Ph: 3	0%	3Ph: 0 , 1Ph: 0	1Ph: 0 (0%)
Location:	Mounting:	Surface	Reference No.:
Connected from: DB1	IP Rating:	IP 4X	Isolator Rating:
Zs (Ω): 0.3944	Board Rating (A):		Fault Rating (kA):

Way	Phase	Description	Conductor	Protective devices	In(A)	Ib(A)
1	L1,L2,L3	DB3	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	32	26.09

Circuits schedule report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Description	Voltage	Phase	Total circuit ways
DB3	400V AC	TP&N	3Ph: 10 / 1Ph: 30
Total circuit ways	Spare load	Spare ways	Empty ways
3Ph: 10 / 1Ph: 30	0%	3Ph: 3 , 1Ph: 0	1Ph: 0 (0%)

Location:		Mounting:	Surface	Reference No.:	
Connected from:	DB2	IP Rating:	IP 4X	Isolator Rating:	
Zs (Ω):	0.3976	Board Rating (A):		Fault Rating (kA):	

Way	Phase	Description	Conductor	Protective devices	In(A)	Ib(A)
1	L1,L2,L3	SPD	16mm ²	MCB C 3P 6A/10kA Generic BS EN 60898 10kA MCB Type C		
2	L1	FC1-Booth 1	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
2	L2	FC1-Booth 2	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
2	L3	FC1-Booth 3	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
3	L1	FC1-Booth 4	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
3	L2	FC1-Booth 5	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
3	L3	FC1-Booth 6	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
4	L1	FC1-Booth 7	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
4	L2	FC1-Booth 8	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
4	L3	FC1-Booth 9	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
5	L1	FC1-Booth 10	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
5	L2	FC1-Booth 11	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
5	L3	FC1-Booth 12	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35

Circuits schedule report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Protective devices	In(A)	Ib(A)
6	L1	FC1-Booth 13	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
6	L2	FC1-Booth 14	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
6	L3	FC1-Booth 15	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
7	L1	FC1-Booth 16	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
7	L2	FC1-Booth 17	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
7	L3	FC1-Booth 18	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	32	4.35
8	L1,L2,L3	Spare				0
9	L1,L2,L3	Spare				0
10	L1,L2,L3	Spare				0

Boards schedule report



Company UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Designer Neil Bridgeman EngTech, MIET, CMgr FCMI

Board description	Supply from	Phase	Volts (V)	Conductor	Protective devices	Incomer devices
SB1-Sub-Main Chamber	Supply	TPN	400 / 230	4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu Length: 1m		
DB1-Current DB	SB1-Sub-Main Chamber	TPN	400 / 230	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	Isolator 125A
DB2-Glasgow Switch	DB1-Current DB	TPN	400 / 230	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	
DB3	DB2-Glasgow Switch	TPN	400 / 230	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	

Cables schedule report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Cable ID	Voltage	From	To	L (m)	Make-up	Type	Method	Classification
c-d-1	400V AC	Supply	SB1-Sub-Main Chamber	1	4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu	Single-core 70°C PVC non-armoured - Cu	Clipped direct flat touching	
c-d-1	400V AC	SB1-Sub-Main Chamber	DB1-Current DB	15	4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	Clipped direct	
c-d-2	400V AC	DB1-Current DB	DB2-Glasgow Switch	12	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	Clipped direct	
c-d-3	400V AC	DB2-Glasgow Switch	DB3	5	4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	Clipped direct	
c-f-1	230V AC	DB3	FC1-Booth 1	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 2	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 3	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 4	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 5	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 6	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 7	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 8	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 9	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 10	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 11	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 12	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 13	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 14	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	

Cables schedule report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Cable ID	Voltage	From	To	L (m)	Make-up	Type	Method	Classification
c-f-1	230V AC	DB3	FC1-Booth 15	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 16	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 17	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	
c-f-1	230V AC	DB3	FC1-Booth 18	20	3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	Multicore 70°C PVC armoured - Cu	On a perforated cable tray	

Brief calculations report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit			Current inequalities check		Breaking capacity check	Phase fault adiabatic check	CPC adiabatic check	Maximum Zs at earth fault	Earth fault disconnection time	Status
Way	Phase	Description	$I_b \leq I_n/I_r$ (A)	$\min I_z \leq I_t$ (A)	$I_{sc} \leq I_{cu}$ (kA)	$I^2t \leq k^2s^2$ ($\times 10^3$)	$cpc \geq \sqrt{(I^2t)/k}$ (mm ²)	$Z_s \leq \max Z_s$ (Ω)	$disc \leq \max$ (s)	
L1,L2,L3		SB1-Sub-Main Chamber	$26.09 \leq 80$	$80 \leq 104$	$11.79 \leq 33$	$511.7 \leq 8265.63$	$25 \geq 6.66$	$0.38 \leq 0.47$	$1.78 \leq 5$	OK

1	L1,L2,L3	DB1-Current DB	$26.09 \leq 80$	$80 \leq 125$	$11.59 \leq 80$	$361.31 \leq 16200.63$	$69.59 \geq 5.5$	$0.39 \leq 0.54$	$1.26 \leq 5$	OK
---	----------	----------------	-----------------	---------------	-----------------	------------------------	------------------	------------------	---------------	----

Brief calculations report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit			Current inequalities check		Breaking capacity check	Phase fault adiabatic check	CPC adiabatic check	Maximum Zs at earth fault	Earth fault disconnection time	Status
Way	Phase	Description	$I_b \leq I_n/I_r$ (A)	$\min I_z \leq I_t$ (A)	$I_{sc} \leq I_{cu}$ (kA)	$I^2t \leq k^2s^2$ ($\times 10^3$)	$cpc \geq \sqrt{(I^2t)/k}$ (mm ²)	$Z_s \leq \max Z_s$ (Ω)	$disc \leq \max$ (s)	
L1,L2,L3		DB1-Current DB	$26.09 \leq 80$	$80 \leq 125$	$11.59 \leq 80$	$361.31 \leq 16200.63$	$69.59 \geq 5.5$	$0.39 \leq 0.54$	$1.26 \leq 5$	OK

1	L1,L2,L3	DB2-Glasgow Switch	$26.09 \leq 50$	$50 \leq 102$	$9.4 \leq 10$	$3.37 \leq 8265.63$	$56.04 \geq 0.48$	$0.39 \leq 0.44$	$0.01 \leq 5$	OK
---	----------	--------------------	-----------------	---------------	---------------	---------------------	-------------------	------------------	---------------	----

Brief calculations report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit			Current inequalities check		Breaking capacity check	Phase fault adiabatic check	CPC adiabatic check	Maximum Zs at earth fault	Earth fault disconnection time	Status
Way	Phase	Description	$I_b \leq I_n/I_r$ (A)	$\min I_z \leq I_t$ (A)	$I_{sc} \leq I_{cu}$ (kA)	$I^2t \leq k^2s^2$ ($\times 10^3$)	$cpc \geq \sqrt{(I^2t)/k}$ (mm ²)	$Z_s \leq \max Z_s$ (Ω)	$disc \leq \max$ (s)	
L1,L2,L3		DB2-Glasgow Switch	$26.09 \leq 50$	$50 \leq 102$	$9.4 \leq 10$	$3.37 \leq 8265.63$	$56.04 \geq 0.48$	$0.39 \leq 0.44$	$0.01 \leq 5$	OK

1	L1,L2,L3	DB3	$26.09 \leq 32$	$32 \leq 102$	$7.45 \leq 80$	$3.42 \leq 8265.63$	$56.04 \geq 0.51$	$0.4 \leq 1.74$	$0.01 \leq 5$	OK
---	----------	-----	-----------------	---------------	----------------	---------------------	-------------------	-----------------	---------------	----

Brief calculations report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit			Current inequalities check		Breaking capacity check	Phase fault adiabatic check	CPC adiabatic check	Maximum Zs at earth fault	Earth fault disconnection time	Status
Way	Phase	Description	$I_b \leq I_n/I_r$ (A)	$\min I_z \leq I_t$ (A)	$I_{sc} \leq I_{cu}$ (kA)	$I^2t \leq k^2s^2$ (x10 ³)	$cpc \geq \sqrt{(I^2t)/k}$ (mm ²)	$Z_s \leq \max Z_s$ (Ω)	$disc \leq \max$ (s)	
L1,L2,L3		DB3	$26.09 \leq 32$	$32 \leq 102$	$7.45 \leq 80$	$3.42 \leq 8265.63$	$56.04 \geq 0.51$	$0.4 \leq 1.74$	$0.01 \leq 5$	OK

1	L1,L2,L3	SPD	-	-	-	-	-	-	-	-
2	L1	FC1-Booth 1	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
2	L2	FC1-Booth 2	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
2	L3	FC1-Booth 3	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
3	L1	FC1-Booth 4	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
3	L2	FC1-Booth 5	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
3	L3	FC1-Booth 6	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
4	L1	FC1-Booth 7	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
4	L2	FC1-Booth 8	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
4	L3	FC1-Booth 9	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
5	L1	FC1-Booth 10	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
5	L2	FC1-Booth 11	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
5	L3	FC1-Booth 12	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
6	L1	FC1-Booth 13	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
6	L2	FC1-Booth 14	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
6	L3	FC1-Booth 15	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
7	L1	FC1-Booth 16	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
7	L2	FC1-Booth 17	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
7	L3	FC1-Booth 18	$4.35 \leq 32$	$44.44 \leq 53$	$4.35 \leq 10$	$2.39 \leq 476.1$	$16.2 \geq 0.42$	$0.45 \leq 0.68$	$0.01 \leq 0.4$	OK
8	L1,L2,L3	Spare	-	-	-	-	-	-	-	-

Brief calculations report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit			Current inequalities check		Breaking capacity check	Phase fault adiabatic check	CPC adiabatic check	Maximum Zs at earth fault	Earth fault disconnection time	Status
Way	Phase	Description	$I_b \leq I_n/I_r$ (A)	$\min I_z \leq I_t$ (A)	$I_{sc} \leq I_{cu}$ (kA)	$I^2t \leq k^2s^2$ ($\times 10^3$)	$cpc \geq \sqrt{I^2t}/k$ (mm ²)	$Z_s \leq \max Z_s$ (Ω)	$disc \leq \max$ (s)	
L1,L2,L3		DB3	$26.09 \leq 32$	$32 \leq 102$	$7.45 \leq 80$	$3.42 \leq 8265.63$	$56.04 \geq 0.51$	$0.4 \leq 1.74$	$0.01 \leq 5$	OK

9	L1,L2,L3	Spare	-	-	-	-	-	-	-	-
10	L1,L2,L3	Spare	-	-	-	-	-	-	-	-

Voltage drop analysis report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Ib (A)	1Ph AC or DC @ Operating temperature		cosφ	Ct	Voltage drop (%) @ 230V				1%	2%	3%	4%	5%	6%	7%	8%	9%	10+	
					R mΩ/m	X mΩ/m			Supply	Circuit	Total	Max											
L1	SB1-Sub-Main Chamber		1m, 4x1Cx25mm ² + 1x25mm ² E Pvc70/S/Cu	26.09	0.87	0.14	1	0.88	0	0.01	0.01	5											
L2				26.09					0	0.01	0.01												
L3				26.09					0	0.01	0.01												
1	L1	DB1-Current DB	15m, 4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.64	0.08	1	0.87	0.01	0.09	0.1	5											
1	L2	DB1-Current DB	15m, 4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.64	0.08	1	0.87	0.01	0.09	0.1	5											
1	L3	DB1-Current DB	15m, 4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.64	0.08	1	0.87	0.01	0.09	0.1	5											

Voltage drop analysis report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Ib (A)	1Ph AC or DC @ Operating temperature		cosφ	Ct	Voltage drop (%) @ 230V													
					R mΩ/m	X mΩ/m			Supply	Circuit	Total	Max										
L1	DB1-Current DB	15m, 4Cx35mm ² + 1x35mm ² E(and armour) SwaPvc70/M/Cu	26.09	26.09	0.64	0.08	1	0.87	0.01	0.09	0.1	5	1%	2%	3%	4%	5%	6%	7%	8%	9%	10+
L2									0.01	0.09	0.1		1%	2%	3%	4%	5%	6%	7%	8%	9%	10+
L3									0.01	0.09	0.1		1%	2%	3%	4%	5%	6%	7%	8%	9%	10+
1	L1	DB2-Glasgow Switch	12m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.1	0.1	0.21	5	1%	2%	3%	4%	5%	6%	7%	8%	9%	10+
1	L2	DB2-Glasgow Switch	12m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.1	0.1	0.21	5	1%	2%	3%	4%	5%	6%	7%	8%	9%	10+
1	L3	DB2-Glasgow Switch	12m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.1	0.1	0.21	5	1%	2%	3%	4%	5%	6%	7%	8%	9%	10+

Voltage drop analysis report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Ib (A)	1Ph AC or DC @ Operating temperature		cosφ	Ct	Voltage drop (%) @ 230V				1%	2%	3%	4%	5%	6%	7%	8%	9%	10+	
					R mΩ/m	X mΩ/m			Supply	Circuit	Total	Max											
L1	DB2-Glasgow Switch	12m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.1	0.1	0.21	5												
L2			26.09					0.1	0.1	0.21													
L3			26.09					0.1	0.1	0.21													
1	L1	DB3	5m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.21	0.04	0.25	5											
1	L2	DB3	5m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.21	0.04	0.25	5											
1	L3	DB3	5m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.21	0.04	0.25	5											

Voltage drop analysis report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	lb (A)	1Ph AC or DC @ Operating temperature				Voltage drop (%) @ 230V				
					R mΩ/m	X mΩ/m	cosφ	Ct	Supply	Circuit	Total	Max	
L1	DB3	5m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	26.09	0.87	0.08	1	0.88	0.21	0.04	0.25	5	
L2									0.21	0.04	0.25		
L3									0.21	0.04	0.25		
1	L1	SPD	-	-	-	-	-	-	-	-	-	-	
1	L2	SPD	-	-	-	-	-	-	-	-	-	-	
1	L3	SPD	-	-	-	-	-	-	-	-	-	-	
2	L1	FC1-Booth 1	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
2	L2	FC1-Booth 2	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
2	L3	FC1-Booth 3	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
3	L1	FC1-Booth 4	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
3	L2	FC1-Booth 5	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
3	L3	FC1-Booth 6	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
4	L1	FC1-Booth 7	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
4	L2	FC1-Booth 8	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
4	L3	FC1-Booth 9	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
5	L1	FC1-Booth 10	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
5	L2	FC1-Booth 11	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
5	L3	FC1-Booth 12	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
6	L1	FC1-Booth 13	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
6	L2	FC1-Booth 14	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
6	L3	FC1-Booth 15	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	
7	L1	FC1-Booth 16	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5	

Voltage drop analysis report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Way	Phase	Description	Conductor	Ib (A)	1Ph AC or DC @ Operating temperature		cosφ	Ct	Voltage drop (%) @ 230V				1%	2%	3%	4%	5%	6%	7%	8%	9%	10+	
					R mΩ/m	X mΩ/m			Supply	Circuit	Total	Max											
L1	DB3		5m, 4Cx25mm ² + 1x25mm ² E(and armour) SwaPvc70/M/Cu	26.09	0.87	0.08	1	0.88	0.21	0.04	0.25	5											
L2				26.09					0.21	0.04	0.25												
L3				26.09					0.21	0.04	0.25												
7	L2	FC1-Booth 17	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5											
7	L3	FC1-Booth 18	20m, 3Cx6mm ² + E(cable core and armour) SwaPvc70/M/Cu	4.35	7.3	0	1	0.93	0.25	0.26	0.51	5											
8	L1	Spare	-	-	-	-	-	-	-	-	-	-											
8	L2	Spare	-	-	-	-	-	-	-	-	-	-											
8	L3	Spare	-	-	-	-	-	-	-	-	-	-											
9	L1	Spare	-	-	-	-	-	-	-	-	-	-											
9	L2	Spare	-	-	-	-	-	-	-	-	-	-											
9	L3	Spare	-	-	-	-	-	-	-	-	-	-											
10	L1	Spare	-	-	-	-	-	-	-	-	-	-											
10	L2	Spare	-	-	-	-	-	-	-	-	-	-											
10	L3	Spare	-	-	-	-	-	-	-	-	-	-											

Connected loads analysis report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Load types analysis for the whole installation

Connected Load Type	Circuits	Installation Points	Phase	L1 (kVA)	L2 (kVA)	L3 (kVA)	Connected kVA
Other circuit	18	18	SPN	6.00	6.00	6.00	18.00

Connected loads analysis report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Load types analysis for distribution circuit

Distribution Circuit Details	
Description	DB3
Voltage (V)	400 / 230
Phase	TPN
Max. Demand	26.09 A
Location	

Connected / Diversified Load				
	L1	L2	L3	Total
Connected kVA	6.00	6.00	6.00	18.00
Diversified kVA	6.00	6.00	6.00	18.00
Power factor	1	1	1	
Spare %	0			

Design Load Analysis				
	L1	L2	L3	Total / N
Amperes	26.09	26.09	26.09	0
kVA	6	6	6	18
kW	6	6	6	18
kVAr	0	0	0	0

Connected Load Type	Circuits	Installation Points	Phase	L1 (kVA)	L2 (kVA)	L3 (kVA)	Connected kVA
Other circuit	18	18	SPN	6.00	6.00	6.00	18.00

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	SB1-Sub-Main Chamber	Voltage / Phase	Three phase+N (400V and 230V) / L1,L2,L3	Cable ID	c-d-1
Supply from	Supply	Circuit type	Switch Board	Cable Classification	

Circuit design data							
Conductor type	Single-core 70°C thermoplastic insulated non-armoured, 4x1Cx25mm ² + 1x25mm ² E, Pvc70/S/Cu				Length (m)	1	
	Element	Copper (Cu)	Armour	No	Temp (°C)	Full loaded:70 / Actual:32.5	Reference
Installation method	Clipped direct flat touching - Reference method C			Correction factors	Ci:1 Cg:1 Ca:1 Ct:0.88 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30.					
Protective conductor C.P.C	Installation settings		Separate conductor				
	Separate conductor (mm²)	25	Other cpc (mm²)	0	Total equivalent to Cu (mm²)		25
Protective devices	Overcurrent		Generic, BS1361 fuses (from supply) Rating(A): 80			Icu / Ics	33kA / 33kA
	RCD/Earth fault device		No			mA	-

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
26.09	80	80	104	0.00088	0.00088	0.3803	0.0885

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	1	1	Current (A)	26.09	26.09	26.09	0	Source (%)	0	0	0
3rd Harmonics (%)	0	0	0	Load (kVA)	6	6	6	18	Circuit (%)	0.01	0.01	0.01
Diversity factor	1	1	1	Resistive (kW)	6	6	6	18	Total (%)	0.01	0.01	0.01
Spare (%)	0			Reactive (kVAr)	0	0	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.57	0.3809	0.4714	5	1.7836	6.66

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of Fuse (s)	Conductors withstand duration (s)
	11.98 (Limited:11.79)	11.59	0.6	1.4	22.68

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	DB1-Current DB	Voltage / Phase	Three phase+N (400V and 230V) / L1,L2,L3	Cable ID	c-d-1
Supply from	SB1-Sub-Main Chamber (Way 1)	Circuit type	Din Rail	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 4Cx35mm ² + 1x35mm ² E(and armour), SwaPvc70/M/Cu					Length (m)	15	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:31.7	Reference	BS/4D4
Installation method	Clipped direct - Reference method C				Correction factors	Ci:1 Cg:1 Ca:1 Ct:0.87 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30.						
Protective conductor C.P.C	Installation settings		Cable armour and separate conductor					
	Separate conductor (mm²)	35	Armour (mm²)	78	Total equivalent to Cu (mm²)		69.59	
Protective devices	Overcurrent		Generic, BS88 fuses Rating(A): 80				Icu / Ics	80kA / 80kA
	RCD/Earth fault device		No				mA	-

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
26.09	80	80	125	0.00961	0.00751	0.3809	0.0902

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	1	1	Current (A)	26.09	26.09	26.09	0	Source (%)	0.01	0.01	0.01
3rd Harmonics (%)	0	0	0	Load (kVA)	6	6	6	18	Circuit (%)	0.09	0.09	0.09
Diversity factor	1	1	1	Resistive (kW)	6	6	6	18	Total (%)	0.1	0.1	0.1
Spare (%)	0			Reactive (kVA_r)	0	0	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.56	0.3874	0.542	5	1.259	5.5

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of Fuse (s)	Conductors withstand duration (s)
	11.59	9.4	0.59	1.03	46.16

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	DB2-Glasgow Switch	Voltage / Phase	Three phase+N (400V and 230V) / L1,L2,L3	Cable ID	c-d-2
Supply from	DB1-Current DB (Way 1)	Circuit type	Din Rail	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 4Cx25mm ² + 1x25mm ² E(and armour), SwaPvc70/M/Cu					Length (m)	12	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:32.6	Reference	BS/4D4
Installation method	Clipped direct - Reference method C				Correction factors	Ci:1 Cg:1 Ca:1 Ct:0.88 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30.						
Protective conductor C.P.C	Installation settings		Cable armour and separate conductor					
	Separate conductor (mm²)	25	Armour (mm²)	70	Total equivalent to Cu (mm²)		56.04	
Protective devices	Overcurrent		Generic, BS EN 60898 10kA MCB Type C Rating(A): 50				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		No				mA	-

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
26.09	50	50	102	0.01044	0.00796	0.3874	0.1094

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	1	1	Current (A)	26.09	26.09	26.09	0	Source (%)	0.1	0.1	0.1
3rd Harmonics (%)	0	0	0	Load (kVA)	6	6	6	18	Circuit (%)	0.1	0.1	0.1
Diversity factor	1	1	1	Resistive (kW)	6	6	6	18	Total (%)	0.21	0.21	0.21
Spare (%)	0			Reactive (kVA_r)	0	0	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Zs(Ω) at fault conditions	Max Zs(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.55	0.3944	0.437	5	0.01	0.48

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of MCB (s)	Conductors withstand duration (s)
	9.4	7.45	0.58	0.01	24.55

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	DB3	Voltage / Phase	Three phase+N (400V and 230V) / L1,L2,L3	Cable ID	c-d-3
Supply from	DB2-Glasgow Switch (Way 1)	Circuit type	Din Rail	Cable Classification	

Circuit design data										
Conductor type								Length (m)	5	
Multicore 70°C thermoplastic insulated armoured, 4Cx25mm ² + 1x25mm ² E(and armour), SwaPvc70/M/Cu										
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:32.6		Reference	BS/4D4		
Installation method				Correction factors		Ci:1 Cg:1 Ca:1 Ct:0.88 Cf:1 Ch:1				
Clipped direct - Reference method C										
Settings		Ambient temperature (°C): 30.								
Protective conductor C.P.C		Installation settings								
		Cable armour and separate conductor								
		Separate conductor (mm²)	25	Armour (mm²)	70	Total equivalent to Cu (mm²)		56.04		
Protective devices		Overcurrent						Icu / Ics	80kA / 80kA	
		Generic, BS88 fuses Rating(A): 32								
		RCD/Earth fault device						mA	-	
		No								

Circuit calculations									
Currents (A)					Impedances (Ω) at operating temperature				
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t		Phase conductor Z₁	CPC Z₂	Earth external	Phase external	
26.09	32	32	102		0.00435	0.00332	0.3944	0.1302	

Load factors			L1	L2	L3	Design load		L1	L2	L3	N/Totals	Voltage drop		
Power factor			1	1	1	Current (A)		26.09	26.09	26.09	0	Source (%)		
3rd Harmonics (%)			0	0	0	Load (kVA)		6	6	6	18	Circuit (%)		
Diversity factor			1	1	1	Resistive (kW)		6	6	6	18	Total (%)		
Spare (%)			0			Reactive (kVA_r)		0	0	0	0	Limit		
											Public supply other uses:5%			

Earth Fault Calculations	Earth fault current(kA)	Zs(Ω) at fault conditions	Max Zs(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.55	0.3976	1.7346	5	0.01	0.51

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Let-through Energy of Fuse I² t (A² s) x 10³	Conductors withstand k² S² x 10³
	7.45	6.8	0.57	3.42	8265.63

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 1	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 2)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 2	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 2)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 3	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 2)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1	
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.					
Protective conductor C.P.C	Installation settings						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device					mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 4	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 3)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu				Length (m)	20	
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E			Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings Cable armour and integral conductor						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)					mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 5	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 3)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu				Length (m)	20	
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E			Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings Cable armour and integral conductor						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)					mA	30

Circuit calculations				Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external				
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389				

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 6	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 3)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu				Length (m)	20	
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E			Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings Cable armour and integral conductor						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)					mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 7	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 4)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL			
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI			

Circuit Description	FC1-Booth 8	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 4)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 9	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 4)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu				Length (m)	20	
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E			Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings Cable armour and integral conductor						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)					mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 10	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 5)	Circuit type	Other circuit	Cable Classification	

Circuit design data							
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu				Length (m)	20	
Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E			Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings Cable armour and integral conductor						
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2
Protective devices	Overcurrent Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32					Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)					mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 11	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 5)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 12	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 5)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 13	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 6)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 14	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 6)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 15	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 6)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 16	Voltage / Phase	Single phase+N (230V) / L1	Cable ID	c-f-1
Supply from	DB3 (Way 7)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	1	-	-	Current (A)	4.35	-	-	4.35	Source (%)	0.25	-	-
3rd Harmonics (%)	0	-	-	Load (kVA)	1	-	-	1	Circuit (%)	0.26	-	-
Diversity factor	1	-	-	Resistive (kW)	1	-	-	1	Total (%)	0.51	-	-
Spare (%)	-			Reactive (kVA_r)	0	-	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 17	Voltage / Phase	Single phase+N (230V) / L2	Cable ID	c-f-1
Supply from	DB3 (Way 7)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	1	-	Current (A)	-	4.35	-	4.35	Source (%)	-	0.25	-
3rd Harmonics (%)	-	0	-	Load (kVA)	-	1	-	1	Circuit (%)	-	0.26	-
Diversity factor	-	1	-	Resistive (kW)	-	1	-	1	Total (%)	-	0.51	-
Spare (%)	-			Reactive (kVA_r)	-	0	-	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Analytical calculations Report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL				
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI				

Circuit Description	FC1-Booth 18	Voltage / Phase	Single phase+N (230V) / L3	Cable ID	c-f-1
Supply from	DB3 (Way 7)	Circuit type	Other circuit	Cable Classification	

Circuit design data								
Conductor type	Multicore 70°C thermoplastic insulated armoured, 3Cx6mm ² + E(cable core and armour), SwaPvc70/M/Cu					Length (m)	20	
	Element	Copper (Cu)	Armour	Steel	Temp (°C)	Full loaded:70 / Actual:30.5	Reference	BS/4D4
Installation method	On a perforated cable tray - Reference method E				Correction factors	Ci:1 Cg:0.72 Ca:1 Ct:0.93 Cf:1 Ch:1		
	Settings	Ambient temperature (°C): 30. Grouped circuits: 18 with Simultaneous overload. Trays: 1. Cables/Tray: 18. Arrangement: Horizontal Touching.						
Protective conductor C.P.C	Installation settings		Cable armour and integral conductor					
	Integral conductor (mm²)	6	Armour (mm²)	23	Total equivalent to Cu (mm²)		16.2	
Protective devices	Overcurrent		Generic, BS EN 61009 10kA RCBO 30mA Type C Rating(A): 32				Icu / Ics	10kA / 7.5kA
	RCD/Earth fault device		RCBO, 32A. Touch voltage = 0.01V (Maximum = 50V)				mA	30

Circuit calculations							
Currents (A)				Impedances (Ω) at operating temperature			
Design current I_b	Device rating I_n	Minimum effective conductor capacity - min I_z	Tabulated conductor capacity I_t	Phase conductor Z₁	CPC Z₂	Earth external	Phase external
4.35	32	44.44	53	0.073	0.05043	0.3976	0.1389

Load factors	L1	L2	L3	Design load	L1	L2	L3	N/Totals	Voltage drop	L1	L2	L3
Power factor	-	-	1	Current (A)	-	-	4.35	4.35	Source (%)	-	-	0.25
3rd Harmonics (%)	-	-	0	Load (kVA)	-	-	1	1	Circuit (%)	-	-	0.26
Diversity factor	-	-	1	Resistive (kW)	-	-	1	1	Total (%)	-	-	0.51
Spare (%)	-			Reactive (kVA_r)	-	-	0	0	Limit	Public supply other uses:5%		

Earth Fault Calculations	Earth fault current(kA)	Z_s(Ω) at fault conditions	Max Z_s(Ω)	Max Disconnection Time (s)	Device Disconnection Time (s)	Min CPC (mm²)
	0.48	0.4536	0.6828	0.4	0.01	0.42

Phase Fault Calculations	Max at starting point (kA)	Max at end point (kA)	Min at end point (kA)	Disconnection time of RCBO (s)	Conductors withstand duration (s)
	4.35	1.35	0.49	0.01	1.99

Zs - Earth fault loop impedance report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time	Max Discon.	Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		SB1-Sub-Main Chamber	4x1Cx25mm ² 1x25mm ² E Pvc70/S/Cu Length: 1m		1.7836	5	0.38	0.31	0.47	0.38
1	L1,L2,L3	DB1-Current DB	4Cx35mm ² 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	1.259	5	0.39	0.31	0.54	0.43

Zs - Earth fault loop impedance report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time	Max Discon.	Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		DB1-Current DB	4Cx35mm ² 1x35mm ² E(and armour) SwaPvc70/M/Cu Length: 15m	Fuse 3P 80A/80kA Generic BS88 fuses	1.259	5	0.39	0.31	0.54	0.43
1	L1,L2,L3	DB2-Glasgow Switch	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	0.01	5	0.39	0.32	0.44	0.35

Zs - Earth fault loop impedance report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time	Max Discon.	Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		DB2-Glasgow Switch	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 12m	MCB C 3P 50A/10kA Generic BS EN 60898 10kA MCB Type C	0.01	5	0.39	0.32	0.44	0.35
1	L1,L2,L3	DB3	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	0.01	5	0.4	0.32	1.74	1.39

Zs - Earth fault loop impedance report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time	Max Discon.	Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		DB3	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	0.01	5	0.4	0.32	1.74	1.39
1	L1,L2,L3	SPD	16mm ²	MCB C 3P 6A/10kA Generic BS EN 60898 10kA MCB Type C	-	-	-	-	-	-
2	L1	FC1-Booth 1	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
2	L2	FC1-Booth 2	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
2	L3	FC1-Booth 3	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
3	L1	FC1-Booth 4	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
3	L2	FC1-Booth 5	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
3	L3	FC1-Booth 6	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
4	L1	FC1-Booth 7	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55

Zs - Earth fault loop impedance report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time		Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		DB3	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	0.01	5	0.4	0.32	1.74	1.39
4	L2	FC1-Booth 8	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
4	L3	FC1-Booth 9	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
5	L1	FC1-Booth 10	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
5	L2	FC1-Booth 11	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
5	L3	FC1-Booth 12	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
6	L1	FC1-Booth 13	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
6	L2	FC1-Booth 14	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
6	L3	FC1-Booth 15	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55

Zs - Earth fault loop impedance report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Uo - Nominal Line Voltage to Earth: 230V

Way	Phase	Description	Conductor	Protective devices	Discon. time	Max Discon.	Zs Calculated (Ω)		Max Zs Calculated (Ω)	
					sec	sec	Zs	Z x 0.8	max Zs	max Zs x 0.8
L1,L2,L3		DB3	4Cx25mm ² 1x25mm ² E(and armour) SwaPvc70/M/Cu Length: 5m	Fuse 3P 32A/80kA Generic BS88 fuses	0.01	5	0.4	0.32	1.74	1.39
7	L1	FC1-Booth 16	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
7	L2	FC1-Booth 17	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
7	L3	FC1-Booth 18	3Cx6mm ² E(cable core and armour) SwaPvc70/M/Cu Length: 20m	RCBO C 1P 30mA Class AC 32A/10kA Generic BS EN 61009 10kA RCBO 30mA Type C	0.01	0.4	0.45	0.36	0.68	0.55
8	L1,L2,L3	Spare	-		-	-	-	-	-	-
9	L1,L2,L3	Spare	-		-	-	-	-	-	-
10	L1,L2,L3	Spare	-		-	-	-	-	-	-

Warnings: SB1-Sub-Main Chamber

Description	Warnings	Notes
SB1-Sub-Main Chamber		
[1.L1,L2,L3] DB1-Current DB	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Warnings: DB1-Current DB

Description	Warnings	Notes
DB1-Current DB	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[1.L1,L2,L3] DB2-Glasgow Switch	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Warnings: DB2-Glasgow Switch

Description	Warnings	Notes
DB2-Glasgow Switch	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[1.L1,L2,L3] DB3	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Warnings: DB3

Description	Warnings	Notes
DB3	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[2.L1] FC1-Booth 1	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[2.L2] FC1-Booth 2	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[2.L3] FC1-Booth 3	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[3.L1] FC1-Booth 4	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[3.L2] FC1-Booth 5	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[3.L3] FC1-Booth 6	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Warnings: DB3

Description	Warnings	Notes
DB3	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[4.L1] FC1-Booth 7	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[4.L2] FC1-Booth 8	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[4.L3] FC1-Booth 9	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[5.L1] FC1-Booth 10	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[5.L2] FC1-Booth 11	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[5.L3] FC1-Booth 12	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Warnings: DB3

Description	Warnings	Notes
DB3	Important: 1) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[6.L1] FC1-Booth 13	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[6.L2] FC1-Booth 14	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[6.L3] FC1-Booth 15	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[7.L1] FC1-Booth 16	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[7.L2] FC1-Booth 17	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	
[7.L3] FC1-Booth 18	Important: 1) Energy-based selectivity error: Downstream Let-through energy > Upstream Fuse pre-arcing energy ($2.39 \times 10^3 \text{ A}^2\text{s} > 1.61 \times 10^3 \text{ A}^2\text{s}$) 2) Selectivity warning with upstream device. The protective device is not suitable for selective use during overcurrent	

Harmonic assessment report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Board description	Supply from	3rd Harmonic current (%)				3rd Harmonic current (A)			
		L1	L2	L3	N	L1	L2	L3	N
SB1-Sub-Main Chamber	Supply	0	0	0	0	0	0	0	0
DB1-Current DB	SB1-Sub-Main Chamber	0	0	0	0	0	0	0	0
DB2-Glasgow Switch	DB1-Current DB	0	0	0	0	0	0	0	0
DB3	DB2-Glasgow Switch	0	0	0	0	0	0	0	0

IT System Touch Voltage report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Board description	Supply from	Volts (V)	Conductor	Length (m)	IT 2nd Fault Touch Voltage Checks		
					Calculated (V)	RAxla Check (V)	Check Limit (V)


Equipment Type report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Equipment Type	Equipment Description	Supply from	Volts (V)	Conductor	Isc (kA)	In/Ir (A)	Voltage drop (%)	Zs (Ω)

Bill of quantities report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI	

Final circuits

Description	Part No.	Unit	Price/Unit	Quantity	Total price
[1Ph] Other circuit		Unit	0	18	0
[3Ph] SPD T2/In:20kA/Up:2.5kV		Unit	0	1	0
					0

Boards/Connections

Description	Part No.	Unit	Price/Unit	Quantity	Total price
[3Ph] Distribution Board - Din Rail (1 circuits)		Unit	0	2	0
[3Ph] Distribution Board - Din Rail (10 circuits)		Unit	0	1	0
[3Ph] Switch Board		Unit	0	1	0
					0

Cables/Busbar

Description	Part No.	Unit	Price/Unit	Quantity	Total price
Pvc70/S/Cu [Cores: 1] 25mm ²		Metres	0	22	0
Pvc70/S/Cu [Cores: 1] 35mm ²		Metres	0	15	0
SwaPvc70/M/Cu [Cores: 3] 6mm ²		Metres	0	360	0
SwaPvc70/M/Cu [Cores: 4] 25mm ²		Metres	0	17	0
SwaPvc70/M/Cu [Cores: 4] 35mm ²		Metres	0	15	0
					0

Protective devices

Description	Part No.	Unit	Price/Unit	Quantity	Total price
[1Ph] RCBO C 1P 30mA Class AC 32A/10kA		Unit	0	18	0
[3Ph] Fuse 3P 32A/80kA		Unit	0	1	0
[3Ph] Fuse 3P 80A/80kA		Unit	0	1	0
[3Ph] MCB C 3P 50A/10kA		Unit	0	1	0
[3Ph] MCB C 3P 6A/10kA		Unit	0	1	0
[3Ph] SWITCH AC21/125A		Unit	0	1	0
					0

Grand Total **0**

Selectivity study results report



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Upstream	Downstream	Over-current	Energy based	Earth fault
Supply Generic BS1361 fuses In (A): 80	DB1-Current DB Generic BS88 fuses In (A): 80	✘	N/A	N/A
DB1-Current DB Generic BS88 fuses In (A): 80	DB2-Glasgow Switch Generic BS EN 60898 10kA MCB Type C In (A): 50	✘	✓	N/A
DB2-Glasgow Switch Generic BS EN 60898 10kA MCB Type C In (A): 50	DB3 Generic BS88 fuses In (A): 32	✘	N/A	N/A
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 1 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 2 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 3 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 4 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 5 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 6 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 7 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 8 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 9 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 10 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 11 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 12 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 13 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 14 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 15 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓


Selectivity study results report





Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Upstream	Downstream	Over-current	Energy based	Earth fault
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 16 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 17 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓
DB3 Generic BS88 fuses In (A): 32	FC1-Booth 18 Generic BS EN 61009 10kA RCBO 30mA Type C In (A): 32	✘	✘	✓

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	Supply	DB1-Current DB
Manufacturer	Generic	Generic
Type	Fuses	Fuses
Family	BS1361 fuses	BS88 fuses
Rating	In (A): 80	In (A): 80
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
26.087	11.59	0.59	0.56


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	N/A	N/A

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB1-Current DB	DB2-Glasgow Switch
Manufacturer	Generic	Generic
Type	Fuses	Miniature Circuit Breakers
Family	BS88 fuses	BS EN 60898 10kA MCB Type C
Rating	In (A): 80	In (A): 50
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
26.087	9.4	0.58	0.55


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	OK - Downstream Let-through energy < Upstream Fuse pre-arcing energy (3.37 x 10 ³ A ² s < 14.09 x 10 ³ A ² s)	N/A

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB2-Glasgow Switch	DB3
Manufacturer	Generic	Generic
Type	Miniature Circuit Breakers	Fuses
Family	BS EN 60898 10kA MCB Type C	BS88 fuses
Rating	In (A): 50	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
26.087	7.45	0.57	0.55


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	N/A	N/A

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 1
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 2
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 3
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-



Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 4
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 5
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 6
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 7
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 8
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 9
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 10
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 11
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 12
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 13
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 14
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

Ib (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	Ief (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 15
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 16
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 17
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-




Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48


Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Selectivity study analysis report

Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI	

	Upstream	Downstream
Circuits	DB3	FC1-Booth 18
Manufacturer	Generic	Generic
Type	Fuses	RCBOs
Family	BS88 fuses	BS EN 61009 10kA RCBO 30mA Type C
Rating	In (A): 32	In (A): 32
RCD	-	-
Settings	-	-



Downstream Circuit Calculations

I _b (A)	Max Isc at the Device (kA)	Min Isc of the Circuit (kA)	I _{ef} (kA)
4.3478	4.35	0.49	0.48

Selectivity checks between Upstream and Downstream devices

Overcurrent	Energy based	Earth fault
Fail	Fail - Downstream Let-through energy > Upstream Fuse pre-arcing energy (2.39 x 10 ³ A ² s > 1.61 x 10 ³ A ² s)	OK

Current limiting report : SB1-Sub-Main Chamber



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Distribution circuit	Devices	Reinforced Breaking Capacity (kA)	Use Limiting	Non Limited Fault In (rms) (kA)	Limited Fault Out (Peak) (kA)	Limited Fault Out (rms) (kA)	Limited (1ph) Fault (rms) Out (kA)	Current limiting %
DB1-Current DB	Generic\BS88 fuses\80A	N/A	No	11.59	21.3	11.59	11.42	0%
DB2-Glasgow Switch	Generic\BS EN 60898 10kA MCB Type C\50A	N/A	No	9.4	14.96	9.4	7.45	0%
DB3	Generic\BS88 fuses\32A	N/A	No	7.45	11.85	7.45	4.99	0%

Protective devices commissioning report : SB1-Sub-Main Chamber



Company UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Designer Neil Bridgeman EngTech, MIET, CMgr FCI

Circuit	DB1-Current DB	Supply from	SB1-Sub-Main Chamber	Cable ID	c-d-1
Device	Generic\BS88 fuses				
Rating - In	80 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	80 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB1-Current DB



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Circuit	DB2-Glasgow Switch	Supply from	DB1-Current DB	Cable ID	c-d-2
Device	Generic\BS EN 60898 10kA MCB Type C				
Rating - In	50 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB2-Glasgow Switch



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Circuit	DB3	Supply from	DB2-Glasgow Switch	Cable ID	c-d-3
Device	Generic\BS88 fuses				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	80 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Circuit	SPD	Supply from	DB3	Cable ID	c-f-20
Device	Generic\BS EN 60898 10kA MCB Type C				
Rating - In	6 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 1	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 2	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCI

Circuit	FC1-Booth 3	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 4	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 5	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit	FC1-Booth 6	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 7	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 8	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit	FC1-Booth 9	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 10	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 11	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit	FC1-Booth 12	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 13	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 14	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit	FC1-Booth 15	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					

Circuit	FC1-Booth 16	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					


Circuit	FC1-Booth 17	Supply from	DB3	Cable ID	c-f-1
Device	Generic\BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					


Protective devices commissioning report : DB3



Company	UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL
Designer	Neil Bridgeman EngTech, MIET, CMgr FCMI

Circuit	FC1-Booth 18	Supply from	DB3	Cable ID	c-f-1
Device	Generic BS EN 61009 10kA RCBO 30mA Type C				
Rating - In	32 A	Adjusted Rating - Ir	N/A	Breaking Capacity - Icu	10 kA
RCD: No			Arc Fault Detection: No		
Device Settings					
N/A					
Commissioning Information					
Full name		Signature		Date	
Comments					





SB1-Sub-Main Chamber results:
 Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
 Isc(kA) Start point: 11.79 / End point: 11.59
 Zs(Ω): 0.38 / Max Zs(Ω): 0.47
 VD(%): 0.01 / Max VD(%): 5

Project description

Waltham College Training Booths

Design firm
 UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Client
 Waltham College

Details

SB1-Sub-Main Chamber

Design by
 Neil Bridgeman EngTech, MIET, CMgr FCMI

Revision by

Design date
 14/10/2021


Revision date

Drawing No.

Sheet No.

1





DB1-Current DB results:
 Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
 Isc(kA) Start point: 11.59 / End point: 9.4
 Zs(Ω): 0.39 / Max Zs(Ω): 0.54
 VD(%): 0.09 / Max VD(%): 5

Project description

Waltham College Training Booths

Design firm
 UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Client
 Waltham College

Details
 DB1-Current DB

Design by
 Neil Bridgeman EngTech, MIET, CMgr FCMI

Revision by

Design date
 14/10/2021


Revision date

Drawing No.

Sheet No.

1





DB2-Glasgow Switch results:
Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
Isc(kA) Start point: 9.4 / End point: 7.45
Zs(Ω): 0.39 / Max Zs(Ω): 0.44
VD(%): 0.1 / Max VD(%): 5

Project description

Waltham College Training Booths

Design firm
UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Client
Waltham College

Details

DB2-Glasgow Switch

Design by
Neil Bridgeman EngTech, MIET, CMgr FCMI

Revision by

Design date
14/10/2021


Revision date

Drawing No.

Sheet No.

1





From: DB2-Glasgow Switch
 Ib:26.09A/Isc:7.5kA
 Zs:0.39Ω/MaxZs:0.44Ω
 VD:0.2%/MaxVD:5%

FC1-Booth 1
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 2
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 3
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 4
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 5
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 6
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 7
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

FC1-Booth 8
 Ib:4.35A/Isc:1.4kA
 Zs:0.45Ω/MaxZs:0.68Ω
 VD:0.5%/MaxVD:5%

DB3 results:
 Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
 Isc(kA) Start point: 7.45 / End point: 6.8
 Zs(Ω): 0.4 / Max Zs(Ω): 1.73
 VD(%): 0.04 / Max VD(%): 5

Project description

Waltham College Training Booths

Design firm
 UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Client
 Waltham College

Details
 DB3

Design by
 Neil Bridgeman EngTech, MIET, CMgr FCMI

Revision by


Design date
 14/10/2021

Revision date

Drawing No.

Sheet No.
 1






DB3 results:
Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
Isc(kA) Start point: 7.45 / End point: 6.8
Zs(Ω): 0.4 / Max Zs(Ω): 1.73
VD(%): 0.04 / Max VD(%): 5

Project description Waltham College Training Booths	
Design firm UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL	
Client Waltham College	

Details DB3	
Design by Neil Bridgeman EngTech, MIET, CMgr FCMI	Drawing No.
Revision by	Sheet No.
Design date 14/10/2021	2
Revision date	





DB3 results:
 Load(A): L1: 26.09 , L2: 26.09 , L3: 26.09
 Isc(kA) Start point: 7.45 / End point: 6.8
 Zs(Ω): 0.4 / Max Zs(Ω): 1.73
 VD(%): 0.04 / Max VD(%): 5

Project description

Waltham College Training Booths

Design firm
 UKES Rail Ltd - Kingsbury House, Kingsbury Square, Melksham, Wiltshire, SN12 6HL

Client
 Waltham College

Details
 DB3

Design by
 Neil Bridgeman EngTech, MIET, CMgr FCMI

Design date
 14/10/2021

Drawing No.

Revision by

Revision date

Sheet No.

3

