



CERTIFICATE OF ANALYSIS

REPORTED TO Lakeshore Waterworks LTD

PO 24073 Government Street

Penticton, BC V2A 8L9

ATTENTION Mike Snair **WORK ORDER** 0012139

2020-01-31 10:00 / 6°C **PO NUMBER RECEIVED / TEMP**

REPORTED 2020-02-04 16:29 **PROJECT Drinking Water** No Number **PROJECT INFO COC NUMBER**

Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO 17025:2005 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks

(whew) is VERY important. We know that too.

We've Got Chemistry

It's simple. We figure the more you with our fun and working the more members; likely you are to give us continued opportunities to support you.

Ahead of the Curve

Through research, regulation knowledge, and instrumentation, are your analytical centre for the knowledge you technical BEFORE you need it, so you can stay up to date and in the know.

You know that the sample you collected after snowshoeing to site, digging 5 meters, and enjoy engaged team racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions

If you have any questions or concerns, please contact me at teamcaro@caro.ca

Authorized By:

Team CARO Client Service Representative

1-888-311-8846 | www.caro.ca



TEST RESULTS

REPORTED TO	Lakeshore Waterworks LTD	WORK ORDER	0012139
PROJECT	Drinking Water	REPORTED	2020-02-04 16:29

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
Apple Booster (0012139-01) Ma	trix: Water Sampled: 2020	0-01-30 15:30			
Microbiological Parameters					
Coliforms, Total	< 1	MAC = 0	1 CFU/100 mL	2020-01-31	
E. coli	< 1	MAC = 0	1 CFU/100 mL	2020-01-31	



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Lakeshore Waterworks LTD

PROJECT Drinking Water

WORK ORDER

0012139

REPORTED 2020-02-04 16:29

Analysis Description	Method Ref.	Technique	Location
Coliforms, Total in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	Kelowna
E. coli in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Glossary of Terms:

RL Reporting Limit (default)

Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors

CFU/100 mL Colony Forming Units per 100 millilitres

MAC Maximum Acceptable Concentration (health based)

SM Standard Methods for the Examination of Water and Wastewater, American Public Health Association

General Comments:

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued unless otherwise agreed to in writing. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted **red**. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do <u>not</u> take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager:teamcaro@caro.ca