

TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact EAST RIO HONDO WATER SUPPLY CORPORATION (956)748-2605.

#### Coliform Bacteria

| Maximum Contaminant Level/Goal | Total Coliform Maximum Contaminant Level | Highest No. of Positive | Fecal Coliform or E. Coli Maximum Contaminant Level | Total No. of Positive E. Coli or Fecal Coliform Samples | Violation | Likely Source of Contamination        |
|--------------------------------|--|-------------------------|---|---|-----------|---------------------------------------|
| 0                              | 1 positive monthly sample.               | 1                       |   | 0   | N         | Naturally present in the environment. |

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | #Sites Over AL | Units | Violation | Likely Source of Contamination   |
|-----------------|--------------|------|-------------------|-----------------|----------------|-------|-----------|--|
| Copper          | 08/29/2023   | 1.3  | 1.3               | 0.0375          | 0              | ppm   | N         | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems |
| Lead            | 08/29/2023   | 0    | 15                | 3.72            | 0              | ppb   | N         | Corrosion of household plumbing systems; Erosion of natural deposits.                                  |

We have developed a service line inventory. To access the inventory, please call or email Amy Lopez at (956)233-4021 Option 5, or email at [secretary@townofindianlake.com](mailto:secretary@townofindianlake.com).