

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for The Bluffs at Gull Lake

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During July 2025, we did not complete all monitoring or testing for total coliform bacteria, and therefore cannot be sure of the quality of your drinking water during that time.

What happened? What is being done?

We took our required monthly routine bacteriological sample on July 11, 2025. We were notified that the sample was total coliform positive on July 12, 2025. Within 24 hours, we are required to collect at least one groundwater source sample from each groundwater source in use at the time the total coliform positive sample was collected. However, we inadvertently missed monitoring our groundwater source within 24 hours. We returned to compliance on July 14, 2025, when we collected the required ground water source samples. All samples taken on July 14, 2025, were negative for total coliform bacteria. We are making efforts to ensure this does not happen again.

What should I do?

There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. The results of the sample were negative for bacteria. Even though public health was not impacted, as our customers you have a right to know what happened and what we did to correct the situation.

For more information, please contact: William Bresson_@ 269-731-4595

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by The Bluffs at Gull Lake.