



# CEI 0-16:2022-03 Annex Nbis.

## EXPOFIN SOLID POWER

### HV 261 KWH

**EXPOFIN srl** - E.S.Co (Energy Service Company)

Viale dell'Industria, 19 - 35129 Padova (PD)

P.IVA e C.F: 05419570287

Tel. +39 045 2457 812

Mail. [info@expofin.it](mailto:info@expofin.it) - [segreteria@expofin.it](mailto:segreteria@expofin.it)

PEC: [expofin@legalmail.it](mailto:expofin@legalmail.it)

Sito: [www.expofin.eu](http://www.expofin.eu)

## **DICHIARAZIONE SOSTITUTIVA DI ATTO NOTORIO AI SENSI DEL D.P.R. 28 DICEMBRE 2000 N. 445**

Dichiarazione di conformità alle prescrizioni della norma CEI 0-16:2022-03

*Declaration of compliance with the requirements of the CEI 0-16:2022-03*

Regola tecnica di riferimento per la connessione di utenti attivi e passivi alle reti MT e AT delle imprese distributrici di energia elettrica

*Reference technical rules for the connection of active and passive consumers to the MV and HV electrical networks of distribution companies.*

**Con la presente si attesta che il prodotto:**

*We hereby declare that the product*

**Famiglia di generatori – sistemi di accumulo**

*Family of generators – storage systems*

Definiti da:

*Defined by:*

**Expofin Solid Power HV 261**

**È CONFORME AGLI STANDARD**

**Is compliant to the standards**

**CEI 0-16:2022-03 Annex Nbis.**



## 1) Expofin Solid Power HV 261

### Informazioni tecniche e descrizione del prodotto:

Il sistema trova applicazione principalmente in scenari industriali e commerciali.

1. Il sistema di accumulo di energia comprende un rack per batterie, un armadio PCS, un armadio di distribuzione dell'energia, un sistema di distribuzione ausiliario, un sistema di aria condizionata, una scatola di controllo BMS e un sistema antincendio.

- La scatola di distribuzione ausiliaria serve a fornire l'alimentazione ausiliaria per l'intero sistema di controllo BMS e per il sistema di aria condizionata.
- L'armadio della batteria si collega al PCS tramite la convergenza della barra collettiva e il PCS converte la corrente continua generata dalle batterie di accumulo di energia in corrente alternata, necessaria per il collegamento alla rete tramite trasformatori e altri componenti o richiesta dal cliente.
- L'ESS è dotato di un controller locale nell'armadio di distribuzione dell'alimentazione e raccoglie informazioni sul funzionamento del PCS, della batteria e di altri dispositivi nel sistema. Inoltre carica le informazioni nel sistema di gestione dell'energia tramite lo sfondo e facilita la gestione del sistema di accumulo dell'energia.
- La funzione di controllo principale integrata nella scatola di controllo BMS.

### Technical Information and product description:

The system is mainly applied in industrial and commercial scenarios.

1. The Energy Storage System which include one battery rack, one PCS cabinet, one power distribution cabinet, auxiliary distribution system, Air-condition system, BMS control box and fire suppression system.

- The auxiliary distribution box is for providing the auxiliary power for whole BMS control system, air-condition system.
- Battery cabinet connects to PCS through the busbar convergence, and the PCS converts the DC power generated by the energy storage batteries into AC power which required for connecting to the grid through transformers and other components or required by client.
- The ESS is equipped with the local controller in Power distribution cabinet, it collects running information of the PCS, battery, and other devices in the system. And it uploads the information to the energy management system via the background and facilitate the management of energy storage system.
- The master control function integrated in BMS control box.



**DICHIARA**

che il sistema di accumulo energetico EXPOFIN SOLID POWER HV 261 è stato sottoposto a verifiche di conformità presso TÜV Rheinland secondo la norma CEI 0-16:2022-03 e successive varianti applicabili (V1, V2, V3, V3/EC, V3/EC2, V4), con esito positivo; che i relativi rapporti di prova originali sono conservati presso EXPOFIN S.r.l.; che la documentazione tecnica completa potrà essere resa disponibile, su richiesta motivata, ai soggetti aventi titolo, nel rispetto degli obblighi di riservatezza e delle condizioni d'uso dei documenti emessi dal laboratorio

## Test Report - Products

<b>Cliente:</b> <b>Client:</b>	EXPOFIN S.R.L. VIALE DELL'INDUSTRIA, N.19 – 35129 PADOVA (PD) – ITALY
<b>Elemento di prova:</b> <b>Test item:</b>	Energy Storage System (Integrated Battery Energy Storage System)
<b>Identificazione / Numero di tipo:</b> <b>Identification / Type no.:</b>	SOLID POWER HV 261
<b>Specifiche del test:</b> <b>Test specification:</b>	CEI 0-16:2022-03 CEI 0-16;V1:2022-11 CEI 0-16;V2:2023 CEI 0-16;V3:2024-01 CEI 0-16;V3/EC:2024 CEI 0-16;V3/EC2:2024 CEI 0-16;V4:2025-02
<b>Laboratorio di prova:</b> <b>Testing laboratory:</b>	TÜV Rheinland (Shanghai) Co., Ltd.
<b>Risultato del test*:</b> <b>Test result*:</b>	Pass/Approvato

**TEST REPORT**

**CEI 0-16:2022-03**  
**CEI 0-16; V1:2022-11**  
**CEI 0-16; V2:2023**  
**CEI 0-16; V3:2024-01**  
**CEI 0-16; V3/EC:2024**  
**CEI 0-16; V3/EC2:2024**  
**CEI 0-16; V4:2025-02**

**Norme tecniche di riferimento per il collegamento dei consumatori attivi e passivi alle reti elettriche HV e MV della società di distribuzione**

**/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company**

<p><b>Nome e indirizzo del richiedente:</b>  <b>Applicant's name and Address:</b></p>	<p>EXPOFIN S.R.L.          VIALE DELL'INDUSTRIA, N.19 – 35129 PADOVA (PD) – ITALY</p>
<p><b>Descrizione dell'elemento di prova:</b>  <b>Test item description:</b></p>	<p>Energy Storage System          (Integrated Battery Energy Storage System)</p>
<p><b>Marchio:</b>  <b>Trade Mark:</b></p>	
<p><b>Produttore:</b>  <b>Manufacturer:</b></p>	<p>EXPOFIN S.R.L.          VIALE DELL'INDUSTRIA, N.19 – 35129 PADOVA (PD) – ITALY</p>

**NORME DI RIFERIMENTO:**

Reference Standard:

**CEI 0-16:2022-03**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

**CEI 0-16; V1:2022-11**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

**CEI 0-16; V2:2023**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

**CEI 0-16;V3:2024-01/01.24**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

**CEI 0-16;V3/EC:2024**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

**CEI 0-16;V3/EC2:2024**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

## **CEI 0-16;V4:2025-02**

Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica

/Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company

The standard refers to the following standards:

### **IEC 61400-21:2008-08 Ed.2 (§. 7.4)**

Wind turbines

Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines

### **FGW TR3**

Technical Guidelines for Power Generating Units - Part 3

Determination of electrical characteristics of power generating units connected to MV, HV and EHV grids

<b>N.2 Elenco delle prove e condizioni di riferimento</b> <i>/Testing list at reference conditions</i>			
<b>Test</b>	<b>§</b>	<b>Ref. standard</b>	<b>Result</b>
<b>EMC</b>	<b>N.2</b>	CEI EN 61000-6-2 CEI EN 61000-6-3/-4	<b>Note<sup>1</sup></b>
Misure per la qualità della tensione <i>/Voltage quality measure</i>	<b>N.3</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica del campo di funzionamento in tensione e frequenza <i>/Voltage-frequency working range</i>	<b>N.4</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica delle condizioni di sincronizzazione e presa di carico <i>/synchronization and re-connection</i>	<b>N.5</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva <i>/Reactive power capability</i>	<b>N.6</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica dei requisiti costruttivi circa la regolazione di potenza attiva <i>/Active power regulation</i>	<b>N.7</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica della insensibilità agli abbassamenti di tensione <i>/LVRT capability</i>	<b>N.8</b>	CEI 0-16:2022-03	<b>N/A</b>
Verifica della insensibilità alle richiuse automatiche in discordanza di fase <i>/Check of the insensibility to the re-closures when phases are in discordanca</i>	<b>N.9</b>	CEI 0-16:2022-03	<b>N/A</b>
Misure per la qualità della tensione <i>/Voltage quality measure</i>	<b>Nbis.3</b>	CEI 0-16:2022-03	<b>P</b>
Verifica del campo di funzionamento in tensione e frequenza <i>/Voltage-frequency working range</i>	<b>Nbis.4</b>	CEI 0-16:2022-03	<b>P</b>
Verifica delle condizioni di sincronizzazione e presa di carico <i>/synchronization and re-connection</i>	<b>Nbis.5</b>	CEI 0-16:2022-03	<b>P</b>
Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva <i>/Reactive power capability</i>	<b>Nbis.6</b>	CEI 0-16:2022-03	<b>P</b>
Verifica dei requisiti costruttivi circa la regolazione di potenza attiva <i>/Active power regulation</i>	<b>Nbis.7</b>	CEI 0-16:2022-03	<b>P</b>
Verifica della insensibilità agli abbassamenti di tensione <i>/LVRT capability</i>	<b>Nbis.8</b>	CEI 0-16:2022-03	<b>P</b>
Verifica della insensibilità alle richiuse automatiche in discordanza di fase <i>/Check of the insensibility to the re-closures when phases are in discordanca</i>	<b>Nbis.9</b>	CEI 0-16:2022-03	<b>P</b>
Regolazioni del sistema di protezione dei gruppi generatori <i>/ System protection regulations for generators</i>	<b>Annex Z</b>	CEI 0-16:2022-03 CEI 0-16; V3:2024-01	<b>P</b>

**Sample 1: Hybrid inverter and battery are housed in a single cabinet, model name:**  
- Expofin Solid Power HV 261

C.2.4.7.4 Compatibilità Climatica / Climatic compatibility				
Test	§	Ref. standard	Result	Sample
<b>Compatibilità Climatica</b> /Climatic compatibility  <b>Storage conditions</b>	<b>C.2.4.7.4</b> <b>D.3.6</b> <b>E.4.5</b> (limit conditions)	Caldo secco / Dry heat test CEI EN 60068-2-2 (Test B) - Tab.12	PASS	1
		Umidità / Humidity test CEI EN 60068-2-78 (Test Cab) - Tab.12	PASS	1
		Freddo / Cold test CEI EN 60068-2-1 (Test A) - Tab.12	PASS	1
		Ciclo termico /changing temperature CEI EN 60068-2-14 - Tab.12	PASS	1
<b>Compatibilità Climatica</b> /Climatic compatibility  <b>Inverter in working conditions</b>	<b>C.2.4.7.4</b> <b>D.3.6</b> <b>E.4.5</b> (limit conditions)	Caldo secco / Dry heat test CEI EN 60068-2-2 (Test B) - Tab.12	PASS	1
		Umidità / Humidity test CEI EN 60068-2-78 (Test Cab) - Tab.12	PASS	1
		Freddo / Cold test CEI EN 60068-2-1 (Test A) - Tab.12	PASS	1
		Ciclo termico /changing temperature CEI EN 60068-2-14 - Tab.12	PASS	1

C.2.4.7.4 Prove di isolamento /Insulating test				
Test	Ref. CEI 0-21	Ref. standard	Result	Sample
<b>Tenuta ad impulso</b> /Pulse test	<b>C.2.4.7.4</b> <b>D.3.6</b> <b>E.4.5</b>	CEI EN 60255-5 Note <sup>1</sup>	PASS	1
<b>Rigidità Dielettrica</b> /Dielectric Strength		CEI EN 60255-5 Note <sup>1</sup>	PASS	1
<b>Resistenza di Isolamento</b> /insulation resistance		CEI EN 60255-5 Note <sup>1</sup>	PASS	1

<b>N.3 Misure per la qualità della tensione</b> <i>/Voltage quality measure</i>					
Test	§	Requirement	Ref. standard	Result	Sample
Misura di correnti armoniche <i>/Harmonics current</i>	N.3.1	N.3	CEI 0-16:2022-03	N/A	N/A
	7.4	--	IEC 61400-21	N/A	N/A
Misura di fluttuazioni di tensione dovute a manovre di sezionamento/separazione <i>/Voltage fluctuations caused by Switching operations</i>	N.3.2	N.3	CEI 0-16:2022-03	N/A	N/A
	7.3.4	--	IEC 61400-21	N/A	N/A
Misura di fluttuazioni di tensione (flicker) in condizioni di funzionamento continuo <i>/Voltage fluctuations (Flickers) during Continuous operation</i>	N.3.3	N.3	CEI 0-16:2022-03	N/A	N/A
	6.3.2 7.3.3	--	IEC 61400-21	N/A	N/A

<b>N.4 Verifica del campo di funzionamento in tensione e frequenza</b> <i>/Voltage-frequency working range</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Prove a piena potenza su rete simulata <i>/full power test with grid simulator</i>	N.4.1.1	CEI 0-16:2022-03	N/A	N/A

<b>N.5 Verifica delle condizioni di sincronizzazione e presa di carico</b> <i>/synchronization and re-connection</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Sincronizzazione e riconnessione. <i>/Synchronization</i>	N.5.1	CEI 0-16:2022-03	N/A	N/A
Verifica della erogazione graduale della potenza attiva (presa di carico) <i>/gradually erogation of the power</i>	N.5.2	CEI 0-16:2022-03	N/A	N/A

<b>N. 6 Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva</b> <i>/Reactive power capability</i>				
<b>Test</b>	<b>Ref. CEI 0-16</b>	<b>Ref. standard</b>	<b>Result</b>	<b>Sample</b>
Verifica della capability di erogazione della potenza reattiva <i>/reactive power production capability</i>	N.6.1	CEI 0-16:2022-03	N/A	N/A
Scambio di potenza reattiva secondo un livello assegnato <i>/Reactive power production according to an assigned level</i>	N.6.2 Annex I	CEI 0-16:2022-03	N/A	N/A
Tempo di risposta ad una variazione a gradino del livello assegnato <i>/Reaction time after a step variation of the assigned level.</i>	N.6.2.1	CEI 0-16:2022-03	N/A	N/A
Regolazione automatica di potenza reattiva secondo una curva caratteristica $\cos\phi = f(P)$ <i>/Automatic reactive power production according to a characteristic curve <math>\cos(\phi)=f(P)</math></i>	N.6.3	CEI 0-16:2022-03	N/A	N/A
Erogazione/assorbimento automatico di potenza reattiva secondo una curva caratteristica $Q=f(V)$ applicabile a generatori con capability rettangolare <i>/Automatic reactive power production according to a characteristic curve <math>Q=f(V)</math></i>	N.6.4	CEI 0-16:2022-03	N/A	N/A

<b>N. 7 Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva</b>				
<i>/Reactive power capability</i>				
<b>Test</b>	<b>Ref. CEI 0-16</b>	<b>Ref. standard</b>	<b>Result</b>	<b>Sample</b>
Limitazione automatica in logica locale, per valori di tensione prossimi al 110%  <i>/ Active power limitation for voltage values near to 100 % di Un</i>	N.7.1 8.8.6.4.1 Annex J (§. J.2)	CEI 0-16:2022-03	N/A	N/A
Limitazione automatica per transitori di sovrافrequenza originatisi sulla rete  <i>/ Active power regulation in coincidence with transitory on the transmission grid</i>	N.7.2 8.8.6.4.2 Annex J (§. J.3)	CEI 0-16:2022-03	N/A	N/A
Incremento automatico per transitori di sottofrequenza originatisi sulla rete  <i>/automatic increasing of active power in coincidence with underfrequency transients.</i>	N.7.2 8.8.6.4.3 Annex K	CEI 0-16:2022-03	N/A	N/A
Limitazione su comando esterno proveniente dal Distributore, e/o in logica centralizzata  <i>/Active power limitation in coincidence with external command coming from the Electricity Distributor</i>	N.7.4 8.8.6.3 Annex M	CEI 0-16:2022-03	N/A	N/A
Verifica del tempo di assestamento ad un comando di riduzione di potenza  <i>/settling time verification after a power limitation command.</i>	N.7.4.1	CEI 0-16:2022-03	N/A	N/A



N.8 VFRT capability				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
VFRT Capability	N.8 8.8.6.1	CEI 0-16:2022-03	N/A	N/A
Test procedure for static converter	N.8.1	CEI 0-16:2022-03		

N.9 Verifica della insensibilità alle richiuse automatiche in discordanza di fase				
<i>/Check of the insensibility to the re-closures when phases are in discordance</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Verifica della insensibilità alle richiuse automatiche in discordanza di fase  <i>/Check of the insensibility to the re-closures when phases are in discordance</i>	N.9	CEI 0-16:2022-03	N/A	N/A

<b>Nbis.3 Misure per la qualità della tensione</b> <i>/Voltage quality measure</i>					
Test	§	Requirement	Ref. standard	Result	Sample
Misura di correnti armoniche <i>/Harmonics current</i>	Nbis.3.1	Nbis.3	CEI 0-16:2022-03	PASS	1
	7.4	--	IEC 61400-21	PASS	1
Misura di fluttuazioni di tensione dovute a manovre di sezionamento/separazione <i>/Voltage fluctuations caused by Switching operations</i>	Nbis.3.2	Nbis.3	CEI 0-16:2022-03	PASS	1
	7.3.4	--	IEC 61400-21	PASS	1
Misura di fluttuazioni di tensione (flicker) in condizioni di funzionamento continuo <i>/Voltage fluctuations (Flickers) during Continuous operation</i>	Nbis.3.3	Nbis.3	CEI 0-16:2022-03	PASS	1
	6.3.2 7.3.3	--	IEC 61400-21	PASS	1

<b>Nbis.4 Verifica del campo di funzionamento in tensione e frequenza</b> <i>/Voltage-frequency working range</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Prove a piena potenza su rete simulata <i>/full power test with grid simulator</i>	Nbis.4	CEI 0-16:2022-03	PASS	1

<b>Nbis.5 Verifica delle condizioni di sincronizzazione e presa di carico</b> <i>/synchronization and re-connection</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Sincronizzazione e riconnessione. <i>/Synchronization</i>	Nbis.5.1	CEI 0-16:2022-03	PASS	1
Verifica della erogazione graduale della potenza attiva (presa di carico) <i>/gradually erogation of the power</i>	Nbis.5.2	CEI 0-16:2022-03	PASS	1

<b>Nbis. 6 Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva</b> <i>/Reactive power capability</i>				
<b>Test</b>	<b>Ref. CEI 0-16</b>	<b>Ref. standard</b>	<b>Result</b>	<b>Sample</b>
Verifica della capability di erogazione della potenza reattiva <i>/reactive power production capability</i>	Nbis.6.1	CEI 0-16:2022-03	PASS	1
Scambio di potenza reattiva secondo un livello assegnato <i>/Reactive power production according to an assigned level</i>	Nbis.6.4	CEI 0-16:2022-03	PASS	1
Tempo di risposta ad una variazione a gradino del livello assegnato <i>/Reaction time after a step variation of the assigned level.</i>	Nbis.6.5	CEI 0-16:2022-03	PASS	1
Regolazione automatica di potenza reattiva secondo una curva caratteristica $\cos\phi = f(P)$ <i>/Automatic reactive power production according to a characteristic curve <math>\cos(\phi)=f(P)</math></i>	Nbis.6.7	CEI 0-16:2022-03	PASS	1
Erogazione/assorbimento automatico di potenza reattiva secondo una curva caratteristica $Q=f(V)$ applicabile a generatori con capability rettangolare <i>/Automatic reactive power production according to a characteristic curve <math>Q=f(V)</math></i>	Nbis.6.8	CEI 0-16:2022-03	PASS	1

<b>Nbis. 7 Verifica dei requisiti costruttivi circa lo scambio di potenza reattiva</b>				
<i>/Reactive power capability</i>				
<b>Test</b>	<b>Ref. CEI 0-16</b>	<b>Ref. standard</b>	<b>Result</b>	<b>Sample</b>
Limitazione automatica in logica locale, per valori di tensione prossimi al 110% <i>/ Active power limitation for voltage values near to 110 % di Un</i>	Nbis.7.1	CEI 0-16:2022-03	PASS	1
Limitazione automatica per transitori di sovrافrequenza originatisi sulla rete <i>/ Active power regulation in coincidence with transitory on the transmission grid</i>	Nbis.7.2	CEI 0-16:2022-03	PASS	1
Incremento automatico per transitori di sottofrequenza originatisi sulla rete <i>/automatic increasing of active power in coincidence with underfrequency transients.</i>	Nbis.7.3	CEI 0-16:2022-03 CEI 0-16; V3/EC2:2024-03 CEI 0-16;V4:2025-03	PASS	1
Verifica della regolazione della potenza attiva su comando esterno proveniente dal Distributore <i>/ Verification of the regulation of the active power on an external command coming from the Distributor</i>	Nbis.7.4	CEI 0-16:2022-03	PASS	1
Verifica del tempo di assestamento ad un comando di incremento/riduzione di potenza <i>/ Check the settling time at an increase / decrease command of power</i>	Nbis.7.4.1	CEI 0-16:2022-03	PASS	1



Nbis.8 VFRT capability				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
VFRT Capability	Nbis.8	CEI 0-16:2022-03	PASS	1

Nbis.9 Verifica della insensibilità alle richiuse automatiche in discordanza di fase				
<i>/Check of the insensibility to the re-closures when phases are in discordance</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Verifica della insensibilità alle richiuse automatiche in discordanza di fase  <i>/Check of the insensibility to the re-closures when phases are in discordance</i>	Nbis.9	CEI 0-16:2022-03	PASS	1

Annex Z Regolazioni del sistema di protezione dei gruppi generatori				
<i>/ System protection regulations for generator</i>				
Test	Ref. CEI 0-16	Ref. standard	Result	Sample
Regolazioni del sistema di protezione dei gruppi generatori  <i>/ System protection regulations for generators</i>	Annex Z	CEI 0-16:2022-03 CEI 0-16; V3:2024-01	PASS	1



<b>Test item particulars</b> .....	
Equipment mobility .....	<input type="checkbox"/> Stationary <input checked="" type="checkbox"/> Fixed
Connection to the mains.....	<input checked="" type="checkbox"/> Permanent connection
Enviromental category.....	<input checked="" type="checkbox"/> Outdoor
Over voltage category Mains.....	<input checked="" type="checkbox"/> OVC III (when used in TT or TN system) <input type="checkbox"/> OVC II (when used in IT system)
Over voltage category PV .....	N/A
Mains supply tolerance (%).....	--
Tested for power systems .....	--
IT testing, phase-phase voltage (V).....	--
Class of equipment .....	<input checked="" type="checkbox"/> Class I
Mass of equipment (kg).....	See model list
Pollution degree .....	<input type="checkbox"/> PD 1 <input checked="" type="checkbox"/> PD 2 (Inside) <input checked="" type="checkbox"/> PD 3(Outside)
IP protection class.....	IP55
<b>Testing</b>	Type Test
Date of receipt of test item(s) .....	See page 1
Dates tests performed.....	See page 1
<b>Possible test case verdicts:</b>	
test case does not apply to the test object .....	N/A
test object does meet the requirement.....	Pass (P)
test object does not meet the requirement.....	Fail (F)
<b>General remarks:</b>	
<p>"(see Attachment #)" refers to additional information appended to the report.          "(see appended table)" refers to a table appended to the report.          The tests results presented in this report relate only to the object tested.          This report shall not be reproduced except in full without the written approval of the testing laboratory.          List of test equipment must be kept on file and available for review.          Additional test data and/or information provided in the attachments to this report.          Throughout this report a point is used as the decimal separator.</p> <p>Definitions:</p> <ul style="list-style-type: none"> <li>(RI) Reinforced insulation; (BI) Basic insulation; (FI) Functional Insulation</li> </ul>	



Informazioni generali sul prodotto / General product information:	
<b>Product:</b>	<input type="checkbox"/> Static generator (Solar Grid tied inverter) <input type="checkbox"/> Wind Full converter (FC) <input type="checkbox"/> Wind Doubly Fed Induction Generator <input checked="" type="checkbox"/> Energy Storage System
<b>License Holder:</b> <i>Address:</i>	EXPOFIN S.R.L. VIALE DELL'INDUSTRIA, N.19 – 35129 PADOVA (PD) – ITALY
<b>Model(s):</b>	SOLID POWER HV 261
<b>Testing Location:</b> <i>Address:</i>	<p>§. N.1 Esecuzione delle prove – accreditamento N.1 Testing - Accreditation</p> <input checked="" type="checkbox"/> CEI UNI EN ISO/IEC 17025:2005 testing Laboratory (See testing laboratory address) <input type="checkbox"/> Manufacturing Plant / Customer facility CEI UNI EN ISO/IEC 17025:2005 testing Laboratory (see Manufacturing plant address)
<b>Testing Laboratory:</b> <i>Address:</i>	TÜV Rheinland (Shanghai) Co., Ltd.
<b>Potenza massima dell'impianto di destinazione:</b> <i>Maximum power of the destination plant:</i>	<input type="checkbox"/> $P_{\text{plant}} < 400 \text{ KW}^*$ <input checked="" type="checkbox"/> $P_{\text{plant}} \geq 400 \text{ KW}^*$ <i>* Only for static generator (wind converter not included)</i>
<b>Input Voltage (Rated):</b>	See modle list
<b>Output Voltage (Rated):</b>	See modle list
<b>Firmware version:</b>	DSP: 1.2.0.5 ARM: 1.9.1.7 EMU: V1.2

## TECHNICAL INFORMATION:

### Product Description:

The system is mainly applied in industrial and commercial scenarios.


1. The Energy Storage System which include one battery rack, one PCS cabinet, one power distribution cabinet, auxiliary distribution system, Air-condition system, BMS control box and fire suppression system.


- a) The auxiliary distribution box is for providing the auxiliary power for whole BMS control system, air-condition system.
- b) Battery cabinet connects to PCS through the busbar convergence, and the PCS converts the DC power generated by the energy storage batteries into AC power which required for connecting to the grid through transformers and other components or required by client.
- c) The ESS is equipped with the local controller in Power distribution cabinet, it collects running information of the PCS, battery, and other devices in the system. And it uploads the information to the energy management system via the background and facilitate the management of energy storage system.
- d) The master control function integrated in BMS control box.

2. There are built-in relays inside of the inverter's on-grid and back-up ports. There are two sets of relays in the grid port, which controlled by DSP and ARM respectively.

When the inverters are the off-grid mode, the built-in on-grid relay will be opened; while the inverters are grid-tied mode, the built-in on-grid relay will be closed.

### Block Diagram:





**Description of change(s):**

N/A

**The product was tested on:**

SOLID POWER HV 261

**Firmware version:**

DSP: 1.2.0.5

ARM: 1.9.1.7

EMU: V1.2

**Test condition:**

Temperature: 25°C Relative humidity: 65%



Copy of marking plates:

	
Product Name	Semi-Solid State Battery Energy Storage System Rechargeable Li-Ion Battery System
Battery Designation	IFjP73/175/208/1525/658M-30+50B5
Product Model	SOLID POWER HV 2B1
Nominal Voltage	832Vd.c
Rated Energy	261KWh
Rated Capacity	314Ah
Max. Charge Voltage	940Vd.c
Max. Charge Current	157A
Cut-off Discharge Voltage	650Vd.c
Max. Discharge Current	157A
Available SOC Range	10%–100%
Rated AC Voltage	400V <sub>a.c</sub> (3L+N)
Frequency	50/60Hz
Max. AC Current	150A
Aux Voltage	220V <sub>a.c</sub> 50/60Hz
Aux Rate Power	2.6KW
Ambient Temperature	-30°C to +55°C
Dimensions (WxD*H)	1150*1400*2350mm
Weight	2440kg
Protection Class	IP55
Enclosure	
Cooling Mode	Liquid-cooled
Working Altitude	≤3000m
Production Date	22-Sep-2025
Series Number	 00250255-00001
manufacturer	EXPOFIN S.R.L.

 **CAUTION**

Please read user manual before operating the system

- \* Avoid to open the box unless authorized.
- \* Do not open charge & use discharge.
- \* Do not fall short grounded per bus profile.
- \* Recharge at least once every 10 days.
- \* Recharge at the end of each work when system under voltage.
- \* Do not disassemble the battery pack.
- \* Do not short circuit or reverse polarity.
- \* Do not use in flammable and avoid the strong shock.
- \* Do not use battery if it is damaged or deformed.
- \* Do not expose to temperatures above 60°C.
- \* Do not transport or store the battery with metal objects.




**Emergency Situations**

- \* If leaking, fire, wet or damaged, switch off the breaker, get away from the battery.
- \* Do not touch the leaking liquid, do not use water, hot water or dry powder extinguisher in public.

Do not dispose of battery in trash, dispose of according to local regulations.

Made in China



DATASHEET



Note: The information of importer provided on product prior marketing.



The main features of the product are shown as below:

	Cell	Module
Product	Solid State Battery Cell	Solid State Battery
Type/model	EFS314	GTEFS-166V52.25K-M05P
Cell Capacity [Ah]	314	314
Cell Quantity	1	52
Battery structure	-	1P52S
Nominal voltage [V]	3.2	166.4
Rated capacity [Wh]	1004.8	52249.6
Upper limit charging voltage [V]	3.8	197.6
Recommend charging current [A]	157	157
Maximum charging current [A]	314	195
Recommend discharging current [A]	157	157
Maximum discharging current [A]	314	195
Discharge cut-off voltage [V]	2.5	130
Lower limit discharging voltage [V]	2.0	104
Temperature range for charging [°C]	0 to 55	-30 to 50
Temperature range for discharging [°C]	-30 to 60	-30 to 50
Temperature threshold for protection	-	53
Overcharge protected voltage supply by battery system	-	≥197.6V
Recommend charging method by manufacturer	Charging the cell with 157A constant current until to 3.65V, then constant voltage 3.65V until charging current reduces to 15A	At constant Power 26100W till cell voltage reaches 3.65 V.
Dimension [mm]	TxWxH: (71.95±0.5) x (174.8±0.5) x (207.1±0.5)	1152±3*800±3*238±3
Weight [kg]	5.63±0.2	340±5
Ingress Protection (IP)	-	IP67
Protective Class	-	I
Cooling type	-	Liquid cooling
Altitude [m]	-	≤3000
Notes:		



	Battery system
Product	Integrated Battery Energy Storage System
Type/model	SOLID POWER HV 261
Cell Capacity [Ah]	314
Cell Quantity	260
Battery structure	(1P52S)5S
Nominal voltage [V]	832
Rated capacity [Wh]	261248
Upper limit charging voltage [V]	936
Recommend charging current [A]	157
Maximum charging current [A]	195
Recommend discharging current [A]	157
Maximum discharging current [A]	195
End-of-charge voltage [V]	936
Discharge cut-off voltage [V]	728
Temperature range for charging [°C]	-30 to 50*
Temperature range for discharging [°C]	-30 to 50
Operating ambient temperature [°C]	-30 to 50
Temperature threshold for protection	53
Overcharge protected voltage supply by battery system	≥3.7V/cell
Recommend charging method by manufacturer	At constant Power 125kW till cell voltage reaches 3.65 V
Dimension [mm]	1100*1400*2350
Weight [kg]	2440
Ingress Protection (IP)	IP55
Protective Class	I
Cooling type	Liquid-cooled
Altitude[m]	≤3000
<p>*Notes: When the cell temperature is less than 0°C, the battery system will stop working and the liquid cooling unit will start heating. It will start derating when ambient temperature is 0°C to 10°C and more than 45°C.</p>	



## 2. PCS Cabinet:

MODELS LIST		INPPCS-125/0.4-W-14-A2-OS
DC Side	VMAX DC [Vdc]	1000
	Voltage Range V[Vdc]	600-1000
	Max. DC current [Ad.c.]	198
	Rated DC power [kW]	125
	Max. DC power [kW]	137.5
	Overvoltage Category (OVC)	II
AC Side	Rated Output Voltage Ur [Vac]	3L / N / PE, 230 / 400
	AC rated Input /Output active Power PE [kW]	125
	Rated Output Frequency FNETZ [Hz]	50/60±2.5
	Harmonic (THDi)	≤5% (at nominal Power)
	Max. AC Input/Output current [Aa.c.]	180
	AC voltage tolerance	-15%~+15%
	Adjustable reactive Power range	-100%~100%
	Power Factor cosφ [λ]	-0.99~+0.99, At nominal Power
	Overvoltage Category (OVC)	III
System	Max. efficiency	99%
	Protective Class	I
	Ingress Protection (IP)	IP20
	Operating Temperature Range [°C]	-30 to 50(>45 derating)
	Cooling Type	Air Cooling
	Pollution degree (PD)	3
	Altitude [m]	3000(>2,000 derating)
	Weight [kg]	70
Size [mm]	W520×H240×D680	




### 3. Energy Storage System

MODELS LIST		Integrated Battery Energy Storage System
DC side	VMAX DC[Vdc]	936
	Battery Nominal Voltage [Vd.c.]	832
	Rated capacity[Wh]	261248
	Max. Current I <sub>max</sub> [A]	195
	Voltage Range [Vd.c.]	728 to 936
AC side	PCS Cabinet Model	INPPCS-125/0.4-W-14-A2-OS
	Rated H.V. voltage [kVa.c.]	400
	Rated H.V. current [A a.c.]	180
	Rated grid frequency [Hz]	50/60
	Max. Current [A a.c.]	198
	Rated AC power [kVA]	125
	Overvoltage Category (OVC)	III
Battery Energy Storage System	IP rating/ Enclosure index / type	IP55
	Protective Class	I
	Operating Temperature Range [°C]	-30 to 50 (>45 derating)
	Pollution degree (PD)	PD3 (PD2 inside)
	Altitude [m]	≤3000 (>2000 derating)
	Weight [kg]	2440
	Size (W x D x H) [mm]	1100*1400*2350

## TESTING RESULTS


C.2.4.7.3 D.3.5 E.4.4	TABLE : Dry heat (Test B) – storage conditions.	P
CEI EN 60068-2-2:2008-11 Prove ambientali - Parte 2-2: Prove - Prova B: Caldo secco <i>/Environmental testing - Part 2-2: Tests - Test B: Dry heat</i>		
Condizioni di test / <i>Test conditions</i>	dissipa calore / <i>heat -dissipating</i>	
Tipo di campione / <i>Specimen type</i>	Bb: graduale / <i>gradual</i>	
Tipo di ventilazione / <i>Air circulation</i>	forzata / <i>forced air</i>	
Temperatura misurata / <i>Measured temperature:</i>	70 °C	
Duration:	16 h	
Precondizionamento / <i>Preconditioning</i> —		
Verifiche iniziali / <i>Initial measurement</i> Verifica della corretta funzionalità del dispositivo / <i>verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia / <i>verification of correct interface protection</i>		
Verifiche finali / <i>Final measurement</i> Dopo il ciclo termico / <i>after thermal cycle</i> Verifica della corretta funzionalità del dispositivo / <i>verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia / <i>verification of correct interface protection</i>		
Condizioni particolari di prova / <i>Particular test condition</i> Apparato non operativo (non alimentato) / <i>device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Dry heat (Test B) – storage conditions.




C.2.4.7.3 D.3.5 E.4.4	<b>TABLE : Humidity test (Test Cab) - storage conditions.</b>	<b>P</b>
<p>CEI EN 60068-2-78:2002:03          Prove ambientali - Parte 2-78: Prove - Prova Cab: Caldo umido, regime stazionario          /Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state</p>		
Temperatura misurata /Measured temperature:		40 °C
Umidità misurata /measured humidity:		93 RH%
Duration:		96 h
Instrumentation list		See table "Measurement equipment and instrumentation"
Uncertainty		See table
Precondizionamento /Preconditioning -		
Verifiche iniziali /Initial measurement Verifica della corretta funzionalità del dispositivo / verification of correct device functionality Verifica del corretto funzionamento della protezione di interfaccia / verification of correct interface protection		
Verifiche finali /Final measurement Dopo il ciclo termico / after thermal cycle Verifica della corretta funzionalità del dispositivo / verification of correct device functionality Verifica del corretto funzionamento della protezione di interfaccia / verification of correct interface protection		
Condizioni particolari di prova /Particular test condition Apparato non operativo (non alimentato) / device not operative (not powered)		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Humidity test (Test Cab) - storage conditions.




C.2.4.7.3 D.3.5 E.4.4	<b>TABLE : Cold test (Test A) – storage conditions.</b>	<b>P</b>
CEI EN 60068-2-1:2007:11 Prove ambientali - Parte 2-1: Prove - Prova A: Freddo <i>/Environmental testing - Part 2-1: Tests - Test A: Cold</i>		
Condizioni di test / <i>Test conditions</i>		dissipa calore / <i>heat -dissipating</i>
Tipo di campione / <i>Specimen type</i>		Bb: graduale / <i>gradual</i>
Tipo di raffreddamento del campione / <i>Specimen cooling type</i>		senza raffreddamento artificiale / <i>without artificial cooling</i>
Tipo di ventilazione / <i>Air circulation</i>		forzata / <i>forced air</i>
Temperatura misurata / <i>Measured temperature:</i>		-10 °C
Duration:		16 h
Instrumentation list:		See table "Measurement equipment and instrumentation"
Uncertainty:		See table
Precondizionamento / <i>Preconditioning</i> -		
Verifiche iniziali / <i>Initial measurement</i> Verifica della corretta funzionalità del dispositivo / <i>verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia / <i>verification of correct interface protection</i>		
Verifiche finali / <i>Final measurement</i> Dopo il ciclo termico / <i>after thermal cycle</i> Verifica della corretta funzionalità del dispositivo / <i>verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia / <i>verification of correct interface protection</i>		
Condizioni particolari di prova / <i>Particular test condition</i> Apparato non operativo (non alimentato) / <i>device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		

## Image: Cold test (Test A) – storage conditions




C.2.4.7.3 D.3.5 E.4.4	<b>TABLE : Change of temperature (Test N) – storage conditions.</b>	<b>P</b>
CEI EN 60068-2-14:2023 Prove ambientali - Parte 2-14: Prove - Prova N: Cambio di temperatura <i>/Environmental testing - Part 2-14: Tests - Test N: Change of temperature</i>		
Prova/Test	NB: Cambio a velocità controllata <i>/NB Change with specified rate of change</i>	
Tipo di ventilazione <i>/Air circulation</i>	forzata / forced air	
N° cicli <i>/Number of cycle:</i>	1	
Temperatura minima $T_A$ <i>/Minimum temperature <math>T_A</math> .....:</i>	$- 10 \pm 2 \text{ } ^\circ\text{C}$	
Temperatura massima $T_B$ <i>/Maximum temperature <math>T_B</math> :</i>	$+70 \pm 2^\circ\text{C}$	
Durata di esposizione $t_1$ <i>/Exposure time <math>t_1</math> .....:</i>	3 h	
Tempo di trasferimento $t_2$ <i>/Transition time <math>t_2</math> ....:</i>	3 h	
Instrumentation list:	See table "Measurement equipment and instrumentation"	
Uncertainty:	See table	
Precondizionamento <i>/Preconditioning</i> -		
Verifiche iniziali <i>/Initial measurement</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Verifiche finali <i>/Final measurement</i> Dopo il ciclo termico <i>/ after thermal cycle</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Condizioni particolari di prova <i>/Particular test condition</i> Apparato non operativo (non alimentato) <i>/ device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Change of temperature (Test N) – storage conditions.



C.2.4.7.3 D.3.5 E.4.4	TABLE : Dry heat (Test B) – working conditions.	P
CEI EN 60068-2-2:2008-11 Prove ambientali - Parte 2-2: Prove - Prova B: Caldo secco <i>/Environmental testing - Part 2-2: Tests - Test B: Dry heat</i>		
Condizioni di test <i>/Test conditions</i>		dissipa calore <i>/heat -dissipating</i>
Tipo di campione <i>/Specimen type</i>		Bb: graduale <i>/ gradual</i>
Tipo di ventilazione <i>/Air circulation</i>		forzata <i>/ forced air</i>
Temperatura misurata <i>/Measured temperature:</i>		55 °C
Duration:		16 h
Precondizionamento <i>/Preconditioning</i> —		
Verifiche iniziali <i>/Initial measurement</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Verifiche finali <i>/Final measurement</i> Dopo il ciclo termico <i>/ after thermal cycle</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Condizioni particolari di prova <i>/Particular test condition</i> Apparato non operativo (non alimentato) <i>/ device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		


Image: Dry heat (Test B) – working conditions.






C.2.4.7.3 D.3.5 E.4.4	TABLE : Humidity test (Test Cab) - working conditions.	P
CEI EN 60068-2-78:2002:03 Prove ambientali - Parte 2-78: Prove - Prova Cab: Caldo umido, regime stazionario /Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state		
Temperatura misurata /Measured temperature:	40 °C	
Umidità misurata /measured humidity:	93 RH%	
Duration:	96 h	
Instrumentation list	See table "Measurement equipment and instrumentation"	
Uncertainty	See table	
Precondizionamento /Preconditioning -		
Verifiche iniziali /Initial measurement Verifica della corretta funzionalità del dispositivo / verification of correct device functionality Verifica del corretto funzionamento della protezione di interfaccia / verification of correct interface protection		
Verifiche finali /Final measurement Dopo il ciclo termico / after thermal cycle Verifica della corretta funzionalità del dispositivo / verification of correct device functionality Verifica del corretto funzionamento della protezione di interfaccia / verification of correct interface protection		
Condizioni particolari di prova /Particular test condition Apparato non operativo (non alimentato) / device not operative (not powered)		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Humidity test (Test Cab) - working conditions.




C.2.4.7.3 D.3.5 E.4.4	<b>TABLE : Cold test (Test A) – working conditions.</b>	<b>P</b>
CEI EN 60068-2-1:2007:11 Prove ambientali - Parte 2-1: Prove - Prova A: Freddo <i>/Environmental testing - Part 2-1: Tests - Test A: Cold</i>		
Condizioni di test <i>/Test conditions</i>		dissipa calore <i>/heat -dissipating</i>
Tipo di campione <i>/Specimen type</i>		Bb: graduale <i>/ gradual</i>
Tipo di raffreddamento del campione <i>/Specimen cooling type</i>		senza raffreddamento artificiale <i>/without artificial cooling</i>
Tipo di ventilazione <i>/Air circulation</i>		forzata <i>/ forced air</i>
Temperatura misurata <i>/Measured temperature:</i>		-10 °C
Duration:		16 h
Instrumentation list:		See table "Measurement equipment and instrumentation"
Uncertainty:		See table
Precondizionamento <i>/Preconditioning</i> -		
Verifiche iniziali <i>/Initial measurement</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Verifiche finali <i>/Final measurement</i> Dopo il ciclo termico <i>/ after thermal cycle</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Condizioni particolari di prova <i>/Particular test condition</i> Apparato non operativo (non alimentato) <i>/ device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Cold test (Test A) – working conditions



C.2.4.7.3 D.3.5 E.4.4	TABLE : Change of temperature (Test N) – working conditions.	P
CEI EN 60068-2-14:2023		
Prove ambientali - Parte 2-14: Prove - Prova N: Cambio di temperatura <i>/Environmental testing - Part 2-14: Tests - Test N: Change of temperature</i>		
Prova/Test	NB: Cambio a velocità controllata <i>/NB Change with specified rate of change</i>	
Tipo di ventilazione <i>/Air circulation</i>	forzata / forced air	
N° cicli <i>/Number of cycle:</i>	1	
Temperatura minima $T_A$ <i>/Minimum temperature <math>T_A</math> .....:</i>	$- 10 \pm 2^\circ\text{C}$	
Temperatura massima $T_B$ <i>/Maximum temperature <math>T_B</math> :</i>	$+55 \pm 2^\circ\text{C}$	
Durata di esposizione $t_1$ <i>/Exposure time <math>t_1</math> .....:</i>	3 h	
Tempo di trasferimento $t_2$ <i>/Transition time <math>t_2</math> ...:</i>	3 h	
Instrumentation list:	See table "Measurement equipment and instrumentation"	
Uncertainty:	See table	
Precondizionamento <i>/Preconditioning</i> -		
Verifiche iniziali <i>/Initial measurement</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Verifiche finali <i>/Final measurement</i> Dopo il ciclo termico <i>/ after thermal cycle</i> Verifica della corretta funzionalità del dispositivo <i>/ verification of correct device functionality</i> Verifica del corretto funzionamento della protezione di interfaccia <i>/ verification of correct interface protection</i>		
Condizioni particolari di prova <i>/Particular test condition</i> Apparato non operativo (non alimentato) <i>/ device not operative (not powered)</i>		
Supplementary information: After the conditions, the inverter still work without any problem.		

Image: Change of temperature (Test N) – working conditions.





C.2.4.7.4 D.3.6 E.4.5	<b>TABLE: Insulation tests</b>	<b>P</b>	
<input checked="" type="checkbox"/> CEI EN 60255-5:2001-11 Parte 5: Coordinamento dell'isolamento per i relè di misura e per i dispositivi di protezione Prescrizioni e prove <i>/Electrical Relays - Part 5: Insulation coordination for measuring relays and protection equipment – Requirements and tests</i>			
<input type="checkbox"/> CEI EN 60146-1-1:1997 + A1:1998 Convertitori a semiconduttori - Prescrizioni generali e convertitori commutati dalla linea Prove di isolamento (§ 4.2.1). <i>/ Semiconductor converters - General requirements and line commutated converters - Part 1-1: Specification of basic requirements Insulation tests (§. 4.2.1).</i>			
Ambient temperature (°C) .....		20°C ± 2°C	
Humidity (RH %) .....		35% - 75% RH	
Instrumentation list.....		See table "Measurement equipment and instrumentation"	
Uncertainty .....		See table	
<b>Resistenza di isolamento /Insulation Resistance</b>			
Test	Test Voltage (V)	R measured	Limit
Between PE and AC output shorted	500 Vdc	>50G	≥100MΩ
Between PE and DC input shorted	500 Vdc	>50G	≥100MΩ
Between PE and DC + AC shorted	500 Vdc	>50G	≥100MΩ
<b>Prova di rigidità dielettrica/ Dielectric strenght test</b>			
Test	Test Voltage (V)	R Measured after MΩ @ 500Vdc test	Comments
Between PE and AC output shorted	2 kVa.c.	>50G	No discharge.
Between PE and DC + AC shorted	2 kVa.c.	>50G	No discharge.



**Allegato Nbis: Prove sui generatori statici, eolici FC (Full converter) e DFIG (Doubly Fed Induction Generator).**

*Annex Nbis: Testing on static converter, FC (Full converter) and DFIG (Doubly Fed Induction Generator) wind converter.*

**Nbis.3 Misura di correnti armoniche**  
*/Harmonics current*

Reference standard:

IEC 61400-21:2008-08 Ed.2 (§. 7.4)

*Wind turbines*

*Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines*

Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"

**Supplementary information:**

For integrated EESS test has to carry out @  $P_{S\text{MAX}}$  (Max. Discharging Power) or  $P_{N\text{INV}}$  (Nominal Power Inverter)

For EESS connected to bi-directional converter test has to carry out @  $P_{C\text{MAX}}$  (Max. Charging Power)

Tolerance of the Power: 5%  $S_N$  ( $S_N$  = Nominal Power of the Converter).

**Notes on recording:**

- Samplerate at least 40 kHz
- Record at least U and I per phase digitally
- Record at least 600 s per power bin

**\*Standard current harmonics up to order 50**

Note:

The current harmonics up to order 50 .

## Harmonics Current

Order	0 % P/P <sub>S MAX</sub>	20 % P/P <sub>S MAX</sub>	40 % P/P <sub>S MAX</sub>	60 % P/P <sub>S MAX</sub>	80 % P/P <sub>S MAX</sub>	100 % P/P <sub>S MAX</sub>
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
2	0.020	0.032	0.038	0.074	0.073	0.261
3	0.467	1.047	1.124	1.249	1.410	0.898
4	0.021	0.073	0.073	0.094	0.083	0.122
5	0.512	0.697	0.709	0.712	0.710	0.717
6	0.067	0.131	0.127	0.111	0.066	0.247
7	0.456	0.181	0.441	0.559	0.630	0.489
8	0.094	0.064	0.050	0.034	0.044	0.049
9	0.492	0.186	0.198	0.252	0.294	0.049
10	0.060	0.115	0.135	0.150	0.158	0.032
11	0.261	0.238	0.194	0.183	0.239	0.337
12	0.037	0.024	0.028	0.028	0.032	0.043
13	0.191	0.190	0.163	0.349	0.442	0.239
14	0.030	0.031	0.040	0.044	0.049	0.038
15	0.180	0.158	0.103	0.283	0.374	0.152
16	0.030	0.015	0.036	0.030	0.024	0.028
17	0.140	0.089	0.053	0.182	0.259	0.172
18	0.021	0.018	0.021	0.016	0.014	0.035
19	0.117	0.113	0.050	0.111	0.171	0.222
20	0.010	0.013	0.011	0.008	0.010	0.027
21	0.106	0.153	0.060	0.080	0.115	0.084
22	0.007	0.018	0.013	0.012	0.011	0.025
23	0.088	0.140	0.066	0.075	0.086	0.220
24	0.009	0.021	0.014	0.013	0.015	0.035
25	0.064	0.093	0.060	0.076	0.073	0.375
26	0.009	0.013	0.010	0.007	0.007	0.009
27	0.052	0.053	0.057	0.076	0.070	0.088
28	0.008	0.007	0.008	0.006	0.005	0.030
29	0.048	0.039	0.054	0.073	0.071	0.210
30	0.005	0.006	0.008	0.006	0.005	0.027
31	0.039	0.039	0.054	0.069	0.072	0.275
32	0.005	0.006	0.006	0.005	0.004	0.013
33	0.032	0.037	0.058	0.064	0.071	0.102
34	0.005	0.006	0.005	0.004	0.004	0.033
35	0.027	0.031	0.059	0.058	0.070	0.225
36	0.004	0.006	0.004	0.004	0.004	0.025
37	0.025	0.019	0.056	0.052	0.070	0.182
38	0.004	0.005	0.005	0.005	0.004	0.009
39	0.023	0.017	0.049	0.041	0.064	0.035
40	0.004	0.005	0.006	0.006	0.006	0.017
41	0.021	0.018	0.042	0.030	0.053	0.004
42	0.004	0.005	0.005	0.005	0.006	0.007
43	0.017	0.021	0.038	0.025	0.046	0.004
44	0.004	0.005	0.005	0.005	0.006	0.006
45	0.014	0.016	0.034	0.023	0.041	0.007
46	0.004	0.005	0.004	0.004	0.005	0.006
47	0.013	0.011	0.030	0.021	0.035	0.054
48	0.003	0.004	0.004	0.004	0.005	0.042
49	0.011	0.009	0.025	0.019	0.030	0.044
50	0.003	0.004	0.003	0.003	0.004	0.021

Note: The maximum average value for each three phase was recorded.



**Table: Inter-Harmonics**

Order	0 % P/ P <sub>SMAX</sub>	20 % P/ P <sub>SMAX</sub>	40 % P/ P <sub>SMAX</sub>	60 % P/ P <sub>SMAX</sub>	80 % P/ P <sub>SMAX</sub>	100 % P/ P <sub>SMAX</sub>
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
75	0.097	0.112	0.146	0.167	0.182	0.192
125	0.043	0.049	0.070	0.078	0.082	0.087
175	0.052	0.061	0.079	0.082	0.083	0.082
225	0.070	0.082	0.106	0.123	0.126	0.129
275	0.055	0.064	0.095	0.111	0.111	0.108
325	0.077	0.090	0.135	0.169	0.179	0.187
375	0.051	0.060	0.110	0.140	0.157	0.170
425	0.044	0.052	0.093	0.107	0.119	0.136
475	0.044	0.051	0.073	0.086	0.096	0.111
525	0.038	0.044	0.058	0.065	0.072	0.081
575	0.036	0.041	0.051	0.057	0.063	0.070
625	0.030	0.035	0.046	0.047	0.051	0.055
675	0.029	0.033	0.043	0.042	0.047	0.050
725	0.027	0.031	0.039	0.038	0.041	0.043
775	0.025	0.029	0.037	0.035	0.037	0.040
825	0.023	0.027	0.033	0.033	0.034	0.035
875	0.022	0.025	0.033	0.031	0.031	0.033
925	0.021	0.024	0.030	0.029	0.029	0.030
975	0.020	0.023	0.029	0.027	0.027	0.028
1025	0.019	0.022	0.028	0.025	0.025	0.026
1075	0.018	0.021	0.027	0.025	0.024	0.024
1125	0.017	0.020	0.025	0.024	0.022	0.022
1175	0.017	0.020	0.024	0.023	0.021	0.021
1225	0.016	0.018	0.021	0.021	0.019	0.019
1275	0.016	0.018	0.021	0.021	0.018	0.018
1325	0.015	0.017	0.018	0.019	0.017	0.017
1375	0.014	0.016	0.018	0.018	0.016	0.016
1425	0.014	0.016	0.017	0.017	0.016	0.016
1475	0.013	0.015	0.016	0.016	0.015	0.015
1525	0.013	0.015	0.015	0.015	0.014	0.014
1575	0.012	0.014	0.014	0.014	0.014	0.013
1625	0.012	0.014	0.013	0.013	0.013	0.013
1675	0.012	0.014	0.013	0.013	0.012	0.012
1725	0.012	0.014	0.012	0.013	0.012	0.012
1775	0.012	0.014	0.013	0.012	0.012	0.011
1825	0.012	0.012	0.013	0.013	0.012	0.012
1875	0.012	0.012	0.015	0.014	0.013	0.013
1925	0.013	0.013	0.016	0.017	0.016	0.016
1975	0.012	0.012	0.016	0.017	0.016	0.016

Note: The maximum average value for each three phase was recorded.



**Table: High Frequency Harmonics**

Freq. [Hz]	0 % P/ P <sub>S</sub> MAX	20 % P/ P <sub>S</sub> MAX	40 % P/ P <sub>S</sub> MAX	60 % P/ P <sub>S</sub> MAX	80 % P/ P <sub>S</sub> MAX	100 % P/ P <sub>S</sub> MAX
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
2100	0.035	0.040	0.045	0.069	0.060	0.093
2300	0.026	0.030	0.034	0.054	0.043	0.064
2500	0.021	0.024	0.024	0.038	0.034	0.047
2700	0.017	0.020	0.020	0.027	0.029	0.033
2900	0.017	0.019	0.017	0.021	0.026	0.023
3100	0.016	0.018	0.015	0.017	0.023	0.016
3300	0.016	0.018	0.015	0.015	0.020	0.015
3500	0.016	0.018	0.014	0.014	0.018	0.015
3700	0.020	0.023	0.018	0.019	0.023	0.025
3900	0.030	0.035	0.045	0.045	0.054	0.070
4100	0.030	0.034	0.037	0.041	0.053	0.070
4300	0.024	0.028	0.023	0.018	0.022	0.024
4500	0.023	0.027	0.019	0.013	0.016	0.015
4700	0.024	0.028	0.020	0.015	0.016	0.016
4900	0.026	0.030	0.020	0.016	0.016	0.016
5100	0.026	0.030	0.019	0.019	0.016	0.017
5300	0.028	0.032	0.020	0.022	0.016	0.017
5500	0.028	0.032	0.019	0.025	0.018	0.017
5700	0.025	0.029	0.019	0.025	0.020	0.020
5900	0.023	0.027	0.021	0.029	0.025	0.023
6100	0.020	0.023	0.020	0.028	0.028	0.022
6300	0.016	0.018	0.020	0.025	0.024	0.026
6500	0.014	0.016	0.017	0.025	0.025	0.022
6700	0.013	0.015	0.013	0.018	0.018	0.016
6900	0.011	0.013	0.013	0.016	0.017	0.017
7100	0.013	0.015	0.009	0.012	0.013	0.012
7300	0.012	0.014	0.007	0.009	0.011	0.010
7500	0.010	0.011	0.007	0.008	0.010	0.010
7700	0.012	0.014	0.006	0.007	0.009	0.010
7900	0.011	0.013	0.007	0.008	0.009	0.011
8100	0.009	0.010	0.006	0.006	0.008	0.010
8300	0.009	0.010	0.005	0.006	0.008	0.009
8500	0.007	0.008	0.005	0.006	0.007	0.009
8700	0.006	0.007	0.005	0.005	0.006	0.008
8900	0.005	0.006	0.004	0.005	0.005	0.007

Note: The maximum average value for each three phase was recorded.

**Additional information:**

The emission of current harmonics, interharmonics and higher frequency components from the device is specified for in percent of  $I_n$  for operation of the device within the power bins 0, 20, . . . 100 % of  $P_n$ .



## Harmonics Current

Order	20 % P/ P <sub>C</sub> MAX	40 % P/ P <sub>C</sub> MAX	60 % P/ P <sub>C</sub> MAX	80 % P/ P <sub>C</sub> MAX	100 % P/ P <sub>C</sub> MAX
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
2	0.033	0.042	0.077	0.078	0.368
3	1.093	1.204	1.316	1.509	0.348
4	0.076	0.078	0.099	0.089	0.406
5	0.727	0.760	0.751	0.760	0.797
6	0.136	0.136	0.116	0.070	0.120
7	0.190	0.472	0.589	0.674	0.255
8	0.067	0.053	0.036	0.047	0.052
9	0.195	0.212	0.266	0.315	0.079
10	0.119	0.145	0.158	0.169	0.044
11	0.248	0.208	0.194	0.256	0.064
12	0.025	0.030	0.030	0.034	0.031
13	0.199	0.175	0.368	0.473	0.203
14	0.032	0.043	0.046	0.053	0.022
15	0.165	0.110	0.299	0.401	0.028
16	0.015	0.038	0.032	0.026	0.015
17	0.093	0.057	0.193	0.277	0.307
18	0.019	0.022	0.016	0.014	0.026
19	0.117	0.054	0.116	0.183	0.058
20	0.013	0.011	0.008	0.010	0.028
21	0.160	0.064	0.084	0.123	0.108
22	0.019	0.014	0.012	0.011	0.029
23	0.145	0.071	0.079	0.092	0.146
24	0.022	0.015	0.013	0.016	0.049
25	0.097	0.064	0.080	0.078	0.314
26	0.013	0.010	0.007	0.007	0.022
27	0.056	0.061	0.080	0.075	0.054
28	0.007	0.008	0.006	0.005	0.023
29	0.040	0.058	0.076	0.076	0.197
30	0.006	0.008	0.006	0.005	0.051
31	0.040	0.058	0.072	0.077	0.220
32	0.006	0.006	0.005	0.004	0.032
33	0.038	0.062	0.067	0.076	0.053
34	0.006	0.005	0.004	0.004	0.013
35	0.032	0.063	0.061	0.075	0.196
36	0.006	0.004	0.004	0.004	0.061
37	0.023	0.060	0.055	0.075	0.043
38	0.006	0.005	0.005	0.004	0.027
39	0.020	0.052	0.043	0.068	0.055
40	0.006	0.006	0.006	0.006	0.036
41	0.022	0.045	0.032	0.057	0.368
42	0.005	0.005	0.005	0.006	0.012
43	0.022	0.041	0.027	0.048	0.010
44	0.005	0.005	0.005	0.006	0.010
45	0.016	0.036	0.024	0.042	0.010
46	0.005	0.004	0.004	0.005	0.011
47	0.011	0.032	0.022	0.036	0.042
48	0.004	0.004	0.004	0.005	0.006
49	0.009	0.026	0.020	0.031	0.030
50	0.004	0.003	0.003	0.004	0.012

**Table: Inter-Harmonics**

Order	20 % P / P <sub>C</sub> MAX	40 % P / P <sub>C</sub> MAX	60 % P / P <sub>C</sub> MAX	80 % P / P <sub>C</sub> MAX	100 % P / P <sub>C</sub> MAX
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
75	0.156	0.180	0.197	0.205	0.214
125	0.074	0.085	0.088	0.093	0.095
175	0.083	0.089	0.089	0.088	0.089
225	0.111	0.133	0.135	0.137	0.140
275	0.100	0.120	0.119	0.114	0.113
325	0.141	0.182	0.193	0.200	0.203
375	0.115	0.152	0.168	0.181	0.195
425	0.098	0.115	0.128	0.144	0.156
475	0.077	0.094	0.103	0.117	0.134
525	0.062	0.070	0.077	0.087	0.099
575	0.055	0.061	0.068	0.074	0.086
625	0.047	0.051	0.055	0.059	0.066
675	0.044	0.046	0.050	0.054	0.059
725	0.040	0.042	0.044	0.045	0.050
775	0.038	0.038	0.040	0.042	0.046
825	0.034	0.036	0.036	0.037	0.040
875	0.034	0.034	0.033	0.035	0.037
925	0.031	0.032	0.031	0.032	0.034
975	0.030	0.030	0.029	0.030	0.031
1025	0.029	0.028	0.027	0.028	0.029
1075	0.028	0.027	0.026	0.026	0.027
1125	0.026	0.025	0.024	0.024	0.025
1175	0.025	0.024	0.023	0.023	0.024
1225	0.022	0.022	0.021	0.021	0.022
1275	0.022	0.022	0.020	0.020	0.021
1325	0.019	0.020	0.019	0.019	0.019
1375	0.019	0.019	0.018	0.018	0.018
1425	0.018	0.018	0.017	0.016	0.017
1475	0.016	0.017	0.016	0.015	0.016
1525	0.015	0.016	0.015	0.014	0.014
1575	0.014	0.015	0.015	0.013	0.013
1625	0.013	0.014	0.014	0.013	0.012
1675	0.013	0.014	0.012	0.012	0.012
1725	0.012	0.014	0.012	0.012	0.012
1775	0.013	0.012	0.012	0.011	0.011
1825	0.013	0.014	0.012	0.012	0.012
1875	0.015	0.015	0.014	0.013	0.012
1925	0.016	0.018	0.017	0.016	0.014
1975	0.016	0.018	0.017	0.016	0.016

**Table: High Frequency Harmonics**

Freq. [Hz]	20 % P/ P <sub>C</sub> MAX	40 % P/ P <sub>C</sub> MAX	60 % P/ P <sub>C</sub> MAX	80 % P/ P <sub>C</sub> MAX	100 % P/ P <sub>C</sub> MAX
	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]	I <sub>h</sub> [%]
2100	0.048	0.072	0.084	0.099	0.131
2300	0.035	0.057	0.045	0.068	0.090
2500	0.025	0.040	0.038	0.050	0.075
2700	0.021	0.029	0.031	0.035	0.058
2900	0.018	0.022	0.028	0.025	0.045
3100	0.016	0.018	0.025	0.018	0.032
3300	0.016	0.015	0.022	0.016	0.025
3500	0.015	0.014	0.020	0.016	0.022
3700	0.019	0.020	0.025	0.027	0.033
3900	0.047	0.047	0.058	0.075	0.094
4100	0.038	0.043	0.057	0.075	0.095
4300	0.024	0.019	0.024	0.028	0.032
4500	0.020	0.013	0.016	0.016	0.022
4700	0.021	0.015	0.016	0.017	0.023
4900	0.021	0.016	0.016	0.017	0.022
5100	0.020	0.020	0.016	0.019	0.021
5300	0.021	0.023	0.018	0.019	0.023
5500	0.020	0.026	0.020	0.019	0.023
5700	0.020	0.027	0.022	0.022	0.023
5900	0.022	0.031	0.027	0.025	0.030
6100	0.021	0.030	0.030	0.024	0.031
6300	0.021	0.027	0.026	0.028	0.030
6500	0.018	0.026	0.027	0.024	0.030
6700	0.014	0.019	0.020	0.018	0.023
6900	0.014	0.016	0.019	0.019	0.024
7100	0.009	0.012	0.013	0.012	0.013
7300	0.007	0.009	0.011	0.010	0.011
7500	0.007	0.008	0.010	0.010	0.010
7700	0.006	0.007	0.009	0.010	0.010
7900	0.007	0.008	0.009	0.011	0.012
8100	0.006	0.006	0.008	0.010	0.010
8300	0.005	0.006	0.008	0.009	0.010
8500	0.005	0.006	0.007	0.009	0.012
8700	0.005	0.005	0.006	0.008	0.007
8900	0.004	0.005	0.005	0.007	0.007



**Nbis.3.2 Misura di fluttuazioni di tensione dovute a manovre di sezionamento/separazione / Voltage fluctuations caused by Switching operations**

Reference standard:  
**IEC 61400-21:2008-08 Ed.2 (§. 7.3.4)**  
*Wind turbines*  
**Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines**

The voltage-change-factor  $k_u(\Psi_k)$ , the flicker-form-factor  $k_f(\Psi_k)$  and the maximum switchcurrent-factor  $k_{max}$  has been calculated for every switching action and every phase.

**Voltage-change-factor  $k_u(\Psi_k)$**

The voltage-change-factor is a standardized rate of the voltage change, due to switching activities of the PGU. The voltage-change-factor is dependent on the phase angle of the grid and thus the voltage change-factor will be calculated for four phase angles of the fictive grid:

$$\Psi_k = 30^\circ, 50^\circ, 70^\circ, 85^\circ$$

- 30degree: 0.46+j0.27
- 50degree: 0.34+j0.41
- 70degree: 0.18+j0.50
- 85degree: 0.05+j0.53

On test configuration the voltage change factor were evaluated in performing the tests at each grid impedance.

Following impedance was been used:

Phase angle	Inductive impedance R/ $\Omega$	Resistive impedance R/ $\Omega$
32	0.240	0.150
50	0.181	0.216
70	0.097	0.265
85	0.025	0.281

The voltage-change-factor will be calculated with following formula:

$$k_u(\Psi_k) = \sqrt{3} \cdot \frac{U_{fic,max} - U_{fic,min}}{U_n} \cdot \frac{S_{k,fit}}{S_n}$$

Where:

- $U_{fic,min}$  and  $U_{fic,max}$  : are the minimum and maximum one period RMS value of the phase-to-neutral voltage on the fictitious grid during the switching operation;
- $U_n$  : is the nominal phase-to-phase voltage;
- $S_n$  : is the rated apparent power of the wind turbine;
- $S_{k,fit}$  : is the short-circuit apparent power of the fictitious grid.

The calculation should be made for every switching activity and for every phase for the different phase Angle  $\Psi_k$ . From these values an average for every phase angle will be evaluated, which corresponds to the final voltage-change-factor.

#### Flicker-form-factor $k_f(\Psi_k)$

The flicker-form-factor is a standardized rate of the flicker-emission due to a switching activity on a PGU. The flicker-form-factor is to determine after following formula:

$$k_f(\Psi_k) = \frac{1}{130} \times \frac{S_{k,fit}}{S_n} \times P_{st,fit} \times T_p^{0,31}$$

Where:

- $T_p$ : is the measurement period, long enough to ensure that the transient of the switching operation has abated, though limited to exclude possible power fluctuations due to turbulence;
- $P_{st,fit}$ : is the flicker emission from the wind turbine on the fictitious grid;
- $S_n$ : is the rated apparent power of the wind turbine;
- $S_{k,fit}$ : is the short-circuit apparent power of the fictitious grid.

Also for the flicker-form-factor, the calculation should be made for every switching activity and for every phase for the different phase angle  $\Psi_k$ . From these values an average for every phase angle will be evaluated, which corresponds to the final flicker form factor.

#### Supplementary information:

For integrated EESS test has to carry out @  $P_{SMAX}$  (Max. Discharging Power) or  $P_{NINV}$  (Nominal Power Inverter)  
For EESS connected to bi-directional converter test has to carry out @  $P_{CMAX}$  (Max. Charging Power)  
Tolerance of the Power: 5%  $S_N$  ( $S_N$  = Nominal Power of the Converter).

#### Notes on recording:

- Samplerate at least 10 kHz
- Record at least U and I per phase digitally

#### Declaration of the switching operations:

- $N_{10\%} = 10$
- $N_{120\%} = 120$
- Switching on @ 10% P/Pn (12 times)
- Switching on @ 100% P/Pn (12 times)

## Integrated EESS

Table N.3.2a: Flicker step factor and voltage change factor for switching at: 100% of $P_{S\text{MAX}}$ (or $P_{\text{INV}}$ for integrated EESS)				
Max. no. of switchin operations $N_{10}$		10		
Max. no. of switchin operations $N_{120}$		120		
Network impedance angle	30°	50°	70°	85°
Flicker step factor $k_f(\Psi_k)$	0.024	0.026	0.027	0.029
Voltage change factor $k_u(\Psi_k)$	0.877	0.735	0.557	0.409

Table N.3.2b: Flicker step factor and voltage change factor for <u>switching</u> at: 10% of $P_{S\text{MAX}}$ (or $P_{\text{INV}}$ for integrated EESS)				
Max. no. of switchin operations $N_{10}$		10		
Max. no. of switchin operations $N_{120}$		120		
Network impedance angle	30°	50°	70°	85°
Flicker step factor $k_f(\Psi_k)$	0.017	0.018	0.020	0.022
Voltage change factor $k_u(\Psi_k)$	0.412	0.394	0.377	0.364

Table N.3.2c: Flicker step factor and voltage change factor for <u>switching off</u> at: 100% of $P_{S\text{MAX}}$ (or $P_{\text{INV}}$ for integrated EESS)				
Max. no. of switchin operations $N_{10}$		10		
Max. no. of switchin operations $N_{120}$		120		
Network impedance angle	30°	50°	70°	85°
Flicker step factor $k_f(\Psi_k)$	0.245	0.180	0.101	0.048
Voltage change factor $k_u(\Psi_k)$	0.318	0.268	0.203	0.149



**Table N.3.2d: Maximum current step factor measured:**

Condition:	Switch on: 10% of $P_{S_{MAX}}$ (or $P_{INV}$ for integrated EESS)	Switch on: 100% of $P_{S_{MAX}}$ (or $P_{INV}$ for integrated EESS)	Switch off: 100% of $P_{S_{MAX}}$ (or $P_{INV}$ for integrated EESS)
$K_{L,max}$	0.100	1.000	1.000

EESS connected to bi-directional converter

**Table N.3.2a': Flicker step factor and voltage change factor for switching at:  
100% of  $P_{C_{MAX}}$**

Max. no. of switchin operations $N_{10}$		10			
Max. no. of switchin operations $N_{120}$		120			
Network impedance angle	30°	50°	70°	85°	
Flicker step factor $k_f(\Psi_k)$	0.024	0.027	0.027	0.029	
Voltage change factor $k_u(\Psi_k)$	0.885	0.757	0.561	0.412	

**Table N.3.2b': Flicker step factor and voltage change factor for switching at:  
10% of  $P_{C_{MAX}}$**

Max. no. of switchin operations $N_{10}$		10			
Max. no. of switchin operations $N_{120}$		120			
Network impedance angle	30°	50°	70°	85°	
Flicker step factor $k_f(\Psi_k)$	0.017	0.018	0.020	0.022	
Voltage change factor $k_u(\Psi_k)$	0.416	0.406	0.380	0.367	

**Table N.3.2c': Flicker step factor and voltage change factor for switching off at:  
100% of  $P_{C_{MAX}}$**

Max. no. of switchin operations $N_{10}$		10			
--	--	----	--	--	--



Max. no. of switchin operations $N_{120}$			120	
Network impedance angle	30°	50°	70°	85°
Flicker step factor $k_f(\Psi_k)$	0.248	0.186	0.102	0.048
Voltage change factor $k_u(\Psi_k)$	0.321	0.276	0.204	0.150

Table N.3.2d<sup>1</sup>: Maximum current step factor measured:

Condition:	Switch on: 10% of $P_{CMAX}$	Switch on: 100% of $P_{CMAX}$	Switch off: 100% of $P_{CMAX}$
$K_{I,max}$	0.100	1.000	1.000



**Nbis.3.3 Misura di fluttuazioni di tensione (flicker) in condizioni di funzionamento continuo**  
*Voltage fluctuations (Flickers) during Continuous operation*

Reference standard:  
 IEC 61400-21:2008-08 Ed.2 (§. 6.3.2 and 7.3.3)  
*Wind turbines*  
 Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines

<b>Testing Method</b>	<input type="checkbox"/> on site test (procedure IEC 61400-21) <input type="checkbox"/> on site test with DC simulator or AC simulator <input checked="" type="checkbox"/> test with AC simulator <sup>(*)</sup> <i>(change of angle of network change 30°, 50°, 70° e 85°)</i> (*) to use a flicker meter compliance with IEC 61000-4-15
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"

**Supplementary information:**  
 For integrated EESS test has to carry out @ P<sub>SMAX</sub> (Max. Discharging Power) or P<sub>NINV</sub> (Nominal Power Inverter)  
 For EESS connected to bi-directional converter test has to carry out @ P<sub>CMAX</sub> (Max. Charging Power)  
 Tolerance of the Power: 5% S<sub>N</sub> (S<sub>N</sub> = Nominal Power of the Converter).

**Test conditions:**

- Procedure according to IEC 61400-21 (same time-series used as for harmonics)

**Notes on recording:**

- Samplerate at least 10 kHz
- Record at least U and I per phase digitally
- Record at least 600 s per power bin

For the calculation of each flicker coefficient following calculation was been performed:

$$c(\Psi_k) = P_{st,fc} \cdot \frac{S_{k,fc}}{S_n}$$

c Ψ<sub>k</sub> = flicker coefficient  
 P<sub>st,fc</sub> = measured value  
 S<sub>k,fc</sub> = calculated short circuit apparent power of the grid  
 S<sub>n</sub> = rated apparent power of the PGU

Discharge mode:

Table N.3.3a:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2663	0.3616	0.3724	0.3940	0.4175	0.4351	0.4588	0.4695	0.4652	0.4853
Pst	0.0129	0.0176	0.0186	0.0198	0.0206	0.0216	0.0233	0.0242	0.0234	0.0244
Angle of network impedance Ψ <sub>k</sub>	30 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3b:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2653	0.3538	0.3802	0.3920	0.4106	0.4165	0.4307	0.2653	0.3538	0.3802
Pst	0.0129	0.0176	0.0186	0.0198	0.0206	0.0206	0.0213	0.0129	0.0176	0.0186
Angle of network impedance Ψ <sub>k</sub>	50 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3c:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2633	0.3734	0.3606	0.3871	0.4155	0.4430	0.4724	0.4880	0.4819	0.5015
Pst	0.0129	0.0186	0.0176	0.0198	0.0206	0.0225	0.0233	0.0245	0.0240	0.0252
Angle of network impedance Ψ <sub>k</sub>	70 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3d:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.3861	0.3508	0.3734	0.4099	0.4390	0.4753	0.4831	0.4900	0.4925	0.3783
Pst	0.0198	0.0176	0.0186	0.0208	0.0216	0.0235	0.0243	0.0245	0.0250	0.0194
Angle of network impedance Ψ <sub>k</sub>	85 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Charge mode:

Table N.3.3a:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2653	0.3538	0.3802	0.3920	0.4106	0.4165	0.4307	0.4371	0.4320	0.4501
Pst	0.0129	0.0176	0.0186	0.0198	0.0206	0.0206	0.0213	0.0216	0.0221	0.0223
Angle of network impedance Ψ <sub>k</sub>	30 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3b:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2663	0.3616	0.3724	0.3940	0.4175	0.4351	0.4588	0.4694	0.4646	0.4850
Pst	0.0129	0.0176	0.0186	0.0198	0.0206	0.0216	0.0233	0.0235	0.0230	0.0243
Angle of network impedance Ψ <sub>k</sub>	50 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3c:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.2633	0.3734	0.3606	0.3871	0.4155	0.4430	0.4724	0.4880	0.4819	0.5015
Pst	0.0129	0.0186	0.0176	0.0198	0.0206	0.0225	0.0233	0.0245	0.0240	0.0252
Angle of network impedance Ψ <sub>k</sub>	70 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Table N.3.3d:

	10% S <sub>N</sub>	20% S <sub>N</sub>	30% S <sub>N</sub>	40% S <sub>N</sub>	50% S <sub>N</sub>	60% S <sub>N</sub>	70% S <sub>N</sub>	80% S <sub>N</sub>	90% S <sub>N</sub>	100% S <sub>N</sub>
C Ψ <sub>k</sub>	0.3861	0.3508	0.3734	0.4099	0.4390	0.4753	0.4831	0.4900	0.4925	0.3783
Pst	0.0198	0.0176	0.0186	0.0208	0.0216	0.0235	0.0243	0.0245	0.0250	0.0194
Angle of network impedance Ψ <sub>k</sub>	85 ° ±2°									
S <sub>k,flc</sub> [KVA]	2500									
S <sub>n</sub> [KVA]	125									

Remark:

Formula for additional impedance to simulate the grid on an AC simulator:

$$S_x = \frac{U_n^2}{\sqrt{R^2 + X^2}}$$

$$R = \frac{3U_n^2}{S_x \sqrt{1 + \tan(\Psi)^2}}$$

$$\tan(\Psi) = \frac{X}{R} = \frac{2 \cdot \pi \cdot f \cdot L}{R}$$

$$L = \tan(\Psi) \cdot \frac{R}{2 \cdot \pi \cdot f}$$


$$\Psi = 70^\circ$$

$$S_x / S_n = 20 \dots 50$$

if  $S_n$  unknown:  $S_n \approx P_n$

Nbis.4 Verifica del campo di funzionamento in tensione e frequenza Voltage-frequency working range			
Aim of the test:	Verification of the capability of the generator to work in the ranges: Output voltage: 85% ÷ 110 % Un Line frequency: 47.5Hz and 51.5Hz (default values) (*) (*) frequency range regulation: 49 Hz and 51 Hz		
Nominal Grid frequency f [Hz]:	50		
Nominal Grid voltage U <sub>n</sub> [V]:	400/230		
Testing Method:	N.4.1 Generatori stabili <input checked="" type="checkbox"/> N.4.1.1 - Prove a piena potenza su rete simulata /full power test with grid simulator <input type="checkbox"/> N.4.1.2 - Prove a potenza ridotta su rete simulata /limited power test with grid simulator		
Ambient temperature (°C) .....	25 °C ± 5 °C		
Humidity (RH %) .....	65%		
Instrumentation list .....	See table "Measurement equipment and instrumentation"		
TEST RESULT			
Set Values	Measured Value	Time [min.]	Result
V=85%*V <sub>n</sub> ; f=47,5Hz; P=100%*P <sub>S MAX</sub> (or P <sub>INV</sub> for integrated EESS) Cosφ=1	See Figure N.4.1.1: Test 1	>5	No disconnection of the equipment.
V=110%*V <sub>n</sub> ; f=51,5Hz; P=100%*P <sub>S MAX</sub> (or P <sub>INV</sub> for integrated EESS) Cosφ=1	See Figure N.4.1.1: Test 2	>5	No disconnection of the equipment.
V=85%*V <sub>n</sub> ; f=47,5Hz; P=100%*P <sub>C MAX</sub> (for EESS connected to BI-directional converter) Cosφ=1	See Figure N.4.1.1: Test 3	>5	No disconnection of the equipment.
V=110%*V <sub>n</sub> ; f=51,5Hz; P=100%*P <sub>C MAX</sub> (for EESS connected to BI-directional converter) Cosφ=1	See Figure N.4.1.1: Test 4	>5	No disconnection of the equipment.
Test 1 & Test 3: Power limitation is allowed reached the I <sub>max</sub> limit during the test conditions.			
Additional Information:			
<ul style="list-style-type: none"> <li>• Sampling frequency = at least 1 samples/s.</li> <li>• Under/over frequency power limitation function disable during measurement.</li> <li>• During measurement Frequency and active Power has to be recorded.</li> <li>• Power must be stable within ±5% S<sub>N</sub> (S<sub>N</sub> = Nominal Power of the Converter).</li> </ul>			


Test Point	Range of operation	Pout [W]	Cosφ	Test time [s]	Limit [%]	Result
Test 1	85% $U_n$ - 47.5Hz	100% $P_{S_{max}}$ (o $P_{NINV}$ )	1.00	at least 300	±5% $S_n$	No Disconnection
Test 2	110% $U_n$ - 51.5Hz	100% $P_{S_{max}}$ (o $P_{NINV}$ )	1.00	at least 300	±5% $S_n$	No Disconnection
Test 3	85% $U_n$ - 47.5Hz	100% $P_{C_{max}}$	1.00	at least 300	±5% $S_n$	No Disconnection
Test 4	110% $U_n$ - 51.5Hz	100% $P_{C_{max}}$	1.00	at least 300	±5% $S_n$	No Disconnection






**Grafico Test 2: 85%  $U_n$  - 47.5Hz / 100% $P_{smax}$**

/ Graph Test 2: 85%  $U_n$  - 47.5Hz




**Grafico Test 3: 110%  $U_n$  - 51.5Hz / 100% $P_{Cmax}$**

/ Graph Test 1: 110%  $U_n$  - 51.5Hz



**Grafico Test 4: 85%  $U_n$  – 47.5Hz / 100% $P_{Cmax}$**

/ Graph Test 4: 85%  $U_n$  – 47.5Hz





<b>Nbis.5 Verifica delle condizioni di sincronizzazione e presa di carico</b> <i>/synchronization and re-connection</i>	
<b>Nbis.5.1 Synchronization</b>	
<b>Nbis.5.2 Gradual erogation of the power</b>	
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list .....	See table "Measurement equipment and instrumentation"
Uncertainty .....	See table
<b>Minimum permanence time:</b>	
T=30s → first connection, maintenance, no SPI disconnection	
T=300s → after SPI disconnection (programmable value from 0s ÷ 900s with step of 5 s)	
Is T=300 s a programmable value?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
<b>Supplementary information:</b>	
<i>Records:</i>	Average 1 minute of RMS-200ms samples
<i>Gradient:</i>	20%P <sub>S</sub> MAX/min (or 20%P <sub>I</sub> INV/min for integrated EESS) 20%P <sub>C</sub> MAX/min
<i>Limit:</i>	P<0.333% P <sub>S</sub> MAX/s (or P <sub>I</sub> INV/s) from power level > 10%* P <sub>S</sub> MAX (or P <sub>I</sub> INV for integrated EESS) P<0.333% P <sub>C</sub> MAX/s from power level > 10%*P <sub>C</sub> MAX
<i>Sampling:</i>	Record Active output power with a min. sampling of 1 sample/sec
<i>Tolerance:</i>	2.5%*S <sub>N</sub> - 2.5% S <sub>N</sub> for EESS connected to bi-directional converter.

Discharge mode									
U [Vac] Set Value	Limit [Vac]	f [Hz] Set Value	Limits [Hz]	Out Power [%] Note 1	Reconnection Time [sec]	Ramp Time(sec) [sec]	Ramp gradient [% Pn/s]	Acceptability criteria	Remark
1.12Un	U > 110%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	OV Ref. b) – § 8.4.1.3
1.08Un	90% <Un< 110%	50	49.90 Hz <F< 50.10 Hz	100	143	330	0.31	Connection Delay for Reconnection ≥30 s	Connection to grid after an input undervoltage Ref. a) – § 8.4.1.3
0.88Un	U < 90%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	UV Ref. b) – § 8.4.1.3
0.92Un	90% <U< 110%	50	49.90 Hz <F< 50.10 Hz	93	313	307	0.32	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
1.12Un	U > 110%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	OV Ref. b) – § 8.4.1.3
1.08Un	90% <U< 110%	50	49.90 Hz <F< 50.10 Hz	100	341	331	0.29	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
Un	90% <U< 110%	48.85	F < 49.90Hz	---	---	---	---	no connection after 300 s	UF Ref. b) – § 8.4.1.3
Un	90% <U< 110%	49.95	49.90 Hz <F< 50.10 Hz	100	313	330	0.30	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
Un	90% <U< 110%	50.15	F > 51.10 Hz	---	---	---	---	no connection after 300 s	OF Ref. b) – § 8.4.1.3
Un	90% <U< 110%	50.05	49.90 Hz <F< 50.10 Hz	100	313	330	0.31	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3

**Note 1:**

For integrated EESS test has to carry out @ P<sub>SMAX</sub> (Max. Discharging Power) or P<sub>NINV</sub> (Nominal Power Inverter)  
For EESS connected to bi-directional converter test has to carry out @ P<sub>CMAX</sub> (Max. Charging Power)


Charge mode									
U [Vac] Set Value	Limit [Vac]	f [Hz] Set Value	Limits [Hz]	Out Power [%] Note 1	Reconnection Time [sec]	Ramp Time(sec) [sec]	Ramp gradient [% Pr/s]	Acceptability criteria	Remark
1.12Un	U > 110%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	OV Ref. b) – § 8.4.1.3
1.08Un	90% <Un< 110%	50	49.90 Hz <F< 50.10 Hz	100	152	330	0.30	Connection Delay for Reconnection ≥30 s	Connection to grid after an input undervoltage Ref. a) – § 8.4.1.3
0.88Un	U < 90%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	UV Ref. b) – § 8.4.1.3
0.92Un	90% <U< 110%	50	49.90 Hz <F< 50.10 Hz	92	313	303	0.30	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
1.12Un	U>110%	50	49.90 Hz <F< 50.10 Hz	---	---	---	---	no connection after 300 s	OV Ref. b) – § 8.4.1.3
1.08Un	85% <U< 110%	50	49.90 Hz <F< 50.10 Hz	100	314	333	0.30	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
Un	85% <U< 110%	48.85	F< 49.90Hz	---	---	---	---	no connection after 300 s	UF Ref. b) – § 8.4.1.3
Un	85% <U< 110%	49.95	49.90 Hz <F< 50.10 Hz	100	313	333	0.30	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3
Un	85% <U< 110%	50.15	F> 51.10 Hz	---	---	---	---	no connection after 300 s	OF Ref. b) – § 8.4.1.3
Un	85% <U< 110%	50.05	49.90 Hz <F< 50.10 Hz	100	312	331	0.30	Connection Delay for Reconnection ≥300 s	Reconnection after fault recovery Ref. b) – § 8.4.1.3

**Note 1:**


For integrated EESS test has to carry out @ P<sub>SMAX</sub> (Max. Discharging Power) or P<sub>NINV</sub> (Nominal Power Inverter)  
For EESS connected to bi-directional converter test has to carry out @ P<sub>CMAX</sub> (Max. Charging Power)

**Grafico Bbis.5.2: Verifica della erogazione graduale della Potenza attiva**  
/ Graph Bbis.5.2: Check of the gradual increase of the power production


**Test in discharging mode ( $P_{S_{max}}$ )**




**Test in charging mode ( $P_{C_{max}}$ )**



<b>Nbis.6 Verifica della capability di erogazione della potenza reattiva</b> <i>/reactive power production capability</i>	
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"
Potenza massima dell'impianto di destinazione: <i>Maximum power of the destination plant:</i>	<input type="checkbox"/> PV plant < 400 KW (see picture 1A) <input checked="" type="checkbox"/> PV plant ≥ 400 KW (see picture 1B)



Picture 1A



Picture 1B


**Nbis.6.1 / Nbis.6.2**

**Modalità di esecuzione e registrazione della prova applicabile a generatori statici**  
/ test execution and recording modes (applicable to static generators)

The maximum absorption capability ( $Q_{min}$ ) and delivery ( $Q_{max}$ ) of reactive power resulting from the sequence of the above measures and that for  $Q = 0$  has to be documented in tabular form.

The test is passed successfully if the detected value of maximum reactive power, reported in a P-Q diagram, is external or at least coincident with the perimeter of the minimum capability of Picture 1B.

Not integrated EESS refer to below P-Q Diagram



Integrated EESS capability is made by contribute of the battery and the static converter.




Table 6.1a: Maximum capability P-Q (Q=0)

TABLE: Reactive power production with set point Q = 0

Power Step	Active Power		Reactive Power		Power Factor	Deviation	Target value	Limit
	[W]	[%Sn]	[VAr]	[%Sn]	Cosφ	ΔQ/Sn[%]	Q/Sn[%]	ΔQ/Sn
90% - 100% $P_{S_{max}}$	124317	99.5	246.0912	0.002	1.00	0.002	0	<±5%
70% - 80% $P_{S_{max}}$	99807	79.8	55.98046	0.000	1.00	0.000	0	<±5%
50% - 60% $P_{S_{max}}$	75952	60.8	43.0424	0.000	1.00	0.000	0	<±5%
30% - 40% $P_{S_{max}}$	50479	40.4	15.8946	0.000	1.00	0.000	0	<±5%
10% - 20% $P_{S_{max}}$	25879	20.7	-98.5046	-0.001	1.00	-0.001	0	<±10%
10% - 20% $P_{C_{max}}$	-25583	-20.5	-54.2855	0.000	1.00	0.000	0	<±10%
30% - 40% $P_{C_{max}}$	-50240	-40.2	-158.48	-0.009	1.00	-0.009	0	<±5%
50% - 60% $P_{C_{max}}$	-75572	-60.5	61.38192	0.000	1.00	0.000	0	<±5%
70% - 80% $P_{C_{max}}$	-100233	-80.2	-143.762	-0.001	1.00	-0.001	0	<±5%
90% - 100% $P_{C_{max}}$	-124922	-99.9	-449.185	-0.004	1.00	-0.004	0	<±5%

Table 6.1b: Maximum capability P-Q ( $Q=Q_{max}(app)$ )

TABLE: Reactive power produced with set point  $Q = Q_{max}$

Power Step	Active Power		Reactive Power		Power Factor	Deviation	Target value	Limit
	[W]	[%Sn]	[VAr]	[%Sn]	Cosφ	$\Delta Q/Sn$ [%]	Q/Sn[%]	$\Delta Q/Sn$
90% - 100% $P_{S_{max}}$	3185	2.5	125350	100.3	0.025	0.3	100	$<\pm 5\%$
70% - 80% $P_{S_{max}}$	2320	1.9	125315	100.3	0.017	0.3	100	$<\pm 5\%$
50% - 60% $P_{S_{max}}$	3186	2.5	125350	100.3	0.025	0.3	100	$<\pm 5\%$
30% - 40% $P_{S_{max}}$	3184	2.5	125357	100.3	0.025	0.3	100	$<\pm 5\%$
10% - 20% $P_{S_{max}}$	3182	2.5	125360	100.3	0.025	0.3	100	$<\pm 5\%$
10% - 20% $P_{C_{max}}$	-5861	-4.7	125343	100.3	-0.047	0.3	100	$<\pm 5\%$
30% - 40% $P_{C_{max}}$	-5858	-4.7	125339	100.3	-0.047	0.3	100	$<\pm 5\%$
50% - 60% $P_{C_{max}}$	-5859	-4.7	125349	100.3	-0.047	0.3	100	$<\pm 5\%$
70% - 80% $P_{C_{max}}$	-6711	-5.4	125309	100.2	-0.0	0.2	100	$<\pm 5\%$
90% - 100% $P_{C_{max}}$	-5959	-4.8	125306	100.2	-0.047	0.2	100	$<\pm 5\%$

Table 6.1c: Maximum capability P-Q (Q=Qmin[ind])

TABLE: Reactive power adsorbed with set point Q = Qmin

Power Step	Active Power		Reactive Power		Power Factor	Deviation	Target value	Limit
	[W]	[%Sn]	[VAr]	[%Sn]	Cosφ	ΔQ/Sn	Q/Sn[%]	ΔQ/Sn
90% - 100% $P_{Smax}$	4797	3.8	-125171	-100.1	-0.034	0.1	-100	<±5%
70% - 80% $P_{Smax}$	3783	3.0	-125201	-100.2	-0.034	0.2	-100	<±5%
50% - 60% $P_{Smax}$	2878	2.3	-125262	-100.2	-0.032	0.2	-100	<±5%
30% - 40% $P_{Smax}$	3779	3.0	-125223	-100.2	-0.034	0.2	-100	<±5%
10% - 20% $P_{Smax}$	3783	3.0	-125020	-100.0	-0.034	0	-100	<±5%
10% - 20% $P_{Cmax}$	-4270	-3.4	-125151	-100.1	-0.034	0.1	-100	<±5%
30% - 40% $P_{Cmax}$	-4365	-3.5	-125173	-100.1	-0.034	0.1	-100	<±5%
50% - 60% $P_{Cmax}$	-5112	-4.1	-125199	-100.2	-0.033	0.2	-100	<±5%
70% - 80% $P_{Cmax}$	-4276	-3.4	-125150	-100.1	-0.034	0.1	-100	<±5%
90% - 100% $P_{Cmax}$	-4273	-3.4	-125149	-100.1	-0.034	0.1	-100	<±5%



<b>Nbis.6.3 Scambio di potenza reattiva secondo un livello assegnato</b> <i>/Reactive power provision according to an assigned level</i>	
<b>Nbis.6.4 Modalità di esecuzione della prova e registrazione dei risultati applicabile a generatori statici</b> <b>(ipotesi di reg. tramite Q)</b> <i>/ Procedure for static generators (regulation through Q).</i>	
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"

**Test Execution:**


Step 1: Set the generator with  $P=50\%P_{nom}$   
 Step 2: Set a set-point of inductive reactive power  $Q_{INDI}=50\%S_N$   
 Step 3: mantein the set-point of step 2 for 60s.

During all steps monitoring:

- Active Power
- Reactive Power (at least 30s ahead Step 2).


Samples rate: RMS-200ms (1 min. everage value)

Acceptance Criteria:  $\Delta Q \leq 5\% S_N$  or  $\Delta \cos\varphi \leq \pm 0.02$  (set-point throught power factor).



**Nbis.6.5 Tempo di risposta ad una variazione a gradino del livello assegnato**  
*/Reaction time after a step variation of the assigned level.*

Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"



**Test execution:**

The values of  $Q_{max|cap}$  and  $Q_{max|ind}$  at 50%Pn of 100%P<sub>SMAX</sub> (or P<sub>INV</sub> for integrated EESS) and 100%P<sub>Cmax</sub> (for EESS connected to Bi-directional converter).


Sample rate: RMS-200ms  
Maximum settling time: 10s

## Q-step response @ P = 50% P<sub>Smax</sub>

Table 6.5a: Q-step response

Setpoint	P [W]	Q [VAr]	cos φ	U [V]
1. Q <sub>0</sub> = 0 VAr	63490	239	0.99	228.58
Settling time [s]	9.2			
2. -Q <sub>max</sub> = -75000VAr	62982	-74875	0.66	228.58
Settling time [s]	9.6			
3. +Q <sub>max</sub> = 75000 VAr	61371	74920	0.67	231.71
Settling time [s]	9.4			
4. Step Q <sub>0</sub> = 0 VAr	62244	1281	0.99	230.18
Maximum settling time [s]:				10

Figure 6.5a – Q-step response @ P = 50% P<sub>Smax</sub>




### Q-step response @ P = 100%P<sub>Smax</sub>

Table 6.5b: Q-step response

Setpoint	P [W]	Q [VAr]	cos φ	U [V]
1. Q <sub>0</sub> = 0 VAr	124349	166	0.99	230.45
Settling time [s]	7.4			
2. -Q <sub>max</sub> = -XXXX VAr	99266	-74046	0.80	229.98
Settling time [s]	8.4			
3. +Q <sub>max</sub> = XXXX VAr	98807	75264	0.79	231.04
Settling time [s]	8.0			
4. Step Q <sub>0</sub> = 0 VAr	123517	115	0.99	230.57
Maximum settling time [s]:	10			

Figure 6.5b – Q-step response @ P = 100% P<sub>Smax</sub>




## Q-step response @ P = 0% P<sub>Cmax</sub>

Table 6.5a: Q-step response

Setpoint	P [W]	Q [VAr]	cos φ	U [V]
1. Q <sub>0</sub> = 0 VAr	915	6.4	0.64	230.22
Settling time [s]	8.0			
2. -Q <sub>max</sub> = -XXXX VAr	1802	-74884	0.02	229.73
Settling time [s]	8.6			
3. +Q <sub>max</sub> = XXXX VAr	1505	74997	0.02	230.81
Settling time [s]	8.4			
4. Step Q <sub>0</sub> = 0 VAr	1711	88.4	0.99	230.29
Maximum settling time [s]:				10

Figure 6.5a – Q-step response @ P = 0% P<sub>Cmax</sub>




## Q-step response @ P = 50% P<sub>cmax</sub>

Table 6.5a: Q-step response

Setpoint	P [W]	Q [VAr]	cos φ	U [V]
1. Q <sub>0</sub> = 0 VAr	-63307	-131	-0.99	230.08
Settling time [s]	8.2			
2. -Q <sub>max</sub> = -XXXX VAr	-61950	-75424	-0.63	229.54
Settling time [s]	8.4			
3. +Q <sub>max</sub> = XXXX VAr	-63192	75190	-0.64	230.63
Settling time [s]	8.2			
4. Step Q <sub>0</sub> = 0 VAr	-62192	-212	-0.99	230.05
Maximum settling time [s]:				

Figure 6.5a – Q-step response @ P = 50% P<sub>cmax</sub>




**Q-step response @ P = 100%P<sub>Cmax</sub>**

**Table 6.5b: Q-step response**

Setpoint	P [W]	Q [VAr]	cos φ	U [V]
1. Q <sub>0</sub> = 0 VAr	-123687	-201	-0.99	229.92
Settling time [s]	8.6			
2. -Q <sub>max</sub> = -XXXX VAr	-98313	-75301	-0.79	230.50
Settling time [s]	7.8			
3. +Q <sub>max</sub> = XXXX VAr	-98101	75163	-0.79	230.50
Settling time [s]	8.0			
4. Step Q <sub>0</sub> = 0 VAr	-124711	-309	-0.99	229.88
Maximum settling time [s]:				10



**Figure 6.5b – Q-step response @ P = 100% P<sub>Cmax</sub>**



**Nbis.6.6 Regolazione automatica di potenza reattiva secondo una curva caratteristica  $\cos\phi = f(P)$**   
/Automatic reactive power production according to a characteristic curve  $\cos(\phi)=f(P)$

**Nbis.6.7 Verifica di rispondenza alle modalità di applicazione della curva standard di erogazione  $\cos\phi = f(P)$**   
/Testin procedure of Automatic reactive power production function according to a characteristic curve  $\cos(\phi)=f(P)$

Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65% ± 5% RH
Instrumentation list.....	See table "Measurement equipment and instrumentation"
Set value.....	Lock-in: 1.05 Vn (Induttivo) (Vn and 1.1 Vn with steps of 0.01) Lock-out: 230 V or 50%PS <sub>max</sub> (0.9 Vn and Vn with steps of 0.01) Lock-in: 0.95 Vn (Capacitivo) (0.9 Vn and Vn with steps of 0.01) Lock-out: 230 V or 50%PS <sub>max</sub> (Vn and 1.1 Vn with steps of 0.01)



**Supplementary information:**

- Function must be enable by a local command of the converter.
- Each value must be reach in < 10s.
- Describe the Lock-in value defined by the manufacturer

**Table 6.6: Verification of reactive power provision according to the standard characteristic curve  $\cos\phi_i=f(P)$**


Induttivo								
P/Pn[%]	P[W]	Vout[V]	Q[Var]	Cosφ measured	Cosφ Set-point	ΔCosφ	LIMIT Δcosφ max	RESULT
20 %	25263	239.24	1116	0.9999	1.00	0.89%	≤ ± 0.01	PASS
30 %	37961	239.29	958	0.9999	1.00	0.77%	≤ ± 0.01	PASS
40 %	50625	239.34	804	1.0000	1.00	0.64%	≤ ± 0.01	PASS
50 %	63336	239.40	675	1.0000	1.00	0.54%	≤ ± 0.01	PASS
60 %	75992	239.45	533	1.0000	1.00	0.43%	≤ ± 0.01	PASS
60 %	76213	244.04	-14852	0.9802	0.98	0.50%	≤ ± 0.01	PASS
70 %	89082	244.08	-25463	0.9601	0.96	0.42%	≤ ± 0.01	PASS
80 %	99334	244.13	-34311	0.9400	0.94	1.39%	≤ ± 0.01	PASS
90 %	113399	244.17	-47288	0.9209	0.92	0.82%	≤ ± 0.01	PASS
100%	116810	244.19	-50650	0.9154	0.90*	4.74%	≤ ± 0.01	PASS
100 %	116990	232.72	-50771	0.9153	0.90*	4.71%	≤ ± 0.01	PASS
100 %	123455	225.89	-267	1.0000	1.00	-0.21%	≤ ± 0.01	PASS

Note\*: Reduced reactive power output is permitted for the reason that the apparent power is limited.

Capacitivo								
P/Pn[%]	P[W]	Vout[V]	Q[Var]	Cosφ measured	Cosφ Set-point	ΔCosφ	LIMIT Δcosφ max	RESULT
20 %	25588	220.86	-979	0.9998	1.00	-0.78%	≤ ± 0.01	PASS
30 %	38298	220.91	-1183	0.9999	1.00	-0.95%	≤ ± 0.01	PASS
40 %	51121	220.97	-1346	0.9999	1.00	-1.08%	≤ ± 0.01	PASS
50 %	63894	221.02	-1466	1.0000	1.00	-1.17%	≤ ± 0.01	PASS
60 %	75171	221.07	-1600	1.0000	1.00	-1.28%	≤ ± 0.01	PASS
60 %	74976	216.49	12856	0.9817	0.98	-1.89%	≤ ± 0.01	PASS
70 %	87528	216.55	23209	0.9617	0.96	-1.86%	≤ ± 0.01	PASS
80 %	100021	216.60	33965	0.9424	0.94	-1.87%	≤ ± 0.01	PASS
90 %	115382	216.66	48613	0.9225	0.92	-0.43%	≤ ± 0.01	PASS
100%	115411	216.68	48638	0.9184	0.90*	-5.81%	≤ ± 0.01	PASS
100 %	115365	228.14	48759	0.9183	0.90*	-5.69%	≤ ± 0.01	PASS
100 %	123626	235.06	-2133	1.0000	1	-1.71%	≤ ± 0.01	PASS

Note\*: Reduced reactive power output is permitted for the reason that the apparent power is limited.


**Figure 6.6 erogazione automatica di potenza reattiva secondo una curva caratteristica  $\cos(\phi) = f(P)$**   
 / Graph reactive power production according to a characteristic curve  $\cos(\phi) = f(P)$





**Nbis.6.8 Erogazione/assorbimento automatico di potenza reattiva secondo una curva caratteristica  $Q=f(V)$**   
*/Automatic reactive power production according to a characteristic curve  $Q=f(V)$*   
**Nbis.6.9 Verifica di rispondenza alle modalità di applicazione della curva caratteristica  $Q=f(V)$**   
*/characteristic curve  $Q=f(V)$  verification*

Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list .....	See table "Measurement equipment and instrumentation"
Set value .....	Lock-in: 0.2 P <sub>S MAX</sub> 0.2 P <sub>N INV</sub> for Integrated EESS 0.2 P <sub>C MAX</sub> for EESS connected to bi-directional converter. (0.1 P <sub>n</sub> and P <sub>n</sub> with steps of 0.1 P <sub>n</sub> ) Lock-out: 0.05 P <sub>n</sub>
Activation settings .....	Activation of the protection with a delay from 0 to 30 s with step of 1 s (Default setting: 3 s)



Q=f(V) standard curve settings:	Default value:	Settable?
V2i	0.90	0.9 Vn ÷ 1.1Vn with steps of 0.01 Vn <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
V1i	0.92	
V1s	1.08	
V2s	1.10	

K	± 0.1	-1÷1 with steps of 0.01 <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
---	-------	--

**Supplementary information:**  
Records: Average 1 minute of RMS-200ms samples.  
According to CEI 0-21:2014 VARIANTE V1 this function has an intentional delay settable from 0 to 30s with step 1s (default setting 3s). Delay have been verified with 0, 3s, 15s, and 30s  
Test must be performed at K, -K, and at default value (0.1).



Discharge mode: $P_{S_{max}}$ ; $k=0.1$	$V_{1s} = 1.08\%V_n$	$V_{2s} = 1.1\%V_n$	Table A.1
	$V_{1l} = 0.92\%V_n$	$V_{2l} = 0.9\%V_n$	Table A.2
Discharge mode: $P_{S_{max}}$ ; $k= -0.1$	$V_{1s} = 1.08\%V_n$	$V_{2s} = 1.1\%V_n$	Table A.3
	$V_{1l} = 0.92\%V_n$	$V_{2l} = 0.9\%V_n$	Table A.4
Charge mode: $P_{C_{max}}$ ; $k=0.1$	$V_{1s} = 1.08\%V_n$	$V_{2s} = 1.1\%V_n$	Table B.1
	$V_{1l} = 0.92\%V_n$	$V_{2l} = 0.9\%V_n$	Table B.2
Charge mode: $P_{C_{max}}$ ; $k= -0.1$	$V_{1s} = 1.08\%V_n$	$V_{2s} = 1.1\%V_n$	Table B.3
	$V_{1l} = 0.92\%V_n$	$V_{2l} = 0.9\%V_n$	Table B.4


**Table A.1: Discharge mode with  $k=0.1$**

Set Point		Measure			Q/Qn[%] expected	$\Delta Q \%$	LIMIT	RESULT
P/P <sub>S<sub>max</sub></sub> [%]	V/V <sub>n</sub>	P/P <sub>S<sub>max</sub></sub> [%]	V <sub>out</sub> [V]	Q [Var]				
<20%	1.07	14.30	246.35	7739	$\approx k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.2	$\leq \pm 5\% S_n$	P
<20%	1.09	14.49	250.83	7788	$\approx k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.2	$\leq \pm 5\% S_n$	P
<20 % → 30 %	1.09	29.72	250.86	-29585	-0.4 Q <sub>max</sub> ( $< 10 \text{ sec}$ )	0.3	$\leq \pm 5\% S_n$	P
40%	1.09	40.39	250.89	-29598	-0.4 Q <sub>max</sub>	0.3	$\leq \pm 5\% S_n$	P
50%	1.09	50.73	250.80	-30610	-0.4 Q <sub>max</sub>	-0.5	$\leq \pm 5\% S_n$	P
60%	1.09	60.35	250.84	-30810	-0.4 Q <sub>max</sub>	-0.6	$\leq \pm 5\% S_n$	P
70%	1.09	69.99	250.83	-30573	-0.4 Q <sub>max</sub>	-0.5	$\leq \pm 5\% S_n$	P
80%	1.09	79.80	250.86	-30991	-0.4 Q <sub>max</sub>	-0.8	$\leq \pm 5\% S_n$	P
90%	1.09	90.12	250.86	-31128	-0.4 Q <sub>max</sub>	-0.9	$\leq \pm 5\% S_n$	P
100%	1.09	98.01	250.82	-30462	-0.4 Q <sub>max</sub>	-0.4	$\leq \pm 5\% S_n$	P
100%	1.10	83.83	253.23	-67524	-0.9 Q <sub>max</sub>	0.1	$\leq \pm 5\% S_n$	P
100 % → 10%	1.10	9.84	253.00	-67687	-0.9 Q <sub>max</sub>	0.1	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	1.10	3.84	253.14	7558	$\approx k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.2	$\leq \pm 5\% S_n$	P

**Table A.2: Discharge mode with k= 0.1**

Set Point		Measure			Q/Qn[%] expected	$\Delta Q$ %	LIMIT	RESULT
P/P <sub>Smax</sub> [%]	V/Vn	P/P <sub>Smax</sub> [%]	Vout [V]	Q [Var]				
<20%	0.93	15.15	214.18	7673	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	0.14	$\leq \pm 5\% S_n$	P
<20%	0.91	15.07	209.25	7621	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	0.10	$\leq \pm 5\% S_n$	P
<20 % → 30 %	0.91	29.89	209.35	44789	0.6 Q <sub>max</sub> ( $< 10$ sec)	-0.17	$\leq \pm 5\% S_n$	P
40%	0.91	40.34	209.28	45492	0.6 Q <sub>max</sub>	0.39	$\leq \pm 5\% S_n$	P
50%	0.91	50.53	209.27	44972	0.6 Q <sub>max</sub>	-0.02	$\leq \pm 5\% S_n$	P
60%	0.91	59.93	209.22	45182	0.6 Q <sub>max</sub>	0.15	$\leq \pm 5\% S_n$	P
70%	0.91	69.91	209.15	46160	0.6 Q <sub>max</sub>	0.93	$\leq \pm 5\% S_n$	P
80%	0.91	79.80	209.25	44487	0.6 Q <sub>max</sub>	-0.41	$\leq \pm 5\% S_n$	P
90%	0.91	82.21	209.26	44486	0.6 Q <sub>max</sub>	-0.41	$\leq \pm 5\% S_n$	P
100%	0.91	83.63	209.06	43944	0.6 Q <sub>max</sub>	-0.84	$\leq \pm 5\% S_n$	P
100%	0.90	67.42	207.16	74299	Q <sub>max</sub>	-0.56	$\leq \pm 5\% S_n$	P
100 % → 10%	0.90	9.05	206.96	75618	Q <sub>max</sub>	0.49	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	0.90	3.34	206.36	7307	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.15	$\leq \pm 5\% S_n$	P

Graph curve Q=f(V)  
Curve A.1



**Graph curve Q=f(V)**  
**Curve A.2**





Table A.3: Discharge mode with  $k = -0.1$

Set Point		Measure			Q/Qn[%] expected	$\Delta Q$ %	LIMIT	RESULT
P/P <sub>Smax</sub> [%]	V/Vn	P/P <sub>Smax</sub> [%]	Vout [V]	Q [Var]				
<20%	1.07	15.01	246.30	-7421	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	0.06	$\leq \pm 5\% S_n$	P
<20%	1.09	15.24	251.10	-7340	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	0.13	$\leq \pm 5\% S_n$	P
<20 % → 30 %	1.09	31.10	250.91	-45489	-0.6 Q <sub>max</sub> ( $< 10$ sec)	-0.39	$\leq \pm 5\% S_n$	P
40%	1.09	40.95	250.94	-45928	-0.6 Q <sub>max</sub>	-0.74	$\leq \pm 5\% S_n$	P
50%	1.09	49.97	250.90	-45461	-0.6 Q <sub>max</sub>	-0.37	$\leq \pm 5\% S_n$	P
60%	1.09	59.62	250.89	-45395	-0.6 Q <sub>max</sub>	-0.32	$\leq \pm 5\% S_n$	P
70%	1.09	70.77	250.92	-46385	-0.6 Q <sub>max</sub>	-1.11	$\leq \pm 5\% S_n$	P
80%	1.09	79.57	250.79	-44928	-0.6 Q <sub>max</sub>	0.06	$\leq \pm 5\% S_n$	P
90%	1.09	89.85	250.81	-45543	-0.6 Q <sub>max</sub>	-0.43	$\leq \pm 5\% S_n$	P
100%	1.09	92.62	250.81	-45930	-0.6 Q <sub>max</sub>	-0.74	$\leq \pm 5\% S_n$	P
100%	1.10	78.86	253.09	-75211	-Q <sub>max</sub>	-0.17	$\leq \pm 5\% S_n$	P
100 % → 10%	1.10	9.64	252.83	-75774	-Q <sub>max</sub>	-0.62	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	1.10	3.74	253.30	-7239	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	0.21	$\leq \pm 5\% S_n$	P

**Table A.4: Discharge mode with  $k = -0.1$**

Set Point		Measure			Q/Qn[%] expected	$\Delta Q \%$	LIMIT	RESULT
P/P <sub>Smax</sub> [%]	V/Vn	P/P <sub>Smax</sub> [%]	Vout [V]	Q [Var]				
<20%	0.93	14.77	214.25	-7890	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.15	$\leq \pm 5\% S_n$	P
<20%	0.91	15.27	208.93	-7735	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.19	$\leq \pm 5\% S_n$	P
<20 % → 30 %	0.91	30.79	209.32	30806	0.4 Q <sub>max</sub> ( $< 10 \text{ sec}$ )	0.48	$\leq \pm 5\% S_n$	P
40%	0.91	39.72	209.35	29440	0.4 Q <sub>max</sub>	-0.45	$\leq \pm 5\% S_n$	P
50%	0.91	50.02	209.36	28471	0.4 Q <sub>max</sub>	-1.22	$\leq \pm 5\% S_n$	P
60%	0.91	60.66	209.15	31592	0.4 Q <sub>max</sub>	1.27	$\leq \pm 5\% S_n$	P
70%	0.91	69.48	209.17	30327	0.4 Q <sub>max</sub>	0.26	$\leq \pm 5\% S_n$	P
80%	0.91	79.75	209.11	29751	0.4 Q <sub>max</sub>	-0.20	$\leq \pm 5\% S_n$	P
90%	0.91	86.95	209.18	29312	0.4 Q <sub>max</sub>	-0.55	$\leq \pm 5\% S_n$	P
100%	0.91	87.25	209.12	29853	0.4 Q <sub>max</sub>	-0.12	$\leq \pm 5\% S_n$	P
100%	0.90	71.13	208.85	67093	0.9 Q <sub>max</sub>	-0.33	$\leq \pm 5\% S_n$	P
100 % → 10%	0.90	10.17	208.62	68233	0.9 Q <sub>max</sub>	0.59	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	0.90	3.88	208.22	-7586	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.07	$\leq \pm 5\% S_n$	P

**Graph curve Q=f(V)**  
**Curve A.3**



**Graph curve Q=f(V)**  
**Curve A.4**





Table B.1: Charge mode with k=0.1

Set Point		Measure			Q/Qn[%] expected	$\Delta Q$ %	LIMIT	RESULT
P/P <sub>Cmax</sub> [%]	V/Vn	P/P <sub>Cmax</sub> [%]	Vout [V]	Q [Var]				
<20%	1.07	-15.20	245.95	7422	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.06	$\leq \pm 5\% S_n$	P
<20%	1.09	-15.46	251.53	7189	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.25	$\leq \pm 5\% S_n$	P
<20 % → 30 %	1.09	-29.75	250.47	-30997	-0.4 Q <sub>max</sub> ( $< 10$ sec)	-0.80	$\leq \pm 5\% S_n$	P
40%	1.09	-39.33	250.65	-31118	-0.4 Q <sub>max</sub>	-0.89	$\leq \pm 5\% S_n$	P
50%	1.09	-49.53	250.67	-30554	-0.4 Q <sub>max</sub>	-0.44	$\leq \pm 5\% S_n$	P
60%	1.09	-59.74	250.74	-31006	-0.4 Q <sub>max</sub>	-0.80	$\leq \pm 5\% S_n$	P
70%	1.09	-70.74	250.75	-30882	-0.4 Q <sub>max</sub>	-0.55	$\leq \pm 5\% S_n$	P
80%	1.09	-80.77	250.88	-31132	-0.4 Q <sub>max</sub>	-0.91	$\leq \pm 5\% S_n$	P
90%	1.09	-90.00	250.85	-30462	-0.4 Q <sub>max</sub>	-0.37	$\leq \pm 5\% S_n$	P
100%	1.09	-96.11	250.83	-29953	-0.4 Q <sub>max</sub>	0.04	$\leq \pm 5\% S_n$	P
100%	1.10	-83.44	253.28	-66155	-0.9 Q <sub>max</sub>	1.08	$\leq \pm 5\% S_n$	P
100 % → 10%	1.10	-10.29	253.67	-65793	-0.9 Q <sub>max</sub>	1.37	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	1.10	-3.71	254.27	7590	$\approx -k Q_{max}$ ( $< \pm 5\% S_n$ )	0.07	$\leq \pm 5\% S_n$	P

Table B.2: Charge mode with k=0.1

Set Point		Measure			Q/Qn[%] expected	$\Delta Q \%$	LIMIT	RESULT
P/P <sub>Cmax</sub> [%]	V/Vn	P/P <sub>Cmax</sub> [%]	Vout [V]	Q [Var]				
<20%	0.93	-15.12	214.39	7688	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	0.15	$\leq \pm 5\% S_n$	P
<20%	0.91	-15.04	209.46	7636	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	0.11	$\leq \pm 5\% S_n$	P
<20 % → 30 %	0.91	-29.83	209.56	44879	0.6 Q <sub>max</sub> ( $< 10 \text{ sec}$ )	-0.10	$\leq \pm 5\% S_n$	P
40%	0.91	-40.26	209.49	45583	0.6 Q <sub>max</sub>	0.47	$\leq \pm 5\% S_n$	P
50%	0.91	-50.43	209.48	45062	0.6 Q <sub>max</sub>	0.05	$\leq \pm 5\% S_n$	P
60%	0.91	-59.81	209.43	45272	0.6 Q <sub>max</sub>	0.22	$\leq \pm 5\% S_n$	P
70%	0.91	-69.77	209.36	46252	0.6 Q <sub>max</sub>	1.00	$\leq \pm 5\% S_n$	P
80%	0.91	-79.64	209.46	44576	0.6 Q <sub>max</sub>	-0.34	$\leq \pm 5\% S_n$	P
90%	0.91	-82.05	209.47	44575	0.6 Q <sub>max</sub>	-0.34	$\leq \pm 5\% S_n$	P
100%	0.91	-83.46	209.27	44032	0.6 Q <sub>max</sub>	-0.77	$\leq \pm 5\% S_n$	P
100%	0.90	-68.29	207.37	74448	Q <sub>max</sub>	-0.44	$\leq \pm 5\% S_n$	P
100 % → 10%	0.90	-9.03	207.17	75769	Q <sub>max</sub>	0.62	$\leq \pm 5\% S_n$	P
10 % → $\leq 5\%$	0.90	-3.33	206.57	7322	$\approx k Q_{max}$ ( $< \pm 5\% S_n$ )	-0.14	$\leq \pm 5\% S_n$	P

**Graph curve Q=f(V)**  
**Curve B.1**



**Graph curve Q=f(V)**  
**Curve B.2**





Table B.3: Charge mode with  $k = -0.1$

Set Point		Measure			Q/Qn[%] expected	$\Delta Q \%$	LIMIT	RESULT
P/P <sub>Cmax</sub> [%]	V/Vn	P/P <sub>Cmax</sub> [%]	Vout [V]	Q [Var]				
<20%	1.07	-15.04	246.79	-7436	$\approx -k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.05	$\leq \pm 5 \% S_n$	P
<20%	1.09	-15.27	251.60	-7355	$\approx -k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.12	$\leq \pm 5 \% S_n$	P
<20 % → 30 %	1.09	-31.16	251.41	-45580	$-0.6 Q_{max}$ ( $< 10 \text{ sec}$ )	-0.46	$\leq \pm 5 \% S_n$	P
40%	1.09	-41.03	251.44	-46018	$-0.6 Q_{max}$	-0.81	$\leq \pm 5 \% S_n$	P
50%	1.09	-50.07	251.40	-45552	$-0.6 Q_{max}$	-0.44	$\leq \pm 5 \% S_n$	P
60%	1.09	-59.74	251.39	-45486	$-0.6 Q_{max}$	-0.39	$\leq \pm 5 \% S_n$	P
70%	1.09	-70.91	251.42	-46478	$-0.6 Q_{max}$	-1.18	$\leq \pm 5 \% S_n$	P
80%	1.09	-79.73	251.29	-45016	$-0.6 Q_{max}$	-0.01	$\leq \pm 5 \% S_n$	P
90%	1.09	-90.03	251.31	-45634	$-0.6 Q_{max}$	-0.51	$\leq \pm 5 \% S_n$	P
100%	1.09	-92.81	251.31	-46022	$-0.6 Q_{max}$	-0.82	$\leq \pm 5 \% S_n$	P
100%	1.10	-79.02	253.60	-75361	$-Q_{max}$	-0.29	$\leq \pm 5 \% S_n$	P
100 % → 10%	1.10	-9.66	253.34	-75926	$-Q_{max}$	-0.74	$\leq \pm 5 \% S_n$	P
10 % → $\leq 5\%$	1.10	-3.75	253.81	-7253	$\approx -k Q_{max}$ ( $< \pm 5 \% S_n$ )	0.20	$\leq \pm 5 \% S_n$	P


Table B.4: Charge mode with  $k = -0.1$

Set Point		Measure			Q/Qn[%] expected	$\Delta Q \%$	LIMIT	RESULT
P/P <sub>Cmax</sub> [%]	V/Vn	P/P <sub>Cmax</sub> [%]	Vout [V]	Q [Var]				
<20%	0.93	-14.81	214.68	-7713.07	$\approx -k Q_{max}$ ( $\leq \pm 5 \% S_n$ )	-0.17	$\leq \pm 5 \% S_n$	P
<20%	0.91	-15.32	209.35	-7758.21	$\approx -k Q_{max}$ ( $\leq \pm 5 \% S_n$ )	-0.21	$\leq \pm 5 \% S_n$	P
<20 % → 30 %	0.91	-30.88	209.74	30697.82	0.4 Q <sub>max</sub> ( $< 10 \text{ sec}$ )	0.56	$\leq \pm 5 \% S_n$	P
40%	0.91	-39.84	209.77	29528.32	0.4 Q <sub>max</sub>	-0.38	$\leq \pm 5 \% S_n$	P
50%	0.91	-50.17	209.78	28556.41	0.4 Q <sub>max</sub>	-1.15	$\leq \pm 5 \% S_n$	P
60%	0.91	-60.84	209.57	31686.78	0.4 Q <sub>max</sub>	1.35	$\leq \pm 5 \% S_n$	P
70%	0.91	-69.69	209.59	30417.98	0.4 Q <sub>max</sub>	0.33	$\leq \pm 5 \% S_n$	P
80%	0.91	-79.99	209.53	29840.25	0.4 Q <sub>max</sub>	-0.13	$\leq \pm 5 \% S_n$	P
90%	0.91	-87.21	209.60	29399.94	0.4 Q <sub>max</sub>	-0.48	$\leq \pm 5 \% S_n$	P
100%	0.91	-87.51	209.54	29942.56	0.4 Q <sub>max</sub>	-0.05	$\leq \pm 5 \% S_n$	P
100%	0.90	-71.34	207.26	67294.28	0.9 Q <sub>max</sub>	-0.16	$\leq \pm 5 \% S_n$	P
100 % → 10%	0.90	-10.20	207.03	68437.70	0.9 Q <sub>max</sub>	0.75	$\leq \pm 5 \% S_n$	P
10 % → $\leq 5 \%$	0.90	-3.93	206.63	-7601.17	$\approx -k Q_{max}$ ( $\leq \pm 5 \% S_n$ )	-0.08	$\leq \pm 5 \% S_n$	P

**Graph curve Q=f(V)**  
**Curve B.3**




**Graph curve Q=f(V)**  
**Curve B.4**





<b>8.8.6.3.1</b>	<b>TABLE: Limitazione della potenza attiva per valori di tensione prossimi al 110 % di Un</b>
<b>Nbis.7.1</b>	<i>/ Active power limitation for voltage values near to 110 % di Un</i>
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list .....	See table "Measurement equipment and instrumentation"
Supplementary information:	
<ul style="list-style-type: none"> <li>- The value for the reduction power activation's is defined from the manufacturer:</li> <li>- Recorder the value of active power with average of 1 second.</li> </ul>	

Set Point	Measure		Limits	Result
	$P_{out}$ [W]	$V_{out}$ [V]		
-2%	121917	248.6	-	P
+2%	-125026	257.5	$\leq 20\% P_{Smax}$ (for unidirectional) $\geq 80\% P_{Cmax}$ (for bidirectional)	P
-2%	123501	248.6	-	P



<b>8.8.6.3.2</b> <b>Nbis.7.2</b>	<b>TABLE: Regolazione della potenza attiva in presenza di transitori sulla rete di trasmissione</b> <b>/Active power regulation in coincidence with transitory on the transmission grid</b>
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"
<b>Supplementary information:</b> <ul style="list-style-type: none"> <li>- Recorder the value of active power with average of 0,2 second.</li> <li>- The storage must have energy equal to 80% of CUS</li> <li>- The Sequence A start to 100%<math>P_{S_{max}}</math> (or <math>P_{inv}</math> for ESS integrated)</li> <li>- The Sequence B start to 50%<math>P_{S_{max}}</math> (or <math>P_{inv}</math> for ESS integrated)</li> <li>- The Sequence C start to 0%<math>P_{S_{max}}</math> (or <math>P_{inv}</math> for ESS integrated) and it's applicable only for Bidirectional converter</li> </ul> <b>Tolerance of the Power: 2.5% <math>S_N</math> (<math>S_N</math> = Nominal Power of the Converter).</b>	



Sequence A						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
1	100% P <sub>Smax</sub>	47.50	125000	123373	± 2.5% S <sub>n</sub>	t1
2	100% P <sub>Smax</sub>	50.15	125000	123325	± 2.5% S <sub>n</sub>	t2
3	100% P <sub>Smax</sub>	50.40	84275	84825	± 2.5% S <sub>n</sub>	t3
4	100% P <sub>Smax</sub>	50.60	46225	46659	± 2.5% S <sub>n</sub>	t4
5	100% P <sub>Smax</sub>	51.49	-123097	-125631	± 2.5% S <sub>n</sub>	t5
6	100% P <sub>Smax</sub>	50.11	-123097	-125614	± 2.5% S <sub>n</sub>	t6
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	100% P <sub>Smax</sub>	50.00	601	9.03	≥ 300	≤ 20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	100% P <sub>Smax</sub>	50.00	125000	122355	± 2.5% S <sub>n</sub>	t7
Sequence B						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	limits	Graph point
1	50% P <sub>Smax</sub>	47.50	62500	62030	± 2.5% S <sub>n</sub>	t1'
2	50% P <sub>Smax</sub>	50.15	62500	62001	± 2.5% S <sub>n</sub>	t2'
3	50% P <sub>Smax</sub>	50.40	33832	34070	± 2.5% S <sub>n</sub>	t3'
4	50% P <sub>Smax</sub>	50.60	4958	5141	± 2.5% S <sub>n</sub>	t4'
5	50% P <sub>Smax</sub>	51.49	-123534	-125899	± 2.5% S <sub>n</sub>	t5'




6	50% P <sub>Smax</sub>	50.11	-123534	-125853	± 2.5% S <sub>n</sub>	t6'
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	100% P <sub>Smax</sub>	50.00	602	9.02	≥ 300	≤ 20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	50% P <sub>Smax</sub>	50.00	62500	62931	± 2.5% S <sub>n</sub>	t7'
Sequence C*						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	limits	Graph point
1	0% P <sub>Smax</sub>	47.50	0	-841	± 2.5% S <sub>n</sub>	t1''
2	0% P <sub>Smax</sub>	50.15	0	-909	± 2.5% S <sub>n</sub>	t2''
3	0% P <sub>Smax</sub>	50.40	-19995	-20963	± 2.5% S <sub>n</sub>	t3''
4	0% P <sub>Smax</sub>	50.60	-39082	-40463	± 2.5% S <sub>n</sub>	t4''
5	0% P <sub>Smax</sub>	51.49	-123550	-126476	± 2.5% S <sub>n</sub>	t5''
6	0% P <sub>Smax</sub>	50.11	-123550	-126419	± 2.5% S <sub>n</sub>	t6''
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	100% P <sub>Smax</sub>	50.00	601	9.02	≥ 300	≤ 20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	0% P <sub>Smax</sub>	50.00	0	-686	± 2.5% S <sub>n</sub>	t7''

**\*Sequence C applicable only for bidirectional converters.**

**Grafico Sequenza A: Curva di limitazione della potenza attiva rispetto alla frequenza**

*/ Graph Sequence A: Active power regulation in coincidence with transitory on the transmission grid*


**Sequence A line graph:**



**Grafico Sequenza B: Curva di limitazione della potenza attiva rispetto alla frequenza**

*/ Graph Sequence B: Active power regulation in coincidence with transitory on the transmission grid*


**Sequence B line graph:**



**Grafico Sequenza C\*: Curva di limitazione della potenza attiva rispetto alla frequenza**

*/ Graph Sequence C\*: Active power regulation in coincidence with transitory on the transmission grid*

**Sequence C line graph:**




<b>8.8.6.3.3</b> <b>Nbis.7.3</b>	<b>TABLE: Regolazione della potenza attiva in presenza di transitori sulla rete di trasmissione</b> <i>/Active power regulation in coincidence with transitory on the transmission grid</i>
-------------------------------------	--

Ambient temperature (°C) .....	25 °C ± 5 °C
--------------------------------	--------------

Humidity (RH %) .....	65%
-----------------------	-----

Instrumentation list.....	See table "Measurement equipment and instrumentation"
---------------------------	---



**Supplementary information:**

- Recorder the value of active power with average of 0,2 second.
- The storage must have energy equal to 80% of CUS
- The Sequence A start to 50%  $P_{Smax}$  (or  $P_{inv}$  for ESS integrated)
- The Sequence B start to 0%  $P_{Smax}$  (or  $P_{inv}$  for ESS integrated)
- The Sequence C start to 100%  $P_{Cmax}$  (or  $P_{inv}$  for ESS integrated) and it's applicable only for Bidirectional converter

Tolerance of the Power: 2.5%  $S_N$  ( $S_N$  = Nominal Power of the Converter).



Sequence A						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	limits	Graph point
1	50% PS <sub>max</sub>	51.50	62500	62590	± 2.5% S <sub>n</sub>	t1
2	50% PS <sub>max</sub>	49.85	62500	62532	± 2.5% S <sub>n</sub>	t2
3	50% PS <sub>max</sub>	49.60	80452	80599	± 2.5% S <sub>n</sub>	t3
4	50% PS <sub>max</sub>	49.40	98271	97633	± 2.5% S <sub>n</sub>	t4
5	50% PS <sub>max</sub>	49.11	124109	123275	± 2.5% S <sub>n</sub>	t5
6	50% PS <sub>max</sub>	49.89	124109	123256	± 2.5% S <sub>n</sub>	t6
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	50% PS <sub>max</sub>	50.00	603	9.04	≥ 300	20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	50% PS <sub>max</sub>	50.00	62500	62648	± 2.5% S <sub>n</sub>	t7

Sequence B						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	limits	Graph point
1	0% PS <sub>max</sub>	51.50	0	-140	± 2.5% S <sub>n</sub>	t1'
2	0% PS <sub>max</sub>	49.85	0	-137	± 2.5% S <sub>n</sub>	t2'
3	0% PS <sub>max</sub>	49.60	34804	35074	± 2.5% S <sub>n</sub>	t3'
4	0% PS <sub>max</sub>	49.40	70882	70796	± 2.5% S <sub>n</sub>	t4'
5	0% PS <sub>max</sub>	49.11	123196	122264	± 2.5% S <sub>n</sub>	t5'



6	0% P <sub>Smax</sub>	49.89	123196	122224	± 2.5% S <sub>n</sub>	t6'
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	0% P <sub>Smax</sub>	50.00	604	9.02	≥ 300	20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	0% P <sub>Smax</sub>	50.00	0	-475	± 2.5% S <sub>n</sub>	t7'


Sequence C*						
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	limits	Graph point
1	100% P <sub>Cmax</sub>	51.50	-125000	-125742	± 2.5% S <sub>n</sub>	t1''
2	100% P <sub>Cmax</sub>	49.85	-125000	-125732	± 2.5% S <sub>n</sub>	t2''
3	100% P <sub>Cmax</sub>	49.60	-54094	-52231	± 2.5% S <sub>n</sub>	t3''
4	100% P <sub>Cmax</sub>	49.40	17544	19009	± 2.5% S <sub>n</sub>	t4''
5	100% P <sub>Cmax</sub>	49.11	121418	121688	± 2.5% S <sub>n</sub>	t5''
6	100% P <sub>Cmax</sub>	49.89	121418	121971	± 2.5% S <sub>n</sub>	t6''
Step #	Set output power [%]	frequency [Hz]	Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]	Limits	
					Wait time [s]	Power Gradient [% P <sub>ref</sub> /min]
6→7	100% P <sub>Cmax</sub>	50.00	605	9.04	≥ 300	20%
Step #	Set output power [%]	frequency [Hz]	Expected power value [W]	Actual power values [W]	Limits	Graph point
7	100% P <sub>Cmax</sub>	50.00	-125000	-125624	± 2.5% S <sub>n</sub>	t7''

\*Sequence C applicable only for bidirectional converters.

### Grafico Sequenza A: Curva di limitazione della potenza attiva rispetto alla frequenza

/ Graph Sequence A: Active power regulation in coincidence with transitory on the transmission grid


Sequence A line graph:



### Grafico Sequenza B: Curva di limitazione della potenza attiva rispetto alla frequenza

/ Graph Sequence B: Active power regulation in coincidence with transitory on the transmission grid


Sequence B line graph:



**Grafico Sequenza C\*: Curva di limitazione della potenza attiva rispetto alla frequenza**

*/ Graph Sequence C\*: Active power regulation in coincidence with transitory on the transmission grid*

**Sequence C line graph:**






<b>8.8.6.3</b> <b>Nbis.7.4</b>	<b>TABLE: Limitazione della potenza attiva su comando esterno proveniente dal Distributore</b> <b>/ Active power limitation in coincidence with external command coming from the Electricity Distributor</b>	
Ambient temperature (°C) .....	25 °C ± 5 °C	
Humidity (RH %) .....	65%	
Instrumentation list.....	See table "Measurement equipment and instrumentation"	
Uncertainty .....	See table	
Supplementary information: Start test with output power at 50%P <sub>Smax</sub> The setting point time's of active power command is 60 seconds. The active power measure's is checked at least after 30 seconds from the set-point of active power command. The test with set-point of 30% P <sub>Cmax</sub> is applicable only for bidirectional converters.		
Operator .....	See cover page	
Supervisor .....	See cover page	
Test Date.....	See cover page	


Test	Set Point	Output Power expected [W]	Output Power measured [W]	Δ P/Pn [%]	Limit [%]	RESULT
1	50%P <sub>Smax</sub> → 30%P <sub>Smax</sub>	37500	37614	0.09	± 2.5% P <sub>Smax</sub>	P
2	50%P <sub>Smax</sub> → 30% P <sub>Cmax</sub> *	-37500	-37681	0.09	± 2.5% P <sub>Smax</sub>	P

**\*Test applicable only for bidirectional converters.**

**Grafico Test 1: Limitazione della potenza attiva in risposta a comando esterno**  
/ Graph Test 1: Active power limitation in coincidence with external command coming from the Electricity Distributor




**Grafico Test 2: Limitazione della potenza attiva in risposta a comando esterno**  
/ Graph Test 2: Active power limitation in coincidence with external command coming from the Electricity Distributor






<b>Nbis.7.4.1</b>	<b>TABLE: Verifica del tempo di assestamento ad un comando di incremento/riduzione di potenza</b> <i>/ Check the settling time with external command to increase/decrease the power</i>	
Ambient temperature (°C) .....	25 °C ± 5 °C	
Humidity (RH %) .....	65%	
Instrumentation list.....	See table "Measurement equipment and instrumentation"	
Supplementary information: <ul style="list-style-type: none"> <li>- Table A is applicable only for bidirectional converters.</li> <li>- Table B is applicable only for unidirectional converters.</li> </ul>		
Operator .....	See cover page	
Supervisor .....	See cover page	
Test Date.....	See cover page	


<b>Tabella A: Tempo di assestamento ad un comando di riduzione della potenza attiva</b> <i>/ Table A: Time of alignment after an active power reduction command</i>							
Test	Set Point	Output Power expected [W]	Output Power measured [W]	Output Power limit [%]	Settling Time [s]	Settling Time limit [s]	RESULT
A.1*	100% P <sub>Smax</sub> → 30% P <sub>Cmax</sub>	-37500	-38423	± 2.5% S <sub>n</sub>	1.4	< 50	P
A.2	100% P <sub>Smax</sub> → 30% P <sub>Smax</sub>	37500	36491	± 2.5% S <sub>n</sub>	1.2	< 50	P
<b>Table B: Tempo di assestamento ad un comando di incremento della potenza attiva</b> <i>/ Table B: Time of alignment after an active power increasing command</i>							
Test	Set Point	Output Power expected [W]	Output Power measured [W]	Output Power limit [%]	Settling Time [s]	Settling Time limit [s]	RESULT
B.1*	100% P <sub>Cmax</sub> → 50% P <sub>Smax</sub>	62500	63204	± 2.5% S <sub>n</sub>	1.0	< 50	P
B.2	0% P <sub>Smax</sub> → 50% P <sub>Smax</sub>	62500	62062	± 2.5% S <sub>n</sub>	1.0	< 50	P
*Test applicable only for bidirectional converters.							
<b>Grafico Test A.1: Limitazione della potenza attiva in risposta a comando esterno</b> <i>/ Graph Test A.1: Active power limitation in coincidence with external command coming from the Electricity Distributor</i>							




**Grafico Test A.2: Limitazione della potenza attiva in risposta a comando esterno**  
/ Graph Test A.2: Active power limitation in coincidence with external command coming from the Electricity Distributor



**Grafico Test B.1: Limitazione della potenza attiva in risposta a comando esterno**  
/ Graph Test B.1: Active power limitation in coincidence with external command coming from the Electricity Distributor




**Grafico Test B.2: Limitazione della potenza attiva in risposta a comando esterno**  
/ Graph Test B.2: Active power limitation in coincidence with external command coming from the Electricity Distributor



### 8.8.6.1

#### Nbis. 8 - VFRT Capability / VFRT Capability

Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"



#### Supplementary information:

Test is performed in the following conditions:

- Output Voltage: 230Vac p-n @ 50Hz

Sample Rate Data Acquisition= 200k Sample/sec

Undersampling= 0.0001 sec


MovingAverage= 0.0100 sec

Average= 0.0100 sec

TABLE Nbis.8 Output power: 25000W				Limit: from 10 % to 30% P <sub>max</sub> .					
Test	Residual magnitude [VVn]			phase angle [°]			Duration [ms]	Recover y time [ms]	Recovery time limit [ms]
	R	S	T	φ <sub>1</sub>	φ <sub>2</sub>	φ <sub>3</sub>			
1s – guasto simmetrico trifase / three phases symmetric failure	0.10 ± 0.05	0.10 ± 0.05	0.10 ± 0.05	0°	-120°	120°	200 ± 20	100	400
1a -- guasto asimmetrico bifase / two phases asymmetric failure	0.87 ± 0.05	0.87 ± 0.05	0.10 ± 0.05	27°	-147°	120°	200 ± 20	102	400
2s – guasto simmetrico trifase / three phases symmetric failure	0.25 ± 0.05	0.25 ± 0.05	0.25 ± 0.05	0°	-120°	120°	400 ± 20	110	400
2a -- guasto asimmetrico bifase / two phases asymmetric failure	0.88 ± 0.05	0.88 ± 0.05	0.25 ± 0.05	22°	-142°	120°	400 ± 20	102	400
3s – guasto simmetrico trifase / three phases symmetric failure	0.50 ± 0.05	0.50 ± 0.05	0.50 ± 0.05	0°	-120°	120°	850 ± 20	104	400
3a -- guasto asimmetrico bifase / two phases asymmetric failure	0.90 ± 0.05	0.90 ± 0.05	0.50 ± 0.05	14°	-134°	120°	850 ± 20	107	400
4s – guasto simmetrico trifase / three phases symmetric failure	0.75 ± 0.05	0.75 ± 0.05	0.75 ± 0.05	0°	-120°	120°	1300 ± 20	134	400
4a -- guasto simmetrico bifase / two phases asymmetric failure	0.94 ± 0.05	0.94 ± 0.05	0.75 ± 0.05	7°	-127°	120°	1300 ± 20	107	400
5 OV1 - three-phase symmetrical overvoltage	1.25 ± 0.05	1.25 ± 0.05	1.25 ± 0.05	0°	-120°	120	100 ± 20	114	400
6 OV2 - three-phase symmetrical overvoltage	1.20 ± 0.05	1.20 ± 0.05	1.20 ± 0.05	0°	-120°	120	500 ± 20	142	400




**Test 1a -- guasto asimmetrico bifase**  
*/ two phases asymmetric failure*







## Test 2s -- guasto simmetrico trifase / three phases symmetric failure



## Test 2a -- guasto asimmetrico bifase / two phases asymmetric failure



**Test 3s – guasto simmetrico trifase**  
*/ three phases symmetric failure*







**Test 3a -- guasto asimmetrico bifase**  
/ two phases asymmetric failure



## Test 4s -- guasto simmetrico trifase / three phases symmetric failure










Output power: 125000W				Limit: from > 90% P <sub>3max</sub>					
Test	Residual magnitude [V/Vn]			phase angle [°]			Duration [ms]	Recover y time [ms]	Recovery time limit [ms]
	R	S	T	φ <sub>1</sub>	φ <sub>2</sub>	φ <sub>3</sub>			
1s – guasto simmetrico trifase / three phases symmetric failure	0.10 ± 0.05	0.10 ± 0.05	0.10 ± 0.05	0°	-120°	120°	200 ± 20	121	400
1a – guasto asimmetrico bifase / two phases asymmetric failure	0.87 ± 0.05	0.87 ± 0.05	0.10 ± 0.05	27°	-147°	120°	200 ± 20	181	400
2s – guasto simmetrico trifase / three phases symmetric failure	0.25 ± 0.05	0.25 ± 0.05	0.25 ± 0.05	0°	-120°	120°	400 ± 20	174	400
2a – guasto asimmetrico bifase / two phases asymmetric failure	0.88 ± 0.05	0.88 ± 0.05	0.25 ± 0.05	22°	-142°	120°	400 ± 20	152	400
3s – guasto simmetrico trifase / three phases symmetric failure	0.50 ± 0.05	0.50 ± 0.05	0.50 ± 0.05	0°	-120°	120°	850 ± 20	188	400
3a – guasto asimmetrico bifase / two phases asymmetric failure	0.90 ± 0.05	0.90 ± 0.05	0.50 ± 0.05	14°	-134°	120°	850 ± 20	245	400
4s – guasto simmetrico trifase / three phases symmetric failure	0.75 ± 0.05	0.75 ± 0.05	0.75 ± 0.05	0°	-120°	120°	1300 ± 20	250	400
4a – guasto simmetrico bifase / two phases asymmetric failure	0.94 ± 0.05	0.94 ± 0.05	0.75 ± 0.05	7°	-127°	120°	1300 ± 20	245	400
OV1 - three-phase symmetrical overvoltage	1.25± 0.05	1.25± 0.05	1.25± 0.05	0°	-120°	120	100± 20	257	400
OV2 - three-phase symmetrical overvoltage	1.20± 0.05	1.20± 0.05	1.20± 0.05	0°	-120°	120	500± 20	284	400

Grafici: LVFRT


/ Graphs: LVFRT

Test 1s -- guasto simmetrico trifase

/ three phases symmetric failure




%	A	B	FIG
FIR(x)	03232988	81248881	021753
AC-U1(A)	28.2017	8.80213	-26.8988
AC-U1(B)	-227.0803	3233374	238.3136
AC-U1(C)	377.8200	-4.06088	-211.8887
AC-U2(A)	302.8944	-25.3713	-81.8019
AC-U2(B)	-255.0285	5.25013	208.9031
AC-U2(C)	385.7947	28.4580	-248.2591
W1_IRMS_w@POWER AC (V)	228.8866	23.1788	-206.7081
W2_IRMS_w@POWER AC (V)	228.5284	23.2168	-206.3402
W3_IRMS_w@POWER AC (V)	229.7700	23.2287	-206.5794
W4_IRMS_w@POWER AC (A)	382.8182	6.18887	-178.8823
W5_IRMS_w@POWER AC (A)	378.5320	5.41887	-175.0186
W6_IRMS_w@POWER AC (A)	382.1717	5.28287	-178.8883
P_1_w@POWER AC (W)	124541.5	-21.1648	-134564.8
S_1_w@POWER AC (VA)	12488.1	1347814	-134884.4




%	A	B	FIG
FIR(x)	03244138	81280374	012838
AC-U1(A)	3.81978	-88.1418	-88.8113
AC-U1(B)	3.88533	-175.838	-181.728
AC-U1(C)	-5.81325	233.271	238.424
AC-U2(A)	-45.3786	-81.3233	-86.2384
AC-U2(B)	-17.7184	252.7824	-215.027
AC-U2(C)	503.820	186.028	178.002
W1_IRMS_w@POWER AC (V)	25.1775	128.447	208.281
W2_IRMS_w@POWER AC (V)	23.2168	228.886	206.788
W3_IRMS_w@POWER AC (V)	23.2287	229.525	206.028
W4_IRMS_w@POWER AC (A)	6.18887	183.871	178.337
W5_IRMS_w@POWER AC (A)	5.41887	179.528	177.028
W6_IRMS_w@POWER AC (A)	5.28287	183.883	178.888
P_1_w@POWER AC (W)	-33.1183	13456.3	13443.7
S_1_w@POWER AC (VA)	206.988	12488.1	134884.4



**Test 1a -- guasto asimmetrico bifase**  
/ two phases asymmetric failure




%	A	B	FIN
VIR (V)	812.89119	813.06352	822.143
AC-U1 (V)	368.9768	4.82862	-288.1382
AC-U2 (V)	6.307893	-8.353646	-4.081736
AC-U3 (V)	-192.1455	-2.998487	208.2548
AC-U1 (V)	388.5862	-242.2796	-258.7596
AC-U2 (V)	-273.8329	126.0273	497.8382
AC-U3 (V)	-34.8692	16.4129	11.4654
U1_IRMS_n@POWER-AC (V)	238.0897	191.4212	-40.81949
U2_IRMS_n@POWER-AC (V)	218.6323	193.0007	-20.88462
U3_IRMS_n@POWER-AC (V)	224.5511	23.27388	-205.6742
I1_IRMS_n@POWER-AC (A)	172.1868	4.828588	-387.6321
I2_IRMS_n@POWER-AC (A)	254.1176	4.400471	-249.0079
I3_IRMS_n@POWER-AC (A)	286.7302	-2.528388	-178.9641
P_1_n@POWER-AC (W)	32456.1	-1302.683	-305318.2
S_1_n@POWER-AC (VA)	318955.1	1205.839	-213681.2




%	A	B	FIN
VIR (V)	813.06359	813.24618	820.224
AC-U1 (V)	3.786878	-86.88132	-86.88132
AC-U2 (V)	-1.188997	-150.6196	-148.5527
AC-U3 (V)	-5.911475	254.9641	258.4095
AC-U1 (V)	-86.65295	-122.5193	-21.36224
AC-U2 (V)	82.42854	205.8548	-207.1796
AC-U3 (V)	36.21863	318.1741	268.6543
U1_IRMS_n@POWER-AC (V)	393.4445	231.0778	31.83339
U2_IRMS_n@POWER-AC (V)	107.6805	230.8264	11.52886
U3_IRMS_n@POWER-AC (V)	23.27381	229.5205	206.2496
I1_IRMS_n@POWER-AC (A)	4.821268	181.0884	178.8181
I2_IRMS_n@POWER-AC (A)	4.612772	171.9655	173.1257
I3_IRMS_n@POWER-AC (A)	3.758397	181.0887	178.8183
P_1_n@POWER-AC (W)	-1576.435	12451.03	115894.0
S_1_n@POWER-AC (VA)	3921.189	124937.7	22948.8



**Test 2s -- guasto simmetrico trifase**  
/ three phases symmetric failure




Simbolo	A	B	PIU'
PIU' (%)	0.0284975	0.1105440	0.40511
AC-U1 (A)	-178.1866	1.81864	383.826
AC-U2 (A)	-75.17939	5.81508	75.95987
AC-U3 (A)	254.5725	-5.064540	264.0771
AC-U1 (V)	-317.5662	-76.78923	347.8780
AC-U2 (V)	-138.5302	1.841578	302.9777
AC-U3 (V)	547.3466	67.00229	-248.4566
W1_1RMS_00@POWER-AC (W)	229.9079	57.01754	-172.8038
W2_1RMS_00@POWER-AC (W)	228.5223	68.0022	172.5287
W3_1RMS_00@POWER-AC (W)	229.4188	57.00294	-172.6380
I1_1RMS_00@POWER-AC (A)	383.8897	3.889752	-178.4280
I2_1RMS_00@POWER-AC (A)	178.1845	2.402819	-175.0700
I3_1RMS_00@POWER-AC (A)	380.1819	3.801868	-178.8888
P_1_00@POWER-AC (W)	124528.4	-184.3780	-124753.8
S_1_00@POWER-AC (VA)	124528.5	185.5708	-124753.1



Simbolo	A	B	PIU'
PIU' (%)	0.02504008	0.11219027	0.178022
AC-U1 (A)	4.876752	-18.88823	-22.88888
AC-U2 (A)	3.516425	126.0209	215.4885
AC-U3 (A)	-4.795849	205.8376	-299.1429
AC-U1 (V)	-75.40812	-88.73405	45.68077
AC-U2 (V)	11.11843	296.8941	265.1057
AC-U3 (V)	64.76127	400.4202	-124.2284
W1_1RMS_00@POWER-AC (W)	57.81754	282.1199	175.1184
W2_1RMS_00@POWER-AC (W)	26.26822	231.6203	174.9168
W3_1RMS_00@POWER-AC (W)	57.80004	232.1561	175.1481
I1_1RMS_00@POWER-AC (A)	3.889758	178.3894	178.9488
I2_1RMS_00@POWER-AC (A)	1.412813	176.2328	175.7260
I3_1RMS_00@POWER-AC (A)	3.888982	178.3399	178.8796
P_1_00@POWER-AC (W)	-184.3700	184.1704	-124254.6
S_1_00@POWER-AC (VA)	185.5700	184.2659	-123878.5




**Test 2a -- guasto asimmetrico bifase**  
/ two phases asymmetric failure






**Test 3s -- guasto simmetrico trifase**  
/ three phases symmetric failure




Id	A	B	PHI
V1R [V]	022.80098	0.19478118	0.89633
AC11 [A]	-971.0281	8.27890	118.3881
AC12 [A]	258.0336	-1.550645	-257.5680
AC13 [A]	138.6790	-9.448748	338.4738
AC41 [A]	-473.5731	188.7308	302.0981
AC42 [A]	327.4121	48.27407	-271.5080
AC43 [A]	-173.4602	-160.2768	268.1076
V1_1RMS_rms@POWER-AC [V]	228.9217	114.0908	-115.1389
V2_1RMS_rms@POWER-AC [V]	228.9218	114.0268	114.0268
V3_1RMS_rms@POWER-AC [V]	228.9223	114.7235	-115.1088
I1_1RMS_rms@POWER-AC [A]	381.8887	8.287828	-277.8208
I2_1RMS_rms@POWER-AC [A]	178.1970	5.824841	-275.2708
I3_1RMS_rms@POWER-AC [A]	882.3480	8.887818	-178.8388
P_T_rms@POWER-AC [W]	124278.5	-752.7330	-115299.1
S.L_rms@POWER-AC [VA]	134034.0	1386.892	-213907.7




Id	A	B	PHI
V1R [V]	022.80098	0.19478118	0.89633
AC11 [A]	-971.0281	8.27890	118.3881
AC12 [A]	258.0336	-1.550645	-257.5680
AC13 [A]	138.6790	-9.448748	338.4738
AC41 [A]	-473.5731	188.7308	302.0981
AC42 [A]	327.4121	48.27407	-271.5080
AC43 [A]	-173.4602	-160.2768	268.1076
V1_1RMS_rms@POWER-AC [V]	228.9217	114.0908	-115.1389
V2_1RMS_rms@POWER-AC [V]	228.9218	114.0268	114.0268
V3_1RMS_rms@POWER-AC [V]	228.9223	114.7235	-115.1088
I1_1RMS_rms@POWER-AC [A]	381.8887	8.287828	-277.8208
I2_1RMS_rms@POWER-AC [A]	178.1970	5.824841	-275.2708
I3_1RMS_rms@POWER-AC [A]	882.3480	8.887818	-178.8388
P_T_rms@POWER-AC [W]	124278.5	-752.7330	-115299.1
S.L_rms@POWER-AC [VA]	134034.0	1386.892	-213907.7



**Test 3a -- guasto asimmetrico bifase**  
/ two phases asymmetric failure




Id	A	B	FIN
IPR [A]	002612773	812597183	0.80000
AC I1 [A]	-36.98811	1.828811	37.81204
AC I2 [A]	76.25505	3.570491	-74.88515
AC I3 [A]	44.97204	0.242979	45.21901
AC U1 [V]	188.6282	273.4883	84.60086
AC U2 [V]	22.88891	-121.8139	-204.8578
AC U3 [V]	-307.6864	96.42880	31.87531
W1_1RMS_w@POWER AC [W]	238.1334	136.4604	-15.80499
W1_1RMS_w@POWER AC [W]	308.9700	186.2637	-22.80726
W2_1RMS_w@POWER AC [W]	229.9847	114.7252	-115.1795
U1_1RMS_u@POWER AC [V]	383.8796	6.533382	-277.8881
U1_1RMS_u@POWER AC [V]	178.6940	5.845257	-174.6487
U2_1RMS_u@POWER AC [V]	180.8238	8.821882	-178.9889
P_1_w@POWER AC [W]	124028.4	-1274.788	-125833.1
S_1_w@POWER AC [VA]	124757.8	1985.203	-122814.6




Id	A	B	FIN
IPR [A]	0122854387	813179395	0.24800
AC I1 [A]	-4.898881	188.8887	187.8881
AC I2 [A]	5.802922	71.00618	85.87526
AC I3 [A]	0.131418	286.1187	-286.8781
AC U1 [V]	307.4886	180.0065	-47.26213
AC U2 [V]	-298.6734	97.90278	304.2590
AC U3 [V]	1616.890	-321.8886	-128.5486
W1_1RMS_w@POWER AC [W]	208.4815	211.5223	25.35881
W1_1RMS_w@POWER AC [W]	208.3626	180.0627	44.80221
W2_1RMS_w@POWER AC [W]	114.7251	251.6838	118.5581
U1_1RMS_u@POWER AC [V]	6.211783	180.2881	178.3276
U1_1RMS_u@POWER AC [V]	5.802930	177.0079	173.1040
U2_1RMS_u@POWER AC [V]	6.807833	180.8888	177.2088
P_1_w@POWER AC [W]	-1275.515	124520.5	115706.0
S_1_w@POWER AC [VA]	3281.978	124757.8	122814.7



## Test 4s -- guasto simmetrico trifase / three phases symmetric failure




%	A	B	PK
PIR (%)	0.1369788	0.14402182	1.011273
AC-U1 (V)	-80.8815	-81.0888	397.3728
AC-U2 (V)	294.4255	18.25218	-216.3795
AC-U3 (V)	-49.11811	31.15329	79.54055
AC-I1 (A)	-258.1135	500.1347	568.2077
AC-I2 (A)	301.1741	-732.3895	-533.6078
AC-I3 (A)	-60.26594	-94.18846	-23.80254
W1_IRMS_W@POWER AC (W)	225.9108	175.0849	-51.91284
W2_IRMS_W@POWER AC (W)	225.9400	180.2925	-60.20811
W3_IRMS_W@POWER AC (W)	225.4154	171.2859	-51.53551
U1_IRMS_U@POWER AC (V)	180.8137	33.30057	-388.8687
U2_IRMS_U@POWER AC (V)	173.4445	29.77819	-343.7061
U3_IRMS_U@POWER AC (V)	182.4829	14.88889	-384.8883
P_T_W@POWER AC (W)	123548.7	-5613.985	-131883.7
S.L.W@POWER AC (VA)	123907.0	18292.67	-213904.8




%	A	B	PK
PIR (%)	0.1468254	0.1468236	0.240972
AC-U1 (V)	5.208718	136.2094	238.0388
AC-U2 (V)	51.39625	110.5768	306.4786
AC-U3 (V)	-5.408830	-263.8020	209.9311
AC-I1 (A)	-228.8750	172.5961	362.5711
AC-I2 (A)	118.7770	156.8608	274.5485
AC-I3 (A)	242.6942	327.8673	609.6238
W1_IRMS_W@POWER AC (W)	172.0903	291.1105	89.40387
W2_IRMS_W@POWER AC (W)	172.6832	287.7284	56.73541
W3_IRMS_W@POWER AC (W)	172.1336	231.0812	59.81783
U1_IRMS_U@POWER AC (V)	5.218320	180.7963	278.6128
U2_IRMS_U@POWER AC (V)	5.947300	172.1405	263.0485
U3_IRMS_U@POWER AC (V)	5.131738	181.2841	277.2623
P_T_W@POWER AC (W)	-234.762	12353.9	11974.7
S.L.W@POWER AC (VA)	295.377	12395.4	22995.0



### Test 4a -- guasto simmetrico bifase / two phases asymmetric failure




Ch	A	B	RMS
HPV [V]	0.0247958	0.1840327	1.02791
AC-U [A]	302.491	-8.00326	-218.0981
AC-V [A]	-302.3478	-11.20052	251.0073
AC-I1 [A]	127.0167	9.21839	-217.8045
AC-U1 [A]	304.0577	36.89961	-367.1136
AC-U2 [A]	-296.1823	382.0799	870.3230
AC-U3 [A]	66.03219	-266.2794	-368.4122
W1_1RMS [W]@POWER AC [W]	258.4390	221.9008	8.154517
W2_1RMS [W]@POWER AC [W]	227.8230	226.8696	-7.962517
W3_1RMS [W]@POWER AC [W]	227.6741	195.0203	30.84571
U1_1RMS [V]@POWER AC [V]	191.7389	184.6668	-171.1888
U2_1RMS [V]@POWER AC [V]	351.1904	14.67811	-368.5020
U3_1RMS [V]@POWER AC [V]	186.1887	28.88883	-388.8881
P_T [W]@POWER AC [W]	124118.5	-5113.442	-15801.8
S_L [VA]@POWER AC [VA]	17807.3	995.498	-118741.8




Ch	A	B	RMS
HPV [V]	0.01546167	0.1366666	0.246132
AC-U [A]	0.38827	-247.8933	-247.7624
AC-V [A]	-15.45204	118.0711	118.1040
AC-I1 [A]	11.26427	134.6777	212.6134
AC-U1 [A]	-0.894853	-325.6519	-314.7478
AC-U2 [A]	279.9755	140.1845	-333.7708
AC-U3 [A]	265.0376	181.6644	-462.6020
W1_1RMS [W]@POWER AC [W]	221.9008	311.4647	8.181070
W2_1RMS [W]@POWER AC [W]	226.8696	226.8697	30.83286
W3_1RMS [W]@POWER AC [W]	198.5205	131.4213	34.48383
U1_1RMS [V]@POWER AC [V]	351.1880	180.6988	278.6281
U2_1RMS [V]@POWER AC [V]	14.67811	176.5705	262.1094
U3_1RMS [V]@POWER AC [V]	30.88883	181.0818	368.9032
P_T [W]@POWER AC [W]	-5113.442	12444.1	11952.5
S_L [VA]@POWER AC [VA]	995.498	12495.4	114743.6




## OV1 - three-phase symmetrical overvoltage



№	A	B	FIN
TIME (s)	0:15:00:590	0:15:00:900	0:15:01:240
AC-U1 (V)	328.1184	28.89833	-75.82027
AC-U2 (V)	-107.3802	-82.46084	86.83130
AC-U3 (V)	79.80233	32.84543	-40.03070
AC-U1 (V)	350.6030	130.0549	-218.9081
AC-U2 (V)	470.5833	372.5036	80.8723
AC-U3 (V)	350.6106	130.0603	-218.9090
U1_1RMS_rms@POWER AC (V)	238.1344	186.2844	56.00081
U2_1RMS_rms@POWER AC (V)	234.5889	182.2682	47.83371
U3_1RMS_rms@POWER AC (V)	232.6405	184.1329	51.44268
I1_1RMS_rms@POWER AC (A)	183.6633	7.278084	-275.0789
I2_1RMS_rms@POWER AC (A)	108.5312	15.02798	-253.7536
I3_1RMS_rms@POWER AC (A)	179.8802	12.88818	-187.2381
P_1_rms@POWER AC (W)	122064.4	-1718.653	-123814.3
S_1_rms@POWER AC (VA)	323580.0	18003.48	-519512.2




№	A	B	FIN
TIME (s)	0:15:49:2321	0:15:50:080	0:15:51:581
AC-U1 (V)	-4.842318	-230.8882	-217.1489
AC-U2 (V)	6.197880	6.717905	-2.460776
AC-U3 (V)	-4.812345	210.6448	211.4771
AC-U1 (V)	-32.78802	-279.5513	-208.7487
AC-U2 (V)	-312.0820	-1.174807	308.8848
AC-U3 (V)	276.0700	281.3833	-84.75280
U1_1RMS_rms@POWER AC (V)	338.5425	229.0239	-86.42345
U2_1RMS_rms@POWER AC (V)	308.4611	325.5517	16.83246
U3_1RMS_rms@POWER AC (V)	188.6300	129.6367	-56.70036
I1_1RMS_rms@POWER AC (A)	8.881881	181.8888	178.0738
I2_1RMS_rms@POWER AC (A)	7.411810	174.0705	207.1580
I3_1RMS_rms@POWER AC (A)	8.131886	183.0247	178.3484
P_1_rms@POWER AC (W)	-1571.935	12375.3	127946.0
S_1_rms@POWER AC (VA)	3081.811	120031.8	718008.6






<b>Nbis.9 Verifica della insensibilità alle richiuse automatiche in discordanza di fase</b> <i>Check of the insensibility to the re-closures when phases are in discordance</i>	
<input checked="" type="checkbox"/> Nbis.9.1 - Test on simulated grid <input type="checkbox"/> Nbis.9.2 - Test on distribution grid through coupler transformer	
Ambient temperature (°C) .....	25 °C ± 5 °C
Humidity (RH %) .....	65%
Instrumentation list.....	See table "Measurement equipment and instrumentation"
Supplementary information: none	
Operator .....	See cover page
Supervisor .....	See cover page
Test Date.....	See cover page


**Test 1a: 0°~ -90° @ 100% of Nominal Power**




## Test 1b: 0°~ 90° @ 100% of Nominal Power




**Test 1c: 0°~180° @ 100% of Nominal Power**



## Test 2a: 0°~ 90° @ 50% of Nominal Power




### Test 2b: 0°~ 90° @ 50% of Nominal Power







**Test 2c: 0°~180° @ 50% of Nominal Power**




## Test 2d: 0°~ -180° @ 50% of Nominal Power




### Test 3a: 0°~ 90° @ 10% of Nominal Power




### Test 3b: 0°~ -90° @ 10% of Nominal Power



### Test 3c: 0°~180° @ 10% of Nominal Power



### Test 3d: 0°~ -180° @ 10% of Nominal Power






Allegato Z – Variante 2			
Regolazioni del sistema di protezione dei gruppi generatori			
<i>Settings of the protection system for groups of generators</i>			
<b>c) Generatori statici FV / Static PV converters</b>			
Ambient temperature (°C) .....	:	25 °C	
Humidity (RH %) .....	:	35 %	
Instrumentation list .....	:	See table "Measurement equipment and instrumentation"	
<b>SETTING:</b>			
Protezione		Soglia di intervento	Tempo di intervento
Minima tensione 27	S1	$\leq 0,85 V_{Nl}$	$\geq 1,5 s$
	S2	$\leq 0,15 V_{Nl}$	$\geq 0,2 s$
Massima tensione 59	S1	$\geq 1,15 V_{Nl}$	$\geq 0,5 s$
	S2	$\geq 1,20 V_{Nl}$	$\geq 0,1 s$
Minima frequenza 81<	S1	$\leq 47,5 Hz$	$\geq 4,0 s$
	S2	$\leq 46,5 Hz$	$\geq 0,1 s$
Massima frequenza 81>	S1	$\geq 51,5 Hz$	$\geq 1,0 s$
	S2	$\geq 52,5 Hz$	$\geq 0,1 s$

### Over Voltage (Ph-N)


V $\phi$ -n nom = 230.0 Vac	Limit (At least)		Settings		Results	
OV>>	Voltage [Vac]	Time [s]	Voltage [Vac]	Time [s]	Voltage [Vac]	Time [s]
L1-L2-L3-N	276.0	0.100	276.0	0.100	276.66	0.193
OV>	Voltage [Vac]	Time [s]	Voltage [Vac]	Time [s]	Voltage [Vac]	Time [s]
L1-L2-L3-N	264.5	0.500	264.5	0.500	264.60	0.610

(\*) Value due to an Hardware limit of the inverter.













### UV< - Trip time






## Over Frequency



F nom = 50.00 Hz	Limit (At least)		Settings		Results	
	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
Over Frequency >>	52.50	0.100	52.50	0.100	52.50	0.235
Over Frequency >	51.50	1.000	51.50	1.000	51.50	1.303







## Under Frequency

F nom = 50.00 Hz	Limit (At least)		Settings		Results	
	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]	Frequency [Hz]	Time [s]
Under Frequency <	47.50	4.000	47.50	4.000	47.50	4.045
Under Frequency <<	46.50	0.100	46.50	0.100	46.49	0.259





-TEST REPORT END-

**Model: SOLID POWER HV 261**



Energy Storage System (Front view)



Energy Storage System (Back view)

**Model: SOLID POWER HV 261**



Energy Storage System (Left view)



Energy Storage System (Right view)

**Model: SOLID POWER HV 261**



Energy Storage System (Open view)




Battery Pack

**Model: SOLID POWER HV 261**



Battery control box



Battery Pack (Top view)

**Model: SOLID POWER HV 261**



**Battery Pack (Right view)**




**Battery Pack (Left view)**

**Model: SOLID POWER HV 261**



**Battery Pack (Front view)**



**Battery Pack (Back view)**

**Model: SOLID POWER HV 261**



**Battery pack (inside view)**