

# Recalled Switch Board Equipment as of July 2019

This may not be a full list of the types of recalled electrical equipment found in typical domestic switchboards.

## Faulty Cable

All INFINITY branded TPS & Orange Round Electrical Cables - inspect the cable for brand marking



Arlec TPS 1.00mm<sup>2</sup> Core Flat Electrical Cable - Code 8010 - inspect the cable for brand and identifier

SKL TPS VVF2C1 1.5mm<sup>2</sup> / 1.5mm<sup>2</sup> / 2.5mm<sup>2</sup> / 4mm<sup>2</sup> / 6mm<sup>2</sup> / 10mm<sup>2</sup> / 16mm<sup>2</sup>- inspect only marked 2013

## Faulty RCBO

### ELECTRICAL SAFETY RECALL

**Single module RCBO (combination RCD & MCB)  
Hager 'mono' range  
AD310T, AD316T, AD320T & AD325T**

**Identification:**  
Products affected include:  
AD310T - 1 module RCBO 10A 30mA  
AD316T - 1 module RCBO 16A 30mA  
AD320T - 1 module RCBO 20A 30mA  
AD325T - 1 module RCBO 25A 30mA

These products have been sold nationally from July 2010.

No other Hager branded RCBO's are affected by this recall.

**Hazard:**  
Risk of electrical shock.

**Action required:**  
Electrical wholesalers and electrical contractors are advised to stop selling and/or installing the above products and contact Hager Electro Pty Ltd to arrange return of their stock and/or replacement of the installed products.

Please visit [www.hagerselectro.com.au/8862.htm](http://www.hagerselectro.com.au/8862.htm) for more information or to register the location of RECALLED RCBO's.



See [www.recalls.gov.au](http://www.recalls.gov.au) for Australia Product Recalls Information

### ELECTRICAL SAFETY RECALL

**Residual Current Device (RCD)**  
Brand name Dielle, Model YK78, Approval mark N.21905



**DEFECT:**  
RCD may fail product standard test requirements. Approval mark N 21905 is not valid.

**IDENTIFICATION:**  
RCD product marked with 'Dielle', 'YK78' and 'N 21905' - see above photos. Product sold from 2006 onwards.

**HAZARD:**  
Potential risk to persons or property of electric shock or fire.

**ACTION REQUIRED:**  
Recalled product needs to be replaced with an alternative RCD that has a valid Australian approval mark.

**CONTACT DETAILS:**  
For further information please direct any queries concerning this recall to Dielle Electrical Distributors Pty Ltd via email at [dielle.electrical@bigpond.com](mailto:dielle.electrical@bigpond.com) or by post (addressed to Dielle Electrical Distributors Pty Ltd, C/- 78 Grange Road, Welland SA 5007).

See [www.productsafety.gov.au](http://www.productsafety.gov.au) for Australian product recall information

### ELECTRICAL SAFETY RECALL

**Electrical components sold within 'SmartSpace' Kit Homes**



**IDENTIFICATION:**  
Cable  
SRF CABLE 1.5mm<sup>2</sup> V90 450/750V TO AS/NZS 5000.2 YAFEI  
SRF CABLE 3 x 2.5mm<sup>2</sup> 450/750V V90 TO AS/NZS 5000.2 YAFEI  
SRF CABLE 3 x 1.5mm<sup>2</sup> 450/750V V90 TO AS/NZS 5000.2 YAFEI  
Circuit Breaker and Residual Current Device (RCD)  
Marked JVM21-63 C 16 240/415V-  
Marked RCBO JVL5 C16 30mA 240V-

The products were sold by Bunnings in Australia as part of the 'SmartSpace' Kit Homes prior to July 2015. This recall does not affect SmartSpace Kit Homes that were purchased after July 2015. No other product is affected.

The various electrical components supplied with the 'SmartSpace' Kit Homes were not sold separately.

**HAZARD:**  
The cables have failed some of the required ageing tests of AS/NZS 5000.2. The insulation could become prematurely brittle with age. If the insulation becomes brittle and the cables are disturbed, the insulation could break and expose live conductors, resulting in possible electric shock or fires. The circuit breaker and RCD do not pose a safety risk, however these components are not approved for sale in Australia.

**ACTION REQUIRED:**  
Home occupiers who are concerned that these components have been used in their homes should contact the SmartSpace support team on the details below. The SmartSpace support team will arrange for a licensed electrician to inspect their home and replace the affected electrical components.

**For further information**  
Ph. 1300 985 110 or email [info@smartspacehomes.com.au](mailto:info@smartspacehomes.com.au)  
See [www.productsafety.gov.au](http://www.productsafety.gov.au) for Australian product recall information

### Product Safety Recall

Items bought between 16/09/2010 to 5/11/2010.

**Mack & Lanson Branded Combination RCD & MCB (RCBO)**  
Part No.'s MRR-H10C, MRR-H16C, MRR-H-20C, MRRH-25C, MRRH-32C and LANRCBO610SA, LANRCBO616SA LANRCBO620SA, LANRCBO625SA LANRCBO632SA sold from Electrical Wholesalers through the period 16/09/2010 to 5/11/2010.

**Defect:** The product fails the 6Ka short circuit test.

**Hazard:** Following a rare high fault current event at full rated capacity, the RCBO may pose an electrical shock risk.

**What to do:** Contact Electrical Product systems to arrange to have the items replaced. Electrical Product Systems will liaise with you as to the installation costs, return of the faulty products along with receipt of a Certificate of Electrical Safety (or equivalent depending on the requirements of the Electrical Authority in your area) to demonstrate the items have been installed. On completion, the relevant electrical authorities will be advised and the faulty items destroyed.

**Contact Details:** Contact "Electrical Product Systems" via the internet at [www.rcborecall.com.au](http://www.rcborecall.com.au) or alternatively contact by phone on 03 9862 4234.



A list of all electrical recalled products can be found at <https://www.productsafety.gov.au/recalls>