













Mfg./Mkted. all types of Fire Extinguishers, Fire Fighting Equipment, CC TV

Spl. in Refilling & Maintenance Contractor

Corporate Office: 38A, Shrinagar Extension, Near Chandralok Square, Behind SNS Hospital, Khajrana Main Road, Indore - 452018 (MP) Email::support@firenetindia101.com, Web.: www.firenetindia101.com

Phone No.: 0731-4063151, Mob.: 88895-91888 Mobile No.: 88899-97672, 88893-03888, 88896-91888

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to: -

M/s. Sahodaya Convent School

CERTIFICATE

Address- Depalpur Main Road, Indore

Inspection Report of fire Extinguisher

Year of Contract	2023-2024	Date-14/06/2023
Certificate No.	FNT/IND/23-24/TSD/21187	
Completion Month	June-2023	
Valid Up to	June-2024	
Warranty for	01–Year	
Details of	ABC Type- Capacity-4 Kgs.	3 Nos.
New/Refilled fire	ABC Type- Capacity-6 Kgs.	4 Nos.
extinguisher	Total Quantity	7 Nos.
Inspection Details Of fire Extinguisher	 Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire. Make sure the instruction label is legible and facing outward. Check to be sure 0the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion or other signs of damage. Look for any modifications to the fire extinguisher that could possibly reduce its functionality. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements. Attach an updated tag or label as a record of proper maintenance. 	
Declaration	We further certify that (FIRE NET) has successfully checked above fire extinguisher	
200037	which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us	

Technical service Department

Signature of the inspector

Head Office: 192/1536, Motha Nagas No. 1, Off. sajal Tower, Goregoan (W) Mumbai - 400104 (M.H.)
Branch Office: 1, Jay Mangai Complex, Opp. HP Petrol Pump, Judges Bunglow Rd., Bodakdev, Ahrnedabad - 380054
Ph.: 079-48410888, Mob.: 96875-33366, 96875-33377, Email: ahmedabad@firenetindia101.com