

UK Property Support Services Ltd
7 Meadow Way
Abbots Langley
Watford
WD5 0RD



e: office@ukpss.uk
t: 01923 518756
w: www.ukpss.uk
Company Registration No13525873 - VAT Registration
No396847526

Job Sheet

20 March 2024

<div></div>	<div>Job Address</div> <div></div>	<div>Job Number</div> <div>UKJB00328</div>
<div></div>	<div>Reference</div> <div></div>	

P/097289

Gable Leak Investigation & Possible Repair

Following a recent call out it was agreed that a 45ft boom lift was required to remove all the plastic covering from the Gable End off the building, once removed then all the lagging will be removed to ascertain exactly where the leak is coming from and then using 90mm pvcu fittings onsite attempt to fix / repair leak.

No lagging has been quoted for within this quotation.

Notes

P/097289

site address

Dintgrade Limited
Estate Office
Gloucester Court,
Kew Road
Richmond
TW9 3DY

Pre Start Picture



1st leak located on the hot water flow

Pipework cut out



Leak located on return pipe at high level on Gable End under roof and at low level on the hot water flow

Failed pipe cut out and replaced with new and allowed to set for 2.5hrs prior to reinstatement



Boilers reinstated to service



Calorifiers reinstated



Pumps reinstated and all operational



Area of works on completion



**All Works Have Been Completed in Line with Agreed Project Specification,
Any Discrepancies Need to Be Brought to the Project Managers Attention Immediately.**

**t: 01923 518765 - e: office@ukpss.uk - w: www.ukpss.uk
Company Registration No13525873 - VAT Registration No396847526**