

Client: DIXON SAND (PENRITH) PTY LTD  
PO BOX 148  
PENRITH NSW 2751

Job No 7555/1  
Date Tested: 29/03/2022  
Tested By: BN  
Checked By: AK

Project: MATERIAL ANALYSIS  
MATERIAL TESTING - 4610 OLD NORTHERN ROAD, MAROOTA

## TEST RESULTS

Page 1 of 1

| TEST PROCEDURE AS1141.11.1 (DRY SIEVING) |                                        |                                             |
|------------------------------------------|----------------------------------------|---------------------------------------------|
| Material Description                     | Coarse SAND                            |                                             |
| Sieve Analysis                           |                                        |                                             |
| Laboratory Number                        | 7555/1-472                             |                                             |
| <u>Sieve Size</u>                        | Percentage Passing                     | Pre-treatment<br>Nil - Standard Oven Drying |
| 9.5mm                                    | 100                                    |                                             |
| 4.75mm                                   | 97                                     |                                             |
| 2.36mm                                   | 85                                     |                                             |
| 1.18mm                                   | 79                                     |                                             |
| 600 microns                              | 66                                     |                                             |
| 300 microns                              | 31                                     |                                             |
| 150 microns                              | 8                                      |                                             |
| 75 microns                               | 1.6                                    |                                             |
| Date Sampled                             | March 2022                             |                                             |
| Sampling Procedure                       | Sampled by Client - Tested as received |                                             |
| Sampling Location                        | Ex Maroota Quarry                      |                                             |

Form No: R 025 Version 05 06/13 - issued by ER



Nata Accreditation Number 2734  
Corporate Site Number 2727

Accredited for compliance with ISO/IEC 17025.

A Kench

01/04/2022

Approved Signatory

Head Office:

34 Borec Road, Penrith NSW 2750

P O Box 880 Penrith NSW 2751

Telephone: (02) 4722 2744 Facsimile: (02) 4722 2777

Prestons Laboratory:

Unit 4, 18-20 Whyalla Place, Prestons NSW 2170

Telephone: (02) 9607 6111 Facsimile: (02) 9607 6200

email: info@geotech.com.au www.geotech.com.au