

Material Test Report

Report Number: 7555/1-4
Issue Number: 2 - This version supersedes all previous issues
Reissue Reason: update
Date Issued: 17/04/2025
Client: DIXON SAND (PENRITH) PTY LTD
 , PENRITH NSW 2751
Contact: Michael Munnoch
Project Number: 7555/1
Project Name: MATERIAL ANALYSIS MATERIAL TESTING - 4610 OLD
 NORTHERN ROAD, MAROOTA
Work Request: 596
Sample Number: S-596E
Date Sampled: 04/04/2025
Dates Tested: 04/04/2025 - 15/04/2025
Sampling Method: Sampled by Client
The results apply to the sample as received
Preparation Method: AS 1289.1.1 - Sampling and Preparation of Soils
Sample Location: Dixon Sand
Material: Coarse Sand April



Geotech Testing Pty Ltd
 Penrith Laboratory
 34 Borec Road Penrith NSW 2750
 Phone: (02) 4722 2744
 Email: matthew@geotech.com.au



Accredited for compliance with ISO/IEC 17025 - Testing

Approved Signatory: Mathew Morley
 Laboratory Manager
 NATA Accredited Laboratory Number: 2734

Particle Size Distribution (AS1289 3.6.1)				
Sieve	Passed %	Passing Limits	Retained %	Retained Limits
75 mm	100		0	
63 mm	100		0	
53 mm	100		0	
37.5 mm	100		0	
26.5 mm	100		0	
19 mm	100		0	
4.75 mm	99		1	
2.36 mm	93		7	
1.18 mm	89		3	
0.6 mm	76		13	
0.425 mm	51		26	
0.3 mm	27		23	
0.15 mm	6		22	
0.075 mm	1		5	

