

Phone (770) 893-2271

This sample taken by M. Scott Webb at 4:30:00 PM on 7/27/2022. . Point of collection: Kitchen Sink

### FHA Basic Water Scan Plus

<u>Analytes</u>	<u>Results</u>	<u>Description</u>	<u>EPA Limits</u>
<b><u>Bacteria</u></b>			
Total Coliform	Present	There should be no Coliform bacteria in the sample.	0
E. Coli	Absent	Known to Cause Illness	0
<b><u>Mineral Chemistry</u></b>			
Iron	0.14 mg/L	Brown Stains, Bitter Taste	0.30 mg/L
Lead	Not Detected	A Toxic Metal, From Plumbing Components	0.015 mg/L
pH	7.94 SU	Acid/Basic Determination	6.5 - 8.5 SU
Turbidity	1.67 N.T.U.	Presence of Particles/Measure of Cloudiness	No Limit
Nitrate as Nitrogen	Not Detected	Indicator of Biological Waste	10.0 mg/L
Nitrite as Nitrogen	Not Detected	Indicator of Waste	1.0 mg/L
Total Nitrate/Nitrite Nitrogen	Not Detected	Total Nitrate and Total Nitrite	10 mg/L