



ANNEXURE - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2357

Dated : 15 May 2026


It is certified that an inspection team headed by Pardeep Kumar

Junior Engineer (Name of officers with designation)

From Sub Divisional, No 2, Water, Hygiene & Sanitation Inspected the Angel's Public School, Dalhousie Road, Mamun, Pathankot (Punjab) (Name & Address of the school) on 06 May 26 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. DWTLPK/22700037/ dated 07 May 26 of (PHED Lab)

Certified that the Angel's Public School, Dalhousie Road, Mamun, Pathankot (Punjab) (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T Govt.

This certificate is valid till 14 May 2027.

Signature with Seal: 

Name :

Sukhjeet Singh

Executive Engineer,
W/S & Sanitation Division
PATHANKOT.

Sub Division


No 2, J/S Sanitary, Pathankot

To

Angel's Public School
Dalhousie Road, Mamun,
Pathankot (Punjab)
(Name & Address of the Institution)

Note : The certificate is to be issued by authorized officer/ PHED Lab/ local bodies


Principal
Angel's Public School
Mamoon, Pathankot (Pb.)
Aff. - 1630192



TEST REPORT

Name & Address of Customer : Angel S Public School Angel S Public School Dalhousie Road Mamun Pathankot.		Customer Reference No.	No : 152 Dated : 06/05/2026
		Sample Submitted by	Sumant
		Date of Sample Receipt	06/05/2026
		Analysis Starting Date	06/05/2026
		Analysis completion Date	07/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC132792600000101F	Sample Type :	Water
Test Report No.:	DWTLPTK/2627/00037	Date of Issue :	07/05/2026
Registration no.:	DWTLPTK/REG2627/00053	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Angel S Public School Dalhousie Road Mamun Pathankot. / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Pathankot
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.87@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	130	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	108	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	84	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	40.08	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	3.888	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	19.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Pathankot

End of the Test Report

Sheetal
Angel's Public School
Mamoon, Pathankot (Pb.)
Aff. - 1630192