Atlantic County Special Services School District 4805 Nawakwa Boulevard Mays Landing, NJ 08330

ADDENDUM NO. 1

New Nurses Suite & Miscellaneous Alterations Project #FY24-003

This addendum amends Drawings and/or Specifications and/or Addenda for the above titled project, as indicated below, and is hereby incorporated into the Contract Documents as part thereof.

Bidders are required to acknowledge receipt of this Addendum in the space provided on the Proposal/Bid Form.

- 1. Who is the fire alarm panel manufacturer and who services the existing system? Response: the existing fire alarm system/panel is Simplex 4100. The existing system is serviced by JCI.
- 2. What is the distance from the work area/area of renovation to the Main Electrical Room? Note: this is not the Electrical Room shown in the work area. Response: it is approximately 250 feet from the Main Electrical Room to the work area/area of renovation.
- 3. Does the AHU-32a unit have a factory disconnect? This is not shown on the drawings or specifications. Response: the disconnect can be factory provided or separate, but a disconnect is required in accordance with the drawings/plans.
- 4. Please provide information for the current fire alarm system & sound system including vendor information since devices/equipment are being added. Response: Sound system manufacturer is Telecor, system is maintained by CM3. See response to Item 1 above for information regarding fire alarm system.
- 5. Electrical refer to revised electrical sheet E1.0 for Work Area power and systems plan revisions.
- Mechanical refer to Specification Section 230900.2.2; included with Addendum no. 1;
 - a. Manufacturer of Control System shall be Honeywell Spyder Bacnet Controller.
 - b. Control system shall be compatible with existing Honeywell Spyder Controls.

Specification Section 010050 – Administrative Provisions

Revise Item 1.7 ALLOWANCES

Addendum No.1 Phase 2 04/12/24 Page 1



Page 2