


DICHIARAZIONE DI CONFORMITÀ ALLA NORMA CEI 0-21

Sez. A	I seguenti generatori rispettano le prescrizioni della norma CEI 0-21 ed. 2022-03											
	Costruttore	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China										
	Tipo Apparecchiatura	Inverter fotovoltaico con sistema di accumulo di energia in batteria										
	Marca											
	N. fasi	☒ Monofase ☐ Trifase Frequenza: 50 Hz Tensione (F-N): 230 V										
	Energia primaria utilizzata	Solare										
	Modello del generatore	AF1K-SL-1 AF1K-SL-0	AF1.5K-SL-1 AF1.5K-SL-0	AF2K-SL-1 AF2K-SL-0	AF2.5K-SL-1 AF2.5K-SL-0	AF3K-SL-1 AF3K-SL-0 AF3K-SL	AF3.6K-SL-1 AF3.6K-SL AF3.6K-SL-0	AF4K-SL AF4K-SLP AF4K-SL-0	AF4.6K-SL AF4.6K-SLP AF4.6K-SL-00	AF5K-SL AF5K-SLP AF5K-SL-0	AF5.5K-SL AF5.5K-SLP AF5.5K-SL-0	AF6K-SL AF6K-SLP AF6K-SL-0
	Potenza Nominale (kW)	1	1.5	2	2.5	3	3.6	4	4.6	5	5.5	6
	Il generatore	È in grado di limitare la I_{dc} allo 0,5% della corrente nominale										
Sez. B	Caratteristiche del sistema di protezione di interfaccia											
	Costruttore	Afore New Energy Technology (Shanghai) Co., Ltd.										
	Modello	AF1K-SL-1 AF1K-SL-0	AF1.5K-SL-1 AF1.5K-SL-0	AF2K-SL-1 AF2K-SL-0	AF2.5K-SL-1 AF2.5K-SL-0	AF3K-SL-1 AF3K-SL-0 AF3K-SL	AF3.6K-SL-1 AF3.6K-SL AF3.6K-SL-0	AF4.6K-SL AF4.6K-SLP AF4.6K-SL-0	AF4.6K-SL AF4.6K-SLP AF4.6K-SL-0	AF5K-SL AF5K-SLP AF5K-SL-0	AF5.5K-SL AF5.5K-SLP AF5.5K-SL-0	AF6K-SL AF6K-SLP AF6K-SL-0
	Tipo	Integrata										
Sez. C	Caratteristiche del convertitore statico											
	Modello del convertitore statico	AF1K-SL-1 AF1K-SL-0	AF1.5K-SL-1 AF1.5K-SL-0	AF2K-SL-1 AF2K-SL-0	AF2.5K-SL-1 AF2.5K-SL-0	AF3K-SL-1 AF3K-SL-0 AF3K-SL	AF3.6K-SL-1 AF3.6K-SL AF3.6K-SL-0	AF4.6K-SL AF4.6K-SLP AF4.6K-SL-0	AF4.6K-SL AF4.6K-SLP AF4.6K-SL-0	AF5K-SL AF5K-SLP AF5K-SL-0	AF5.5K-SL AF5.5K-SLP AF5.5K-SL-0	AF6K-SL AF6K-SLP AF6K-SL-0
	Costruttore del convertitore statico	Afore New Energy Technology (Shanghai) Co., Ltd.										
	Versione firmware	V06										



	Note	- Le batterie non sono integrate nell'inverter e devono essere installate secondo le normative locali. - I modelli riportati sono utilizzabili per il collegamento in parallelo - Eventuali discrepanze con le capacità riportate sull'etichetta o sulla scheda tecnica sono dovute all'arrotondamento da parte dell'ente certificatore
Sez. I	Riferimenti dei laboratori che hanno eseguito le prove e dei relativi rapporti di prova (RdP)	
	Metodo prescelto	Prove eseguite da laboratorio accreditato
	Rapporti di prova (RdP)	6190804.50
	Emessi da: Numero accreditamento: Rif. Ente accreditamento:	DEKRA Testing and Certification (Suzhou) Co., Ltd, Accreditamento a IAS, N° 6190804.01COC Accreditamento secondo norme DIN EN ISO/IEC 17065
Sez. L	Dichiarazione di conformità del costruttore alle prescrizioni della norma CEI 0-21:2022-03	
	Con la presente dichiarazione, redatta ai sensi dell'articolo 47 del DPR 28 Dicembre 2000, n°445, il sottoscritto, Xinghe Chen, in qualità di legale rappresentante della Società Afore New Energy Technology (Shanghai) Co., Ltd, con sede in Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China, P. IVA 91310000561932991K, iscritta al registro delle imprese della pretura di None (Cina) con numero di registrazione 00000000202009040020. DICHIARA che gli inverter di propria costruzione e i relativi sistemi di accumulo di cui alle precedenti sezioni sono conformi alle prescrizioni contenute nella norma CEI 0-21:2022-03. Attesta altresì che la produzione dei dispositivi avviene in regime di qualità (secondo ISO 9001, ed. 2000 e s.m.i.)	

Shanghai, 17.5.2024

Afore New Energy Technology (Shanghai) Co., Ltd.
Xinghe Chen, CEO



*The Ministry of Foreign Affairs of
the People's Republic of China
requests all civil and military
authorities of foreign countries to
allow the bearer of this passport to
pass freely and afford assistance in
case of need.*

国家码/Country Code
CHN

护照号码/Passport No.

EM5232998

姓名/Name

陈星和
CHEN, XINGHE

性别 / Sex

国籍 / Nationality

出生日期/Date of birth

男/M

中國/CHINESE

20 DEC 1966

出生地点/Place of birth

浙江/ZHEJIANG

签发日期/Date of issue

22 5月/MAY 2024

签发地点/Place of issue

上海 / SHANGHAI

有效期至 / Date of expiry

21 5月/MAY 2034

签发机关/Authority

中华人民共和国国家移民管理局
National Immigration Administration, PRC

持照人签名/ Bearer's signature

和

2185580469

**POCHNCHEN<<XINGHE<<<<<<<<<<<<<<<<<<<<<<<<<<<<
EM52329982CHN6612201M3405215LDMCNAMHLKMNA932**

CERTIFICATE OF CONFORMITY

CERTIFICATO DI CONFORMITÀ

Issued to: Afore New Energy Technology (Shanghai) Co., Ltd.
Rilasciato a: Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China

For the product: Hybrid Inverter
Tipo prodotto:

Trade name:
Marchio:



Type/Model: AF1K-SL-1, AF1.5K-SL-1, AF2K-SL-1, AF2.5K-SL-1, AF3K-SL-1, AF3.6K-SL-1,
Riferimento modello: AF3K-SL, AF3.6K-SL, AF4K-SL, AF4.6K-SL, AF5K-SL, AF5.5K-SL, AF6K-SL,
AF4K-SLP, AF4.6K-SLP, AF5K-SLP, AF5.5K-SLP, AF6K-SLP,
AF1K-SL-0, AF1.5K-SL-0, AF2K-SL-0, AF2.5K-SL-0, AF3K-SL-0, AF3.6K-SL-0,
AF4K-SL-0, AF4.6K-SL-0, AF5K-SL-0, AF5.5K-SL-0, AF6K-SL-0

Ratings: See Annex
Dati di targa:

Manufactured by: Afore New Energy Technology (Shanghai) Co., Ltd.
Costruttore: Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China

Requirements: CEI 0-21:2022-03
Requisiti: Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica

The tested models are suitable for installation in systems with a total power greater than 11.08 kW.

I modelli testati sono adatti per l'installazione in sistemi con potenza di uscita maggiore di 11.08 kW.

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6190804.50

Il presente certificato è rilasciato a causa di un esame da parte di DEKRA, i cui risultati sono riportati in un file riservato n. 6190804.50

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The certificate does not include an assessment of the manufacturer's production.

Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Il sottoscritto dichiara che il prodotto di cui sopra è conforme ai requisiti tecnici menzionati. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto sopra menzionato.

La valutazione non include una verifica della produzione di serie né del luogo di produzione.

This Test Certificate expires at the latest on 2029-05-16 or expires upon withdrawal of one of the above mentioned standards.

Il presente certificato di prova scade al più tardi il 2029-05-16 o scade al momento del ritiro di uno dei suddetti standard.

Shanghai, 16 May 2024
DEKRA Testing and Certification (Shanghai) Ltd.

Certificate Number: 6190804.01COC

Cliff Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



PCA-141

DEKRA Testing and Certification (Shanghai) Ltd.
No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com
ESA-CER-F021 v3.0

Document no. : 6190804.01COC

Ratings of the testing Hybrid Inverter:

Valutazioni dell'invertitore ibrido di prova:

Models	AF1K-SL-1	AF1.5K-SL-1	AF2K-SL-1	AF2.5K-SL-1	AF3K-SL-1	AF3.6K-SL-1
PV input:						
Max PV voltage (V)	550					
MPPT voltage range (V)	80-500					
Max PV current (A)	18.5					
Isc PV (A)	26					
Max PV power (W)	1500	2300	3000	3800	4500	5400
Battery port:						
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid					
Battery normal voltage (range) (Vdc)	51.2 (40-60)					
Max charge/discharge current (A)	25	40	50	63	80	80
Max charge/discharge power (W)	1000	1500	2000	2500	3000	3600
AC grid (input and output):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated AC power (W)	1000	1500	2000	2500	3000	3600
Max AC apparent power (VA)	1000	1500	2000	2500	3000	3600
Power factor range	1.0 (-0.8 ~ +0.8 adjustable)					
AC load output (stand alone):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated continuous AC power (W)	1000	1500	2000	2500	3000	3600
Max continuous AC apparent power (VA)	1000	1500	2000	2500	3000	3600
General:						
Protection class	I					
Degree of protection	IP65					
Overvoltage category	II(DC), III(AC)					
Ambient temperature	-25...+60°C (Derating > 45°C)					

Document no. : 6190804.01COC

Models	AF3K-SL	AF3.6K-SL	AF4K-SL	AF4.6K-SL	AF5K-SL	AF5.5K-SL	AF6K-SL
PV input:							
Max PV voltage (V)	550						
MPPT voltage range (V)	80-500						
Max PV current (A)	18.5 x 2						
Isc PV (A)	26 x 2						
Max PV power (W)	4500	5400	6000	6900	7500	8300	9000
Battery port:							
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid						
Battery normal voltage (range) (Vdc)	51.2 (40-60)						
Max charge/ discharge current (A)	80						
Max charge/ discharge power (W)	3000	3600	4000	4600	4800	4800	4800
AC grid (input and output):							
Rated voltage (V)	L/N/PE, 230Vac						
Rated frequency (Hz)	50						
Max AC current (A)	14	17	19	22	23	26	28
Rated AC power (W)	3000	3600	4000	4600	5000	5500	6000
Max AC apparent power (VA)	3000	3600	4000	4600	5000	5500	6000
Power factor range	1.0 (-0.8 ~ +0.8 adjustable)						
AC load output (stand alone):							
Rated voltage (V)	L/N/PE, 230Vac						
Rated frequency (Hz)	50						
Max AC current (A)	14	17	19	22	23	26	28
Rated continuous AC power (W)	3000	3600	4000	4600	5000	5500	6000
Max continuous AC apparent power (VA)	3000	3600	4000	4600	5000	5500	6000
General:							
Protection class	I						
Degree of protection	IP65						
Overvoltage category	II(DC), III(AC)						
Ambient temperature	-25...+60°C (Derating > 45°C)						

Document no. : 6190804.01COC

Models	AF4K-SLP	AF4.6K-SLP	AF5K-SLP	AF5.5K-SLP	AF6K-SLP
PV input:					
Max PV voltage (V)	550				
MPPT voltage range (V)	80-500				
Max PV current (A)	18.5 x 2				
Isc PV (A)	26 x 2				
Max PV power (W)	6000	6900	7500	8300	9000
Battery port:					
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid				
Battery normal voltage (range) (Vdc)	51.2 (40-60)				
Max charge/discharge current (A)	120				
Max charge/discharge power (W)	4000	4600	5000	5500	6000
AC grid (input and output):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated AC power (W)	4000	4600	5000	5500	6000
Max AC apparent power (VA)	4000	4600	5000	5500	6000
Power factor range	1.0 (-0.8~ +0.8 adjustable)				
AC load output (stand alone):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated continuous AC power (W)	4000	4600	5000	5500	6000
Max continuous AC apparent power (VA)	4000	4600	5000	5500	6000
General:					
Protection class	I				
Degree of protection	IP65				
Overvoltage category	II(DC), III(AC)				
Ambient temperature	-25...+60°C (Derating > 45°C)				

Document no. : 6190804.01COC

Models	AF1K-SL-0	AF1.5K-SL-0	AF2K-SL-0	AF2.5K-SL-0	AF3K-SL-0	AF3.6K-SL-0
Battery port:						
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid					
Battery normal voltage (range) (Vdc)	51.2 (40-60)					
Max charge/discharge current (A)	25	40	50	63	80	80
Max charge/discharge power (W)	1000	1500	2000	2500	3000	3600
AC grid (input and output):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated AC power (W)	1000	1500	2000	2500	3000	3600
Max AC apparent power (VA)	1000	1500	2000	2500	3000	3600
Power factor range	1.0 (-0.8 ~ +0.8 adjustable)					
AC load output (stand alone):						
Rated voltage (V)	L/N/PE, 230Vac					
Rated frequency (Hz)	50					
Max AC current (A)	5	7	10	12	14	17
Rated continuous AC power (W)	1000	1500	2000	2500	3000	3600
Max continuous AC apparent power (VA)	1000	1500	2000	2500	3000	3600
General:						
Protection class	I					
Degree of protection	IP65					
Overvoltage category	II(DC), III(AC)					
Ambient temperature	-25...+60°C (Derating > 45°C)					

Document no. : 6190804.01COC

Models	AF4K-SL-0	AF4.6K-SL-0	AF5K-SL-0	AF5.5K-SL-0	AF6K-SL-0
Battery port:					
Battery type	Rechargeable Li-ion Battery/ LiFePO4/ Lead-acid				
Battery normal voltage (range) (Vdc)	51.2 (40-60)				
Max charge/discharge current (A)	120	120	120	120	120
Max charge/discharge power (W)	4000	4600	5000	5500	6000
AC grid (input and output):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated AC power (W)	4000	4600	5000	5500	6000
Max AC apparent power (VA)	4000	4600	5000	5500	6000
Power factor range	1.0 (-0.8 ~ +0.8 adjustable)				
AC load output (stand alone):					
Rated voltage (V)	L/N/PE, 230Vac				
Rated frequency (Hz)	50				
Max AC current (A)	19	22	23	26	28
Rated continuous AC power (W)	4000	4600	5000	5500	6000
Max continuous AC apparent power (VA)	4000	4600	5000	5500	6000
General:					
Protection class	I				
Degree of protection	IP65				
Overvoltage category	II(DC), III(AC)				
Ambient temperature	-25...+60°C (Derating > 45°C)				

Type of generating unit:

Tipologia di apparato:

Static Conversion Device <i>Dispositivo di conversione statica</i>	Interface Protection <i>Protezione di interfaccia</i>	Interface Protection Device <i>Dispositivo di interfaccia</i>	Rotating Generator Device <i>Dispositivo di generazione rotante</i>
Yes/Si	Yes/Si	Yes/Si	No

REMARK: the device is capable to limit the Idc to 0,5% of the nominal current

NOTA: Il dispositivo è in grado di limitare la Idc allo 0,5% della corrente nominale

Hardware version: 1.01

Versione hardware: 1.01

Firmware release (SW): V02

Revisione firmware (SW): V02

Document no. : 6190804.01COC

The battery used for testing with the Hybrid Inverter covered by this certificate:

La batteria utilizzata per i test con l'invertitore ibrido coperto dal presente certificato:

Battery Models	ATOM WB-512100			
Manufacturer	Shenzhen Hailei New Energy Co., LTD.			
Number of battery module in parallel	1	2	3	4
Nominal Voltage	51.2 V			
Nominal capacity	100 Ah	200 Ah	300 Ah	400 Ah
Battery System Capacity	5.12 kWh	10.24 kWh	15.36 kWh	20.48 kWh
Number of battery module in parallel	5	6	7	8
Nominal Voltage	51.2 V			
Nominal capacity	500 Ah	600 Ah	700 Ah	800 Ah
Battery System Capacity	25.6 kWh	30.72 kWh	35.84 kWh	40.96 kWh
Number of battery module in parallel	9	10	11	12
Nominal Voltage	51.2 V			
Nominal capacity	900 Ah	1000 Ah	1100 Ah	1200 Ah
Battery System Capacity	46.08 kWh	51.2 kWh	56.32 kWh	61.44 kWh
Number of battery module in parallel	13	14	15	-
Nominal Voltage	51.2 V			
Nominal capacity	1300 Ah	1400 Ah	1500 Ah	-
Battery System Capacity	66.56 kWh	71.68 kWh	76.8 kWh	-
Remark: The CB test certificate No. of the battery: NL-105998 When the batteries are connected in parallel, the charge/ discharge current is superimposed and is limited by the maximum current of the battery port of the Hybrid Inverter. The batteries are not integrated into the Hybrid Inverter and must be installed according to the local regulations.				

Testing Laboratory:

Laboratorio prove:

Testing Laboratory for CEI 0-21:2022-03

DEKRA Testing and Certification (Suzhou) Co., Ltd.

No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China

Accreditation Number: L5313 (CNAS-ILAC)

Testing Laboratory for EMC:

1. Intertek Testing Services Shanghai

Building No.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai 200233, China

Accreditation Number: 3309.02 (A2LA-ILAC)

2. Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

No.103, Caobao Road, Xuhui District, Shanghai, China

Accreditation Number: L0130 (CNAS-ILAC)

--- End ---