

MOORESTOWN TOWNSHIP

FIRE PREVENTION

PREVENTION THROUGH EDUCATION



Witness:

Title:

Smoke Detectors / Carbon Monoxide Detectors

Single Station / Battery Operated System checked on battery
 Single Station / Hard Wired System checked on battery
 Multiple Station / Hard Wired
 Alarm System Connected to a Central Station* - Tested and certified by NJ licensed fire
*Fire alarm registration required alarm contactor

Smoke Detector / Carbon Monoxide Detector Locations

1st Floor:	Present: _____	Operational: _____	Non-Operational: _____
2nd Floor:	Present: _____	Operational: _____	Non-Operational: _____
3rd Floor:	Present: _____	Operational: _____	Non-Operational: _____
Basement:	Present: _____	Operational: _____	Non-Operational: _____

Fire Extinguisher

No smaller than 2.5 lbs. ABC rated for residential use and not more than 10 lbs.
 Hangers and brackets supplied by manufacturer are used
 Located within 10 feet of the kitchen
 Top of the extinguisher is not more than 5 feet above the floor
 Visible, in a readily accessible location and free from being blocked
 Near a room exit or travel path that provides escape to the exterior
 Owner's manual or written information on operation, inspection, and maintenance is attached
 Operating instructions are clearly visible
 Proof of purchase or receipt for new extinguisher provided
 Service tag in place for extinguisher not manufactured in current year

Other Requirements

Building / Unit / House number visible
 Electrical panel circuits marked
 Method used to test smoke detectors – NFPA smoke
 Method used to test carbon monoxide detectors – Test button

Inspection NOT satisfactory due to: _____

Inspection Satisfactory Issued By: _____ Date: _____