

Frenchglen SD #16

Summary of Water Testing for Lead Results December 2024

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
School Building 4-8 Classroom Faucet	20200100-001-CF24A	12/20/2024	ND
School Building K-3 Classroom Faucet	20200100-002-CF24A	12/20/2024	ND
School Building Kitchen Faucet	20200100-003-KF24A	12/20/2024	ND
School Building Hall Drinking Fountain	20200100-004-DW24A	12/20/2024	ND
School Building Boys' Bathroom Faucet	20200100-005-BF24A	12/20/2024	1.2
School Building Girls' Bathroom Faucet	20200100-006-BF24A	12/20/2024	ND
Old Teacherage Kitchen Faucet	20200102-001-KF24A	12/20/2024	3.6
Old Teacherage Guest Bathroom Faucet	20200102-002-KF24A	12/20/2024	ND
Old Teacherage Guest Bathroom Tub	20200102-002-OT24A	12/20/2024	ND
Old Teacherage Master Bathroom Faucet	20200102-003-BF24A	12/20/2024	ND
Old Teacherage Master Bathroom Tub	20200102-003-OF24A	12/20/2024	ND
New Teacherage Kitchen Faucet	20200103-001-KF24A	12/20/2024	ND
New Teacherage Guest Bathroom Faucet	20200103-002-BF24A	12/20/2024	ND
New Teacherage Guest Bathroom Tub	20200103-002-OT24A	12/20/2024	ND
New Teacherage Master Bathroom Faucet	20200103-001-BF24A	12/20/2024	ND
New Teacherage Master Bathroom Tub	20200103-001-OT24A	12/20/2024	ND

ND=Non Detect- Led level is below the set detection limits of 1ppb