

Frenchglen SD #16

Summary of Water Testing for Lead Results January 2020

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
School Building 4-8 Classroom Faucet	20200100-001-CF20A	1/22/2020	ND
School Building 4-8 Classroom Drinking Fountain	20200100-001-DW20A	1/22/2020	ND
School Building K-3 Classroom Faucet	20200100-002-CF20A	1/22/2020	ND
School Building K-3 Drinking Fountain	20200100-002-DW20A	1/22/2020	ND
School Building Kitchen Faucet	20200100-003-KF20A	1/22/2020	ND
School Building Hall Drinking Fountain	20200100-004-DW20A	1/22/2020	ND
School Building Boys' Bathroom Faucet	20200100-005-BF20A	1/22/2020	ND
School Building Girls' Bathroom Faucet	20200100-006-BF20A	1/22/2020	ND
Old Teacherage Kitchen Faucet	20200102-001-KF20A	1/22/2020	2
Old Teacherage Guest Bathroom Faucet	20200102-002-BF20A	1/22/2020	2
Old Teacherage Guest Bathroom Tub	20200102-002-OT20A	1/22/2020	9
Old Teacherage Master Bathroom Tub	20200102-003-OT20A	1/22/2020	ND
Old Teacherage Master Bathroom Faucet	20200102-003-OT20A	1/22/2020	3
New Teacherage Kitchen Faucet	20200103-001-KF20A	1/22/2020	ND
New Teacherage Guest Bathroom Faucet	20200103-002-BF20A	1/22/2020	ND
New Teacherage Guest Bathroom Tub	20200103-002-OT20A	1/22/2020	ND
New Teacherage Master Bathroom Faucet	20200103-003-BF20A	1/22/2020	ND

New Teacherage Master Bathroom Tub

20200103-003-OT20A

1/22/2020

ND

ND = Non Detect - Lead level is below the set detection limits of 1ppb