

Radon Testing Results Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Frenchglen	Teacherage 1	Bedroom	9538321	12/7/2020	Duplicate	0.8
Frenchglen	Teacherage 1	Dinning Room	9538334	12/7/2020	Duplicate	1
Frenchglen	Teacherage 2	Dining Room	9538311	12/7/2020	Detector Kit	0.9
Frenchglen	School	Classroom 1	9538341	12/7/2020	Detector Kit	0.6
Frenchglen	School	Classroom 2	9538328	12/7/2020	Duplicate	0.6
Frenchglen	School	Classroom 3	9538332	12/7/2020	Duplicate	1.1
Frenchglen	School	Clerks Office	9538333	12/7/2020	Detector Kit	0.7
Frenchglen	School	Gym 1	9538339	12/7/2020	Detector Kit	1.2
Frenchglen	School	Gym 2	9538335	12/7/2020	Detector Kit	1.2
Frenchglen	School	Gym 3	9538331	12/7/2020	Detector Kit	1
Frenchglen	School	Gym Foyer	9538319	12/7/2020	Detector Kit	1
Frenchglen	School	Kitchen	9538336	12/7/2020	Detector Kit	1.4
Frenchglen	School	Library	9538305	12/7/2020	Detector Kit	1
Frenchglen	School	Pantry	9538340	12/7/2020	Detector Kit	0.3
Frenchglen					Spike	30.9

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- [1 Number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.