



Brevard County Fire Rescue


Office of the Fire Marshal  
1040 South Florida Ave.  
Rockledge, FL 32955  
Office (321) 637-5660  
Fax (321) 633-2109  
Email [fire.prevention@brevardfl.gov](mailto:fire.prevention@brevardfl.gov)




Occupant Name:	Marina Village Condo Association 540	Inspection Date:	5/15/2025 (Initial Insp. Date: 4/14/2025)
Address:	540 South Banana River Drive	InspectionType:	Reinspection #1 (Condo/ Apartment)
Suite:		Structure Name:	Condo 540
City:	Merritt Island	Inspected By:	Lucas Mulvehill 321-637-5660
Zip Code:	32952	Occ. Sq. Ft.:	56364

Insp. Result	Location	Code Set	Code
Code Violation - Cleared	Floor 1	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.9.6.4 - Excerpt: [Where sprinklers penetrate a single membrane of...]
	✓ Cleared on 5/15/2025		
Code Violation - Cleared	Floor 1	FL NFPA 01 2021 Chapter 13 Fire Protection Systems	13.1.2 - FIRE PROTECTION SYSTEMS
	✓ Cleared on 5/15/2025		
Code Violation - Cleared	Floor 1	NFPA 70 NEC	408.4 - Electrical- Circuit Identification, Label Panel
	✓ Cleared on 5/15/2025		
Code Violation - Cleared	Floor 1	NFPA 82 Group 1	10.2.2.1 - Chute- Fusible Links
	✓ Cleared on 5/15/2025		

**ALL Fire Code violations** shall be corrected **IMMEDIATELY**. The re-inspection date is for verification of compliance **ONLY!** Failure to bring these discrepancies / violations into compliance will result in **additional inspection fees**. Any request for extensions of time to correct any violations must be in writing. If the request is approved, notification of the approval will be in writing. **This inspection is not a license to operate**. If you have any questions, please get in touch with the Fire Marshal's office at (321) 637-5660.

Company Representative:   
Mike  
5/15/2025  
Signature valid only in mobile-eyes documents

Inspector:   
Lucas Mulvehill  
5/15/2025  
Signature valid only in mobile-eyes documents

Ref: 184376-185644



Brevard County Fire Rescue  
Office of Fire Prevention  
1040 South Florida Ave.  
Rockledge, FL 32955

Marina Village Condo Association 540  
540 South Banana River Drive  
Merritt Island FL 32952

Invoice #	25051548001
Invoice Date	5/15/2025
Balance Due	\$98.00
Due Date	6/14/2025

**TERMS: PAYMENT DUE WITHIN 30 Days**  
Please remit payment upon receipt. **For your convenience, you may pay by credit card or check at [brevardcounty.us/FireRescue](https://brevardcounty.us/FireRescue)** Click on the Pay Fire Inspection Fees button on the right. If you prefer to mail your payment in make checks payable to BOCC and mail payment to Office of Fire Prevention, 1040 South Florida Ave., Rockledge, FL 32955.

BREVARD COUNTY FIRE PREVENTION  
FIRE SAFETY INSPECTION INVOICE

Marina Village Condo Association 540  
540 South Banana River Drive  
Merritt Island FL 32952

Invoice #25051548001  
5/15/2025

Description	Amount Owed	Amount Paid
1st Reinspection Fee - Compliance	\$98.00	
Subtotal:	\$98.00	\$0.00
Balance Due:	\$98.00	

Fees for this invoice shall be submitted to Brevard County Office of Fire Prevention upon receipt. **For your convenience may pay by credit card or check at [brevardcounty.us/FireRescue](https://brevardcounty.us/FireRescue)** Click on the Pay Fire Inspection Fees button on the right. Checks and/or money orders are to be made payable to BOCC, 1040 South Florida Ave., Rockledge, FL 32955. Please call 321-637-5660 if you have any questions regarding your invoice.

Company Representative:   
Mike  
5/15/2025  
Signature valid only in mobile-eyes documents

Inspector:   
Lucas Mulvehill  
5/15/2025  
Signature valid only in mobile-eyes documents