



# Brevard County Fire Rescue

## Office of the Fire Marshal

1040 South Florida Ave.  
Rockledge, FL 32955  
Office (321) 637-5660  
Fax (321) 633-2109

Email [fire.prevention@brevardfl.gov](mailto:fire.prevention@brevardfl.gov)



**Occupant Name:** Marina Village Condo Association 590  
**Address:** 590 South Banana River Drive  
**Suite:**  
**City:** Merritt Island  
**Zip Code:** 32952

**Inspection Date:** 5/14/2025  
**InspectionType:** NC: Fire Alarm Final  
**Structure Name:** Condo 590  
**Inspected By:** Marc Sciacca  
321-637-5660  
**Occ. Sq. Ft.:** 55307

Insp. Result	Location	Code Set	Code
N/A	Floor 1	Codes Verifications	101 - Verify square footage. This item is for the fire inspector only. No action is required from occupant/owner.

**Inspector Comments:** NC fire final for new dialer install. Pull station signal sent received by dispatch. Test completed and passed on permit #25FP00197.

**ALL Fire Code violations** shall be corrected **IMMEDIATELY**. The re-inspection date is for verification of compliance **ONLY!** Failure to bring these discrepancies / violations into compliance will result in **additional inspection fees**. Any request for extensions of time to correct any violations must be in writing. If the request is approved, notification of the approval will be in writing. **This inspection is not a license to operate**. If you have any questions, please get in touch with the Fire Marshal's office at (321) 637-5660.

**Inspector:**

*Marc Sciacca*  
Signature valid only in mobile-eye documents

Marc Sciacca  
5/14/2025

Ref: 185536