

ACE FLOW CONTROL

Backflow Prevention Assembly Test Report

Report via ValveAl UI on: 11/7/2024, 6:38:01 PM

CFC 1429737 FPC21-000120 info@aceflowcontrol.com (407) 574-7208

Site Info

Site Name:

MARINA VILLAGE CONDO

ASSOCIATI

Service Address: 582 S BANANA RIVER DR 6F/L MERRITT ISLAND, FL 32952

Site Type:

Commercial

Connection Info

Utility:

City of Cocoa

Utility Account #: 000287383-000159180

Service Type:

Fire - Potable

Location ID:

159180 NO METER

Meter Number: Meter Size:

AMR Serial:

In

Valve Info

Туре:

DCDA

Model:

350DA

Size:

6.00

Serial: Location: N19651

NWCOP @ RSO Northern ENtrance.

Monitored. Chained. Locked.

Hazard Type:

FIRE SYSTEM - Non Chemical

Technicain Info

Name:

Kyle Belden

Cert Number:

11467

Cert Date:

2023-04-26 10070831

Gauge Serial: Gauge Cert:

2024-03-07

itial Test Check Valves		RPZ	Presure Vaccum Breaker		Shut Off Valves		
	Check Valve 1	Check Valve 2	Relief Valve	Air Inlet	Check	Shut Off 1	Shut Off 2
PASS	PSID: 2.60	PSID: 3.00				CLOSED	CLOSED TIGHT

-				
	om	m	On	te
U	UII	1111	CII	L)

NOH, SO1 Open., SO2 Open.



Work Date-Time:

Final Result:

2024-11-06 09:50:00

PASS

Technician Signature

Kyle Belden



ACE FLOW CONTROL Backflow Prevention Assembly Test Report

Report via ValveAl UI on: 11/7/2024, 6:38:12 PM

CFC 1429737 FPC21-000120 info@aceflowcontrol.com (407) 574-7208

Site Info

Site Name:

MARINA VILLAGE CONDO

ASSOCIATI

Service Address: 590 S BANANA RIVER DR 6F/L

MERRITT ISLAND, FL 32952

Site Type:

Commercial

Connection Info

Utility:

City of Cocoa

Utility Account #: 000287383-000159182

Service Type:

Fire - Potable

Location ID:

159182 NO METER

Meter Number:

Meter Size:

AMR Serial:

Valve Info

Type:

DCDA

Model:

350DA

Size:

6.00

Serial: Location: N20146

SWCOP Behind Wall, Gated. Gate Code

1980 FIRE SYSTEM - Non Chemical

Hazard Type:

Technicain Info

Name:

Kyle Belden

Cert Number:

11467

Cert Date:

2023-04-26

Gauge Serial:

10070831

Gauge Cert:

2024-03-07

Initial Test	Check	eck Valves RPZ		Presure Vaccum Breaker		Shut Off Valves	
	Check Valve 1	Check Valve 2	Relief Valve	Air Inlet	Check	Shut Off 1	Shut Off 2
PASS	PSID: 2.80	PSID: 3.00				CLOSED TIGHT	CLOSED TIGHT

Comments

NOH, SO1 Open., SO2 Open.

Work Date-Time: Final Result:

2024-11-06 09:12:00

PASS



hoto taken at time of event

Technician Signature

Kyle Belden



ACE FLOW CONTROL Backflow Prevention Assembly Test Report

Report via ValveAl UI on: 11/7/2024, 6:38:07 PM

FPC21-000120 info@aceflowcontrol.com (407) 574-7208

Site Info

Site Name:

MARINA VILLAGE CONDO

ASSOCIATI

Service Address: 580 S BANANA RIVER DR 6 F/L

MERRITT ISLAND, FL 32952

Site Type:

Commercial

Fire - Potable

NO METER

Connection Info

City of Cocoa

Utility:

Utility Account #: 000287383-000159184

Service Type:

Location ID: 159184

Meter Number:

Meter Size: AMR Serial:

Initial T

Valve Info

Type:

DCDA 350DA

Model:

6.00

Size: Serial:

N20134

Location:

SWCOB Behind Stem Wall Next to Fire

Risers.

Hazard Type: FIRE SYSTEM - Non Chemical

Technicain Info

Name:

Kyle Belden

Cert Number:

11467

Cert Date:

2023-04-26 10070831

Gauge Serial: Gauge Cert:

2024-03-07

Test	Check	Valves	RPZ	Presure Vaco	um Breaker	Shut Of	f Valves
	Check Valve 1	Check Valve 2	Relief Valve	Air Inlet	Check	Shut Off 1	Shut Off 2
S	PSID: 3.20	PSID: 3.40				CLOSED TIGHT	CLOSED TIGHT

00	mm	ents
CO		ICIII S

PAS

NOH, SO1 Open., SO2 Open.

Work Date-Time:

Final Result:

2024-11-06 09:09:00

PASS



hoto taken at time of event

Kyle Belden

Technician Signature