



Brevard County Fire Rescue

Office of the Fire Marshal

**1040 South Florida Ave.
Rockledge, FL 32955
Office (321) 637-5660
Fax (321) 633-2109**

Email fire.prevention@brevardfl.gov



Occupant Name:	Marina Village Condo Association 540
Address:	540 South Banana River Drive
Suite:	
City:	Merritt Island
Zip Code:	32952

Inspection Date:	5/13/2025
InspectionType:	NC: Fire Alarm Final
Structure Name:	Condo 540
Inspected By:	Marc Sciacca 321-637-5660
Occ. Sq. Ft.:	56364

Insp. Result	Location	Code Set	Code
N/A	Floor 1	Codes Verifications	101 - Verify square footage. This item is for the fire inspector only. No action is required from occupant/owner.

Inspector Comments: NC fire alarm final for dialer upgrade. Pull station activated, signal sent and received by dispatch. Passed on permit # 25FP00200.

ALL Fire Code violations shall be corrected **IMMEDIATELY**. The re-inspection date is for verification of compliance **ONLY!** Failure to bring these discrepancies / violations into compliance will result in **additional inspection fees**. Any request for extensions of time to correct any violations must be in writing. If the request is approved, notification of the approval will be in writing. **This inspection is not a license to operate**. If you have any questions, please get in touch with the Fire Marshal's office at (321) 637-5660.

Inspector:

A handwritten signature in black ink, appearing to read "Marc S 43". The signature is written over a background of repeating red text that says "SIGNATURE - COPIED SIGNATURE".

Marc Sciaccia
5/13/2025

Ref: 185530