

**STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT**



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 05-60-05031  
Name of Facility: Marina Village Condo SPA  
Address: 580 S Banana River Drive  
City, Zip: Merritt Island 32952

**Correct By: None  
Re-Inspection Date: None**

Type: Spa-Type Pools  
Owner: Marina Village Condominium Association of Brevard, Inc.  
Person In Charge: Marina Village Condo Phone: (386) 446-6333  
PIC Email: kristy.showcase@gmail.com  
Pool Operator: Beach Pool Service Phone: (321) 777-7665

**Inspection Information**

Purpose: Reinspection  
Inspection Date: 9/11/2024

Begin Time: 04:30 PM  
End Time: 04:45 PM

**Additional Information**

22. Free Chlor./Bromine .....	VOLUME .....	780
23. pH .....	POOL LOAD .....	5
24. Chlor. Stabilizer .....	FLOW RATE .....	50
33. Flowmeter .....	NIGHT SWIM .....	No
34. Thermometer .....	FILTER TYPE .....	CP

*Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.*

**Violation Markings**

<b>POOL AREA</b> 1. Water Clarity/Algae Control 2. Deck/Walkways 3. Tile/Pool Finish 4. Depth Markers-FBC 5. Handrail/Ladder-FBC 6. Step Markings-FBC 7. Suction Outlets-514.0315(1) 8. Gutter Grates/Skimmer-FBC 9. Lighting 10. No Dive Markings-FBC 11. Diving Board-FBC 12. Pool Cover 13. Pool Side Shower-FBC <b>POOL SAFETY</b> 14. Life Hook(s) w/Pole 15. Life Ring(s) w/Rope 16. Safety Line	17. Rules Posted 18. Certification <b>SANITARY FACILITIES</b> 19. Supplies 64E-10, FAC 20. Clean 64E-10, FAC <b>WATER QUALITY</b> 21. Approved Test Kit 22. Free Chlor./Brom. 23. pH 24. Chlor. Stabilizer 25. Spa Requirements-ORP <b>EQUIPMENT ROOM</b> 26. Wading Pool-Quick Dump 27. Water Level/Control 28. Disinfection Feeder/Generator 29. pH Feeder 30. Chem. Container Label-FBC 31. Filter / Pump	32. Vacuum Cleaner-FBC 33. Flowmeter 34. Thermometer 35. Pressure/Vacuum Gauge 36. Equip. Room 37. Cross Connection 38. Gas Chlorine Eq.-FBC 39. Waste Water - FBC 40. D.E. Separator-FBC 41. Other Equipment 42. Equip. Change-FBC 43. Approved Chemicals 44. Maintenance Log 45. Inspection Posted 46. Safety-514.0315(2) 47. Fences/Gates- FBC 48. Other 49. Other
---	---	--

*NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.*

Inspector Signature:

Client Signature:

*Charm Ayupon*

*Emailed from Office*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



2 of 2

### General Comments

Violation 25 has been corrected via email and photo evidence from pool operator uploaded to the file. No observed violations remain at this time. Please call if you have any questions.

ATTENTION - Please review the information on the following website regarding Federally required anti-entrapment safety devices and guidelines.  
[https://brevard.floridahealth.gov/programs-and-services/environmental-health/pools-and-spas/\\_documents/fy24-vgba-drain-cover-compliance-reminder-letter.pdf](https://brevard.floridahealth.gov/programs-and-services/environmental-health/pools-and-spas/_documents/fy24-vgba-drain-cover-compliance-reminder-letter.pdf)

Facility notes: Resurfaced 2021. Gravity for main and therapy (collector tank), direct for skimmer (ELP). Waterway 12x12" WWP 640-472 grate expires 03/04/2028. 1 set of safety equipment. 1HP non-variable recirc pump, 3HP therapy pump (emergency shut-off switch with alarm and sign). ORP-Rolachem RC554XP, Cl-RolaChem RC103SC, pH-RC103RC. StaRite PLM200 cartridge filter. Aquapro electric and StaRite gas heaters (1 each) plumbed in-line with each other and bypass valves. 1 light. 1 skimmer. Shower on deck. Wall returns and static line (north side of bottom wall next to skimmer equilizer). 1 figure-4 handrail (step/bench markings-green SR). 15 minute timer with clock. Hours Dawn to Dusk. Max Depth 3FT. Test kit and log with equipment.

Email Address(es): yourcamjam@gmail.com;  
mvkimt@gmail.com;  
beachpoolservice@yahoo.com;

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

### Violations Comments

No Violation Comments Available

Inspection Conducted By: Ivan Bryson (26992)  
Inspector Contact Number: Work: (321) 615-9399 ex.  
Print Client Name:  
Date: 9/11/2024

Inspector Signature:

*Ivan Bryson*

Client Signature:

*Emailed from Office*