

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 05-60-05030  
Name of Facility: Marina Village Condo SWP  
Address: 600 S Banana Drive  
City, Zip: Merritt Island 32952

**Correct By: None**  
**Re-Inspection Date: None**

Type: Public Pool <= 25000 Gallons  
Owner: Marina Village Condominium Association of Brevard, Inc.  
Person In Charge: Marina Village Condo Phone: (321) 449-8589  
PIC Email: kristy.showcase@gmail.com  
Pool Operator: Beach Pool Service Phone: (321) 777-7665

**Inspection Information**

Purpose: Routine  
Inspection Date: 7/23/2024

Begin Time: 12:15 PM  
End Time: 01:00 PM

**Additional Information**

22. Free Chlorine ..... 1	VOLUME ..... 17451
23. pH ..... 7.8	POOL LOAD ..... 16
24. Chlor. Stabilizer ..... 40	FLOW RATE ..... 80
33. Flowmeter ..... 85	NIGHT SWIM ..... No
34. Thermometer ..... 90	FILTER TYPE ..... DEV

*Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.*

**Violation Markings**

POOL AREA	17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

**NOTE:** It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

**Inspector Signature:**

**Client Signature:**

*Emailed: No one available to sign.  
Spoke with Kim on phone.*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC POOL AND BATHING PLACE  
INSPECTION REPORT



2 of 2

### General Comments

No violations observed at time of inspection. Please call if you have any questions.

ATTENTION - Please review the information on the following website regarding Federally required anti-entrapment safety devices and guidelines.  
[https://brevard.floridahealth.gov/programs-and-services/environmental-health/pools-and-spas/\\_documents/fy24-vgba-drain-cover-compliance-reminder-letter.pdf](https://brevard.floridahealth.gov/programs-and-services/environmental-health/pools-and-spas/_documents/fy24-vgba-drain-cover-compliance-reminder-letter.pdf)

Facility notes: Resurfaced 2021. Gravity (collector tank). Waterway 12x12" WWP 640-472 grate expires 03/04/2028. 1 set of safety equipment. 2HP non-variable recirc pump, 1HP vac pump. Cl-RolaChem RC103SC, pH-RC103RC. 9 filter grids with Pentair SP60-1.5. Rheem electric heater with bypass valves and solar heater with Aquastar II controller and bypass valves. 1 vac port. 1 light. 2 skimmers (floating weirs). Shower on deck. Wall returns and static line (near north side skimmer). DM-in/deck SR. ND-deck SR. 1 cross-braced ladder. 1 handrail/stairs (steps-green SR). Hours Dawn to Dusk. Maximum Pool Depth 5 Feet 9 Inches. Test kit and log with equipment.

Email Address(es): mvkimt@gmail.com;  
kristy.showcase@gmail.com;  
beachpoolservice@yahoo.com;

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

### Violations Comments

No Violation Comments Available

Inspection Conducted By: Ivan Bryson (26992)  
Inspector Contact Number: Work: (321) 615-9399 ex.  
Print Client Name:  
Date: 7/23/2024

Inspector Signature:

Client Signature:

*Emailed: No one available to sign.  
Spoke with Kim on phone.*