



Brevard County Fire Rescue

Office of the Fire Marshal

1040 South Florida Ave.
Rockledge, FL 32955
Office (321) 637-5660
Fax (321) 633-2109

Email fire.prevention@brevardfl.gov



Occupant Name:	Marina Village Condo Association 580	Inspection Date:	5/14/2025
Address:	580 South Banana River Drive	InspectionType:	NC: Fire Alarm Final
Suite:		Structure Name:	Condo 580
City:	Merritt Island	Inspected By:	Marc Sciacca 321-637-5660
Zip Code:	32952	Occ. Sq. Ft.:	44231
Insp. Result	Location	Code Set	Code
N/A	Floor 1	Codes Verifications	101 - Verify square footage. This item is for the fire inspector only. No action is required from occupant/owner.

Inspector Comments: NC fire final for new dialer install. Water flow and tamper signal sent, received by dispatch. Test completed and passed on permit #25FP00198.

ALL Fire Code violations shall be corrected **IMMEDIATELY**. The re-inspection date is for verification of compliance **ONLY!** Failure to bring these discrepancies / violations into compliance will result in **additional inspection fees**. Any request for extensions of time to correct any violations must be in writing. If the request is approved, notification of the approval will be in writing. **This inspection is not a license to operate**. If you have any questions, please get in touch with the Fire Marshal's office at (321) 637-5660.

Inspector:

185535
5/14/2025 8:59:57 AM
Signature valid only in mobile-eyes documents

Marc Sciacca
5/14/2025

Ref: 185535