



ACE FLOW CONTROL

Backflow Prevention Assembly Test Summary

Summary via ValveAI UI on: 11/19/2024, 5:04:53 PM

CFC 1429737
FPC21-000120
info@aceflowcontrol.com
(407) 574-7208

Site Info

Site Name: *MARINA VILLAGE CONDO ASSOCIATI*
Service Address: *582 S BANANA RIVER DR 6F/L MERRITT ISLAND, FL 32952*
Site Type: *Commercial*

Connection Info

Utility: *City of Cocoa*
Utility Account #: *000287383-000159180*
Service Type: *Fire - Potable*
Location ID: *159180*
Meter Number: *NO METER*
Meter Size:
AMR Serial:

Valve Info

Type: *DC*
Model: *950XL*
Size: *0.75*
Serial: *w2004270*
Location: *NWCOP @ RSO North Entrance. ByPass. On SN 19651*

Hazard Type: *FIRE SYSTEM - Non Chemical*

Technician Info

Name: *Kyle Belden*
Cert Number: *11467*
Cert Date: *2023-04-26*
Gauge Serial: *10070831*
Gauge Cert: *2024-03-07*

Initial Test	Check Valves		RPZ	Pressure Vacuum Breaker		Shut Off Valves	
	Check Valve 1	Check Valve 2	Relief Valve	Air Inlet	Check	Shut Off 1	Shut Off 2
PASS	<i>PSID: 2.00</i>	<i>PSID: 1.40</i>				<i>CLOSED TIGHT</i>	<i>CLOSED TIGHT</i>

Comments	<i>NOH, S01 Open., S02 Open.</i>
----------	----------------------------------



Photo taken at time of event

Work Date-Time:

2024-11-06 09:50:00

Final Result:

PASS