



# Brevard County Fire Rescue

# Office of the Fire Marshal

**1040 South Florida Ave.**

**Rockledge, FL 32955**

**Office (321) 637-5660**

**Fax (321) 633-2109**

Email [fire.prevention@brevardfl.gov](mailto:fire.prevention@brevardfl.gov)



**Occupant Name:** Marina Village Condo Association 550

**Address:** 550 South Banana River Drive

**Suite:**

**City:** Merritt Island

**Zip Code:** 32952

**Inspection Date:** 5/14/2025

**InspectionType:** NC: Fire Alarm Final

**Structure Name:** Condo 550

**Inspected By:** Marc Sciacca  
321-637-5660

**Occ. Sq. Ft.:** 32566

Insp. Result	Location	Code Set	Code
--------------	----------	----------	------

N/A	Floor 1	Codes Verifications	101 - Verify square footage. This item is for the fire inspector only. No action is required from occupant/owner.
-----	---------	---------------------	---

**Inspector Comments:** NC fire final for new dialer install. Water flow test performed, signal sent, received by dispatch. Test complete passed on permit #25FP00199.

**ALL Fire Code violations** shall be corrected **IMMEDIATELY**. The re-inspection date is for verification of compliance **ONLY!** Failure to bring these discrepancies / violations into compliance will result in **additional inspection fees**. Any request for extensions of time to correct any violations must be in writing. If the request is approved, notification of the approval will be in writing. **This inspection is not a license to operate**. If you have any questions, please get in touch with the Fire Marshal's office at (321) 637-5660.

**Inspector:**

Signature valid only in mobile-eyes documents

**Marc Sciacca**

5/14/2025