



PUBLIC WORKS DEPARTMENT
(BUILDINGS AND ROADS)
O/o Executive Engineer, Provincial Division No. 2,
Rohtak - 124001
Tel- 01262-251879
Fax-01262-251879
E-mail:- pwd-ee2-rohtak@hry.nic.in



To

The Principal,
Dr. Sarup Singh Govt. Model,
Sanskriti Sr. Sec. School,
Sanghi (Rohtak)

Memo no.: 1745


Dated: 18/6/2024

Subject: - Issue of Building Safety Certificate.

Reference: Your office letter No. CBSE Spl/01 dated 13.05.2024.

In the above context, it is to inform you that the building of the Dr. Sarup Singh Govt. Model, Sanskriti Sr. Sec. School, Sanghi Rohtak has been visual inspected by the Sub Divisional Engineer alongwith concerned JE & reported that there is no major cracks are visible in the building & overall condition of the building is satisfactory. The school building seems to be structurally safe. The structural stability certificate is hereby issued for a period of one year from the date of issuance of this letter.

D.A. / Nil



Executive Engineer,
Provincial Division No.2,
PWD B&R Deptt., Rohtak

Endst. No.

Dated:

A copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. I, PWD B&R Rohtak w.r.t. your office 258 dated 12.06.2024 for information.

D.A. / Nil


Executive Engineer,
Provincial Division No.2,
PWD B&R Deptt., Rohtak

Office of the Civil Surgeon, Rohtak
Hygienic & Sanitation Certificate

AUO/Health/2024/ 141



Date 11-06-2024

This is to certify the premises of **Dr. SARUP SINGH GOVT MODEL SANSKRITI SR. SEC. SCHOOL, Sanghi, Rohtak** have been visited, there is adequate space & rooms in School. The rooms of the school are well ventilated. All the rooms and vicinity of the institution are neat and clean. There is adequate facility of drinking water & urinal etc. for students and staff. It is concluded that the sanitary conditions of the School are satisfactory. This NOC is valid from **05/06/2024 to 04/06/2025.**


Medical Officer
O/o Civil Surgeon, Rohtak

TO WHOM IT MAY CONCERN

It is certified that drinking water supplied in Dr. Sarup Singh Govt. Model Sanskriti Sr. Sec. School Sanghi is fit and safe for drinking.


Sub Divisional Engineer
P.H.E. Sub Divn. No. 7
ROHTAK

15/5/2024

From Assistant Divisional Fire Officer/Fire Station Officer
Rohtak

To M/s G M S S S School
Village Sanghi Rohtak

Memo No. FS/2022/301 dated : 14/09/2022

Subject: Renewal of Fire Safety Certificate Under 15 mtrs. height from the fire Safety Point of View of the Group B-Educational Building at Village Sanghi Rohtak of G M S S S School :

Reference to you online No 160932223000354 dated 12/08/2022 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Block 1	Ground Floor Only	3.81 M	792.58 SQM
Block 2	Ground Floor Only	3.81 M	691.11 SQM
Block 3	Ground Floor Only	3.81 M	836.57 SQM
Block 4	Ground Floor Only	3.81 M	512.92 SQM
Block 5	Ground Floor Only	3.81 M	115.89 SQM
Block 6	Ground Floor Only	3.81 M	574.13 SQM
Basement Level	Basement Area	Remarks	
----	----	----	

Your site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, Rohtak from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Safety Certificate.

The open set back area is not checked at our end as it shall be checked by concerned building department.

- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30,31 & 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- Approved By CMC Rohtak

Assistant Divisional Fire
Officer

Digitally signed by RAMESH
KUMAR JANGRA
Date: 2022.09.14 17:39:24 +05:30
Reason: Digital Verification



Rohitak
Exercising the power of Director, Fire Services, Haryana

