

ELMIRA WATER BOARD

Elmira, New York

Bids for Estimated 2027 Requirements for:

PRICING IS FOR JANUARY 1, 2027 through DECEMBER 31, 2027

CURB WELL CASTINGS

Bids on the estimated requirements for curb well castings will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 1:30 P.M., EST, on Wednesday, October 14, 2026. At this time the bids will be publicly opened and read.

Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Iranian Energy Divestment Certificate, Bidder's Statement on Sexual Harassment, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

Bid will be on approximately 200 Rod Type Service Box, Quality Water Products curb well casting or equal.

The above amounts are estimates only and the quantities actually ordered will be as needed to meet demands during 2027.

Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira New York. Curb wells will be ordered as required.

The Board reserves the right to reject any or all bids and to re-advertise for new bids at its discretion.

Rod type service box shall be of the rod type. Upper section shall be 1" steel pipe threaded on one end, and a double swedge to be made on the other. Base shall be ASTM A126 gray cast iron, and shall have a locking ring at the top to hold the box at a desired height. Box shall have a maximum extension of 5 ½ feet and a minimum of 1" adjustment. Plug cover shall be cast iron having a deep slot for the release of water and debris. Pentagon plug shall be brass with a coarse rope type thread for quick and easy removal. **Service box rod shall be 36 inch steel with a ductile iron yoke.** The yoke shall have a **brass pin** to attach the rod to the curb stop. Rods shall have a brass 9/16", 5/8", or 3/4" diameter. The service boxes shall be manufactured by Quality Water Products or approved equal.

BIDDER NAME: _____

ADDRESS: _____

PHONE: _____ FAX: _____

EMAIL: _____

<u>Description</u>	<u>Catalog Number</u>	<u>Price for Each</u>
Rod Type Service Box	Quality Water Products or equal	\$ _____