

ELMIRA WATER BOARD

Elmira, New York

Bids on estimated 2026 requirements for:

PRICING IS FOR JANUARY 1, 2026 through DECEMBER 31, 2026

Liquid Sodium Permanganate

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York until 1:30 P.M., EST, on Tuesday, October 14, 2025, and at that time will be publicly opened and read.

The amounts below are estimates only and the quantities actually ordered will be needed to meet demands during 2026.

Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Iranian Energy Divestment Certificate, Bidder's Statement on Sexual Harassment, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Board reserves the right to reject any or all bids and to re-advertise for new bids at its discretion.

- | | | |
|-------------------|---|---|
| <u>Amount</u> | - | Approximately 8,000 gallon/year |
| <u>Standard</u> | - | AWWA B603-2003 NSF Certification
Liquid Sodium Permanganate supplied according to the provisions of this standard shall contain approximately 20 percent Sodium Permanganate (K ₂ MnO ₄). Final acceptance of the bid is contingent upon the provider receiving approval from the Chemung County Health Department for use of the provider's product. |
| <u>Bid Amount</u> | - | Price should be quoted unit price per gallon delivered and should <u>include</u> any other charges (freight and shipping, Superfund, insurance surcharge, etc.) associated with the purchase of this product. |
| <u>Delivery</u> | - | All deliveries must be made in dedicated tanker/container used exclusively for the shipment of 20% Liquid Sodium Permanganate to maintain product integrity and purity. |

Each delivery will include the lot sample and certificate of analysis for that lot, as well as a current safety data sheet.

Provide copy of NSF certification.

Vendor must have the capabilities to deliver product within ninety-six (96) hours.

Further, all deliveries of this product shall be shipped in 1,000 gallon quantities as ordered to the 1 Fountain Drive., Elmira, New York between the hours of 7:00 AM to 3:00 PM, Monday through Friday unless otherwise stated on the purchase order. Please call 732-2277 to schedule delivery.

Deliveries will be by bulk tanker in quantities requested by the Elmira Water Board not to exceed one thousand (1,000) gallons. The truck is to be equipped with pumping

equipment, hoses, hose connections and an air blow-off valve to unload into the Elmira Water Board's bulk storage tank.

Invoicing - Invoices must be in the same unit of measurement as quoted on bid sheet. Specification compliance must be shown on purchase order contract.

Specification Compliance - Sodium Permanganate (as KMnO_4) as a percentage shall be between 19.5 minimum to 20.5 maximum.